
Pacific Energy

Project # 034-S-074-1

Model: TN20 (series B), TN20 Insert
(series B), (AKA: True North 20)

Type: Free Standing / Insert

Residential Non-catalytic Wood Fired
Heater

January 27, 2017

Revised: 11/12/2021, 12/7/2021

EPA Test Method 28R for
Certification and Auditing of Wood
Heaters

Contact:

Mr. Jeff Bain

2975 Allenby Road

Duncan, BC

Canada V9L 6V8

Jeff.Bain@pefp.net

(250) 715-2398

Prepared by: Doug Towne, QA Manager



11785 SE Highway 212 – Suite 305

Clackamas, OR 97015-9050

(503) 650-0088

WWW.DIRIGOLAB.COM

Revision History:

11/11/2021: The following revisions were made to the report.

- CO added in g/m - page 12
- Negative filter weight statement- page 17
- Added additional fuel load pictures to body of report-page 28
- Confirmed conditioning data compliant.
- Added firebox volume- page 21
- Added precision statement- page 14
- 1-hour filter pull data added– page 14
- Confirmed minimum chimney height recommendation and warranty in manual.

12/7/2021

- Updated “Process Operation and Description” to include reference to operating procedures that were supplied by the manufacturer.

11/12/2021:

Request for renewal submitted. New Certificate of Conformity Issued by PFS.

Table of Contents

Affidavit:	4
Introduction:	5
Notes:	5
Wood Heater Identification and Testing:	6
<i>Test Procedures and Equipment:</i>	<i>7</i>
Results:	8
Efficiency:	10
Summary Table:	12
Run 2:	12
Run 3:	12
Run 4:	13
Run 5:	13
Run 6:	13
One Hour Particulate Data:	14
Precision Statement:	14
Filter Catch & Negative Weights Statement:	15
Run 1:	15
Run 2:	15
Run 3:	16
Run 4:	16
Run 5:	17
Run 6 – Fan Confirmation:	18
Test Condition Summary:	19
Heater Specifications:	19
Heater Dimensions	19
Air Flow Schematic	20
Firebox Volume:	21
Process Operations and Description:	26
Settings & Run Notes	26
Test Fuel Properties:	27
Fuel Load Run Pictures:	28
Sampling Locations and Descriptions:	30
Sample Points	30

Sampling Methods:	31
Analytical Methods Description:	31
Calibration, Quality Control and Assurances:	31
Appliance Sealing and Storage:	31
<i>Sealing Label</i>	31
<i>Sealed Unit</i>	32
Appendices:	34
Appendix A:	34
Sampling and Analytical Procedures	34
Appendix B:	34
Participants.....	34
Analysis and Report Writing	34
Observers:.....	34
Appendix C:	34
Appliance Updates	34
Appendix D:	35
Test Equipment Calibration Audit:.....	35
Appendix E:	36
Accreditations:.....	36

Affidavit:

Dirigo Laboratories, Inc. was contracted by Pacific Energy Fireplace Products Ltd. to provide testing services for the True North 20 (series B) non-catalytic wood fired heater per EPA Method 28R for Certification and Auditing of Wood Heaters. All testing and associated procedures were conducted at Dirigo Laboratories, Inc. beginning on 12/13/2016 and ending on 12/20/2016. Dirigo Laboratories is located at 11785 SE Highway 212 – Suite 305, Clackamas, Oregon 97015. Testing procedures followed EPA Method 28R and ASTM E2780-10. Particulate sampling was performed per ASTM E2515-10 *Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel*.

Dirigo Laboratories is accredited by the U.S. Environmental Protection Agency for the certification and auditing of wood heaters pursuant to subpart AAA of 40 CFR Part 60, New Source Performance Standards for Residential Wood Heaters and subpart QQQQ of 40 CFR Part 60, Standards of Performance for New Hydronic Heaters and Forced Air Furnaces, Methods 28R, 28WHH, 28 WHH-PTS, and all methods listed in Sections 60.534 and 60.5476. Dirigo holds EPA Accreditation Certificate Numbers 4 and 4M (mobile). Dirigo Laboratories, Inc. is accredited by A2LA to ISO 17020:2012 "Criteria for Bodies Performing Inspections, ISO 17025:2005 "Requirements for Testing Laboratories", and ISO 17065:2012 "Requirements for Bodies Operating Product Certification Systems". Dirigo holds A2LA Certificate Numbers 3726.01, 3726.02, and 3726.03. See Appendix E for Accreditations.

The following people were associated with the testing, analysis and report writing associated with this project.

Ben Nelke

Digitally signed by Ben Nelke
DN: cn=Ben Nelke, o, ou,
email=bnelke@dirigolab.com,
c=US
Date: 2017.02.01 11:45:26 -08'00'

Ben Nelke, Test Technician

**Doug
Towne**

Digitally signed by Doug Towne
DN: cn=Doug Towne, o=Dirigo,
ou=QA/QC,
email=dtowne@dirigolab.com, c=US
Date: 2017.02.01 11:39:08 -08'00'

Doug Towne, QA Manager

Introduction:

Pacific Energy Fireplace Products Ltd. of Duncan, BC, contracted with Dirigo Laboratories, Inc. to perform EPA certification testing for their Model True North 20 (series B) non-catalytic wood heater. All testing was performed at Dirigo Laboratories, Inc. Testing was performed by Mr. Ben Nelke and Mr. Gary Nelke, CMfgE.

Notes:

- A 50 hour break-in was performed on the appliance: 37 hours by the manufacturer prior to the test series; and 13 hours during assessment runs at Dirigo Laboratories, Inc.
- Prior to testing, the dilution tunnel was cleaned with a steel brush.
- Run #'s 1, 2, 3, 4 & 5 were performed with the convection blower in operation. Run #6 was the blower confirmation run and was performed with the convection blower off.
- Front filters were changed on sample train A at one hour for all runs.

Wood Heater Identification and Testing:

- Appliance Tested: ***TN20 (series B) Free Standing***
- Serial Number: ***TN20 001***
- Manufacturer: ***Pacific Energy Fireplace Products Ltd.***
- Catalyst: ***No***
- Heat exchange blower: ***Optional***
- Type: ***Wood Stove***
- Style: ***Free Standing***
- Date Received: ***Friday, December 02, 2016***
- Wood Heater Aging: ***November 20 - December 8, 2016***
- Testing Period – Start: ***Tuesday, December 13, 2016*** Finish: ***Tuesday, December 20, 2016***
- Test Location: ***Dirigo Laboratories, Inc. 11785 SE HWY 212 - Suite 305, Clackamas, OR 97015***
- Elevation: ***≈131 Feet above sea level***
- Test Technician(s): ***Ben Nelke, Gary Nelke***
- Observers: ***Ken Davis***

Test Procedures and Equipment:

All Sampling and analytical procedures were performed by Ben Nelke and Gary Nelke. All procedures used are directly from EPA Method 28R, ASTM E2780-10 and ASTM E2515-10. See the list below for equipment used. See Appendix D for calibration data.

Equipment List:

1. Analyzer -California Analytical ZRE CO2/CO/O2 IR ANALYZER
2. Delmhorst J-2000 Wood Moisture Meter
3. Dayton 4c121 Blower for dilution tunnel -Emissions Booth #1
4. ScienTech Balance Scale
5. 10 lb Calibration Weight
6. DigiWeigh Bench Shipping Scale
7. APEX XC-60 Digital Emissions Sampling Box A
8. APEX XC-60 Digital Emissions Sampling Box B
9. APEX Ambient sampling box
10. Gast MOA-P122-AA Vacuum Pump
11. Rice Lake 3'x3' floor scale w/digital weight indicator

Results:

The weighted average emission rate is **1.6 g/hr** with a weighted average efficiency of **72.7%** and an average CO of **1.56 g/min**. The Pacific Energy Fireplace Products Ltd. Model True North 20 (series B) non-catalytic wood heater meets the 2020 PM emission standard of ≤ 2.0 g/hr per CFR 40 part 60, §60.532 (b).

Detailed individual run data can be found in separate digital folders supplied with this report.


Emissions:

EPA Method 28 - Weighted Average			
			
Weighted Average: 1.6 (g/hr)			
Client:	Pacific Energy		
Model:	TN20 (series B)		
Tracking No.:	74		
Project No.:	034-S-74-1		
Test Dates:	12/13/16 - 12/20/16		
Burn Rate Category	2	Burn Rate Category	2
Burn Rate (kg/hr-dry)	0.97	Burn Rate (kg/hr-dry)	1.01
Emissions Rate (g/hr)	1.4	Emissions Rate (g/hr)	1.4
Emissions Rate Cap (g/hr)	15	Emissions Rate Cap (g/hr)	15
Weighting Factor	24.47%	Weighting Factor	3.01%
Run Number	5	Run Number	2
Burn Rate Category	2	Burn Rate Category	3
Burn Rate (kg/hr-dry)	1.03	Burn Rate (kg/hr-dry)	1.64
Emissions Rate (g/hr)	0.9	Emissions Rate (g/hr)	2.2
Emissions Rate Cap (g/hr)	15	Emissions Rate Cap (g/hr)	18
Weighting Factor	27.59%	Weighting Factor	33.51%
Run Number	1	Run Number	3
Burn Rate Category	4		
Burn Rate (kg/hr-dry)	2.09		
Emissions Rate (g/hr)	2.0		
Emissions Rate Cap (g/hr)	18		
Weighting Factor	11.43%		
Run Number	4		



EPA Method 28 - Weighted Average

Client: Pacific Energy
Model: TN20 (series B)
Tracking No.: 74
Project No.: 034-S-74-1
Test Dates: 12/13/16 - 12/20/16



Efficiency:

All efficiency values use the HHV.


		CSA B415.1-10 Weighted Average			
Weighted Average:		72.7	%		
Client:	Pacific Energy				
Model:	TN20 (series B)				
Tracking No.:	74				
Project No.:	034-S-74-1				
Test Dates:	12/13/16 - 12/20/16				
Burn Rate Category	2	Burn Rate Category	2		
Burn Rate (kg/hr-dry)	0.97	Burn Rate (kg/hr-dry)	1.01		
OA Efficiency %	72.2	OA Efficiency %	72.9		
Emissions Rate Cap (g/hr)	15	Emissions Rate Cap (g/hr)	15		
Weighting Factor	24.47%	Weighting Factor	3.01%		
Run Number	5	Run Number	2		
Burn Rate Category	2	Burn Rate Category	3		
Burn Rate (kg/hr-dry)	1.03	Burn Rate (kg/hr-dry)	1.64		
OA Efficiency %	74.5	OA Efficiency %	72.2		
Emissions Rate Cap (g/hr)	15	Emissions Rate Cap (g/hr)	18		
Weighting Factor	27.59%	Weighting Factor	33.51%		
Run Number	1	Run Number	3		
Burn Rate Category	4				
Burn Rate (kg/hr-dry)	2.09				
Emissions Rate (g/hr)	70.6				
Emissions Rate Cap (g/hr)	18				
Weighting Factor	11.43%				
Run Number	4				

CSA B415.1-10 - Weighted Average



Client: Pacific Energy
Model: TN20 (series B)
Tracking No.: 74
Project No.: 034-S-74-1
Test Dates: 12/13/16 - 12/20/16

EPA Method 28 - Weighted Average



Summary Table:

Category 2 < 1.00 kg/hr		Category 2 0.80 to 1.25 kg/hr		Category 2 0.80 to 1.25 kg/hr		Category 3 1.25 to 1.90 kg/hr		Category 4 Maximum	
Run Number	5	Run Number	2	Run Number	1	Run Number	3	Run Number	4
Emissions Rate g/hr	1.35	Emissions Rate g/hr	1.38	Emissions Rate g/hr	0.89	Emissions Rate g/hr	2.20	Emissions Rate g/hr	2.04
Burn Rate kg/hr	0.97	Burn Rate kg/hr	1.01	Burn Rate kg/hr	1.03	Burn Rate kg/hr	1.64	Burn Rate kg/hr	2.09
BTU/hr (HHV)	13,931	BTU/hr (HHV)	24,633	BTU/hr (HHV)	15,161	BTU/hr (HHV)	23,451	BTU/hr (HHV)	29,208
CO g/min	1.75	CO g/min	1.65	CO g/min	1.32	CO g/min	1.51	CO g/min	1.55
OA Efficiency (HHV)	72.2%	OA Efficiency (HHV)	72.9%	OA Efficiency (HHV)	74.5%	OA Efficiency (HHV)	72.2%	OA Efficiency (HHV)	70.6%

Run 1:

An attempt at a category II burn rate <1.00 kg/hr was performed on 12/13/16, resulting in a 1.03 kg/hr category II burn rate. The test duration was 5 hours 10 minutes. The fuel weight was 14.0 lbs. There was an average particulate emissions rate of 0.89 g/hr. The run had an overall efficiency of 74.5%. The A filter was changed at 1 hr. The 1-hour filter catch was 3.57g/hr. All test results were appropriate and valid. The burn rate category was achieved. There were no anomalies and all criteria were met.

Run 2:

An additional attempt at a category II burn rate <1.00 kg/hr was performed on 12/14/16, resulting in a 1.01 kg/hr category II burn rate. The test duration was 5 hours 10 minutes. The fuel weight was 13.8 lbs. There was an average particulate emissions rate of 1.38 g/hr. The run had an overall efficiency of 72.9%. The A filter was changed at 1 hr. The 1-hour filter catch was 6.5 g/hr. All test results were appropriate and valid. The burn rate category was achieved. There were no anomalies and all criteria were met.

Run 3:

Run 3 was a category III burn rate performed on 12/14/16. The test duration was 3 hours 10 minutes. The fuel weight was 13.7 lbs. There was an average particulate emissions rate of 2.20 g/hr. The run had an overall efficiency of 72.2%. The A filter

was changed at 1 hr. The 1-hour filter catch was 5.91 g/hr. All test results were appropriate and valid. The burn rate category was achieved. There were no anomalies and all criteria were met.

Run 4:

Run 4 was a category IV burn rate performed on 12/15/16. The test duration was 2 hours 30 minutes. The fuel weight was 13.6 lbs. There was an average particulate emissions rate of 2.04 g/hr. The run had an overall efficiency of 70.6%. The A filter was changed at 1 hr. The 1-hour filter catch was 4.52 g/hr. All test results were appropriate and valid. The burn rate category was achieved. There were no anomalies and all criteria were met.

Run 5:

Run 5, performed on 12/16/16 and resulting in 0.97 kg/hr, was a successful category II burn rate <1.00 kg/hr. The test duration was 5 hours 20 minutes. The fuel weight was 13.7 lbs. There was an average particulate emissions rate of 1.35 g/hr. The run had an overall efficiency of 72.2%. The A filter was changed at 1 hr. The 1-hour filter catch was 5.65 g/hr. All test results were appropriate and valid. The burn rate category was achieved. There were no anomalies and all criteria were met.

Run 6:

Run 6 was the fan confirmation run performed on 12/20/16. The test duration was 5 hours. The fuel weight was 13.6 lbs. There was an average particulate emissions rate of 2.16 g/hr. The one-hour filter catch was 10.74 g/hr. Per Method 28 & ASTM E2515-10 a category II run was performed with the fan in the off position. The emission rate resulting from this test run without the blower operating is equal to or less than the emissions rate plus 1.0 g/h for the test run in the medium burn rate category with the blower operating. Because of this, the wood heater is considered to have the same average emissions rate with or without the blower operating. Additional test runs without the blower operating are unnecessary. Results from Run 6 are not included in the calculation of results.

One Hour Particulate Data:

Run Number	Total Estimated PM Emissions at 1 hour
1	3.57
2	6.5
3	5.91
4	4.52
5	5.65
6*	10.74

*-Fan confirmation

Precision Statement:

Dual Train Comparison (ASTM E2515 11.7 - If either criterion (7.5% of average or 0.5 g/kg difference) is met, the run is valid.									
Run #	Train A % of avg.	Train B % of avg.	Max difference	<7.5% of average?	Or	Train A g/kg	Train B g/kg	Difference	<0.5 g/kg from each other?
1	100.1	99.9	0.1	✓					
2	104.5	95.5	4.5	✓					
3	99.9	100.1	0.1	✓					
4	99.0	101.0	1.0	✓					
5	100.3	99.7	0.3	✓					
6	104.7	95.3	4.7	✓					

Filter Catch & Negative Weights Statement:

Run 1:

Project #	034-S-74-1		MFG	Pacific Energy	
Run #	1		Model	TN20 (series B)	
Date	12/20/16				

Train A	Front	Rear	Filter #	Tare	Final	Net
First Hour	☒	☐	2992	0.1187	0.1219	0.0032
	☐	☒	2993			
	☒	☐	2997	0.2380	0.2387	
	☒	☐	O Ring			
	☐	☒	O Ring	3.5766	3.5770	0.0011
					4.3	mg

Train B	Front	Rear	Filter #	Tare	Final	Net
	☒	☐	2994			
	☐	☒	2995	0.2383	0.2419	
	☒	☐	O ring			
	☐	☒	O ring	3.5411	3.5416	0.0041
					4.1	mg

Nozzle	#	TARE	FINAL	Net
	9A	116.7186	116.7186	0.0000
				0.0

Nozzle	#	TARE	FINAL	Net
	9B	117.1380	117.1381	0.0001
				0.1

Train A Total Catch	4.3
---------------------	-----

Train B Total Catch	4.2
---------------------	-----

Ambient ☐	Filter #	Tare	Final	Net	Vol (liter)
	2996	0.1186	0.1186	0.0000	1715.259
	O ring	1.6849	1.6850	0.0002	
Total				0.2	mg

Notes: Train A Total: 4.3mg Train B Total: 4.2mg Ambient Total: 0.2mg 1 Hour Catch: 3.2mg

Run 2:

Project #	034-S-74-1		MFG	Pacific Energy	
Run #	2		Model	TN20 (series B)	
Date	12/20/16				

Train A	Front	Rear	Filter #	Tare	Final	Net
First Hour	☒	☐	2998	0.1181	0.1240	0.0059
	☐	☒	2999			
	☒	☐	3003	0.2358	0.2364	
	☒	☐	O Ring			
	☐	☒	O Ring	3.5799	3.5804	0.0011
					7.0	mg

Train B	Front	Rear	Filter #	Tare	Final	Net
	☒	☐	3000			
	☐	☒	3001	0.2365	0.2425	
	☒	☐	O ring			
	☐	☒	O ring	3.5164	3.5166	0.0062
					6.2	mg

Nozzle	#	TARE	FINAL	Net
	11A	117.0372	117.0372	0.0000
				0.0

Nozzle	#	TARE	FINAL	Net
	11B	116.6756	116.6757	0.0001
				0.1

Train A Total Catch	7.0
---------------------	-----

Train B Total Catch	6.3
---------------------	-----

Ambient ☒	Filter #	Tare	Final	Net	Vol (liter)
	3002	0.1184	0.1186	0.0002	1726.447
	O ring	1.6564	1.6565	0.0001	
Total				0.3	mg

Notes: Train A Total: 7.0mg Train B Total: 6.3mg Ambient Total: 0.3mg 1 Hour Catch: 5.9mg

Run 3:

Project #	034-S-74-1		MFG	Pacific Energy	
Run #	3		Model	TN20 (series B)	
Date	12/20/16				

Train A	Front	Rear	Filter #	Tare	Final	Net
First Hour	☒	☒	3004	0.1181	0.1234	0.0053
	☐	☒	3005			
	☒	☐	3009	0.2366	0.2367	
	☒	☐	O Ring			
	☐	☒	O Ring	3.5745	3.5749	0.0005
						5.8 mg

Train B	Front	Rear	Filter #	Tare	Final	Net
	☒	☐	3006			
	☐	☒	3007	0.2367	0.2420	
	☒	☐	O ring			
	☐	☒	O ring	3.5597	3.5603	0.0059
						5.9 mg

Nozzle	#	TARE	FINAL	Net
	7A	116.7505	116.7510	0.0005
				0.5

Train A Total Catch	Train B Total Catch
6.3 mg	6.2 mg

Ambient	Filter #	Tare	Final	Net	Vol (liter)
☒	3008	0.1189	0.1189	0.0000	1054.703
	O ring	1.6639	1.6639	0.0000	
	Total			0.0 mg	

Nozzle	#	TARE	FINAL	Net
	7B	117.3054	117.3057	0.0003
				0.3

Notes:	Train A Total: 6.3mg Train B Total: 6.2mg Ambient Total: 0.0mg 1 Hour Catch: 5.3mg				
--------	---	--	--	--	--

Run 4:

Project #	034-S-74-1		MFG	Pacific Energy	
Run #	4		Model	TN20 (series B)	
Date	12/20/16				

Train A	Front	Rear	Filter #	Tare	Final	Net
First Hour	☒	☒	3010	0.1187	0.1228	0.0041
	☐	☒	3011			
	☒	☐	3015	0.2362	0.2363	
	☒	☐	O Ring			
	☐	☒	O Ring	3.5379	3.5384	0.0006
						4.7 mg

Train B	Front	Rear	Filter #	Tare	Final	Net
	☒	☐	3012			
	☐	☒	3013	0.2388	0.2429	
	☒	☐	O ring			
	☐	☒	O ring	3.5897	3.5900	0.0044
						4.4 mg

Nozzle	#	TARE	FINAL	Net
	8A	116.8311	116.8311	0.0000
				0.0

Train A Total Catch	Train B Total Catch
4.7 mg	4.7 mg

Ambient	Filter #	Tare	Final	Net	Vol (liter)
☒	3014	0.1188	0.1188	0.0000	833.188
	O ring	1.6864	1.6865	0.0001	
	Total			0.0 mg	

Nozzle	#	TARE	FINAL	Net
	8B	116.8259	116.8262	0.0003
				0.3

Notes:	Train A Total: 4.7mg Train B Total: 4.7mg Ambient Total: 0.1mg 1 Hour Catch: 4.1mg				
--------	---	--	--	--	--

Run 5:

Project #	034-S-74-1					MFG	Pacific Energy								
Run #	5					Model	TN20 (series B)								
Date	12/20/16														
Train A	Front	Rear	Filter #	Tare	Final	Net	Train B	Front	Rear	Filter #	Tare	Final	Net		
First Hour	☒		3016	0.1173	0.1224	0.0051		☒	☐	3018					
	☐	☒	3017					☐	☒	3019	0.2337	0.2395			
	☒	☐	3021	0.2347	0.2357			☒	☐	O ring					
	☒	☐	O Ring					☐	☒	O ring	3.5450	3.5454	0.0062		
	☐	☒	O Ring	3.5390	3.5393	0.0013									
						6.4	mg						6.2	mg	
Nozzle							Nozzle								
#	TARE		FINAL	Net			#	TARE		FINAL	Net				
2A	116.2355		116.2355	0.0000		0.0	2B	116.3287		116.3287	0.0000		0.0		
Train A Total Catch						6.4	mg	Train B Total Catch						6.2	mg
Ambient	☒	Filter #	Tare	Final	Net	Vol (liter)									
		3020	0.1164	0.1164	0.0000	1721.635									
		O ring	1.6834	1.6834	0.0000										
		Total			0.0	mg									
Notes:	Train A Total: 6.4mg Train B Total: 6.2mg Ambient Total: 0.0mg 1 Hour Catch: 5.1mg														

Run 6 – Fan Confirmation:

Project #	034-S-74-1		MFG	Pacific Energy	
Run #	6		Model	TN20 (series B)	
Date	12/22/16				

Train A	Front	Rear	Filter #	Tare	Final	Net	Train B	Front	Rear	Filter #	Tare	Final	Net
First Hour	☒		3022	0.1171	0.1264	0.0093		☒	☐	3024			
	☐	☒	3023					☐	☒	3025	0.2350	0.2437	
	☒	☐	3027	0.2361	0.2365			☒	☐	O ring			
	☒	☐	O Ring					☐	☒	O ring	3.5701	3.5706	0.0092
	☐	☒	O Ring	3.5809	3.5814	0.0009							
						10.2 mg							9.2 mg

Nozzle	#	TARE	FINAL	Net
	3A	116.0714	116.0714	0.0000
	3B	116.3383	116.3383	0.0000

Train A Total Catch	10.2	Train B Total Catch	9.2
---------------------	------	---------------------	-----

Ambient	Filter #	Tare	Final	Net	Vol (liter)
☒	3026	0.1170	0.1172	0.0002	1565.189
	O ring	1.6737	1.6740	0.0003	
	Total			0.5 mg	

Notes:	Train A Total: 10.2mg	Train B Total: 9.2mg	Ambient Total: 0.5mg	1 Hour Catch: 9.3mg
--------	-----------------------	----------------------	----------------------	---------------------

There were no negative filter weights recorded.

Test Condition Summary:

All testing conditions for all runs fell within allowable specifications of EPA Method 28R, ASTM E2780-10 and ASTM E2515-10. A summary of facility conditions, temperature averages, fuel burned and run times is listed below.

Runs	Ambient (Deg. F)		Barometric Pressure (In. Hg.)	Test Fuel Burned (Lbs.)	Test Fuel Moisture (Dry Basis)	Run Time (Min.)
	Pre	Post				
1	70	69	30.20	14.0	19.7	310
2	70	71	29.96	13.8	19.6	310
3	74	72	29.96	13.7	19.8	190
4	75	74	29.91	13.6	19.9	150
5	71	72	30.12	13.7	19.7	320
6	77	73	30.30	13.6	19.7	300


Heater Specifications:

Dimensions, firebox configuration, air supply locations, air introduction locations, and baffle locations of the wood heater are referenced below and on the following page.

Heater Dimensions

Heater Dimensions				
Height	Width	Depth	Firebox Volume	Weight
11.469"	15.25"	18.094"	1.996 ft ³	255 lbs

Air Flow Schematic



Firebox Volume:

DESCRIPTION:	USEABLE FIREBOX VOLUME	MODEL	TN20
		SERIES	B
		DRAWING #	TN20 #9

VOLUME: DEPTH X WIDTH X HEIGHT

VOLUME 1: 17 27/32 X 15 1/4 X 11 15/32 = 3120.844 IN^3


VOLUME 2: 2 5/16 X 14 3/32 X 8 17/32 = 278.049 IN^3

VOLUME 3: 4 1/4 X 15 1/4 X 25/32 = 0.029 IN^3

USEABLE FIREBOX VOLUME= VOLUME 1 + VOLUME 2 + VOLUME 3

USEABLE FIREBOX VOLUME = 3210.844 + 278.049 + 0.029 =3449.528 IN^3

USEABLE FIREBOX VOLUME = 1.996 FT^3



Front



Left



Right



Rear



Process Operations and Description:

The appliance was operated according to procedures as described in the Operations Manual. Detailed run instructions were provided to the lab and are consistent with the general instructions in the Operations Manual. information can be found in corresponding digital folders submitted with this report.

Settings & Run Notes

	Run Notes	
	Pre-Burn	Test Run
Run 1	Primary set to 0.212". Start at 1054	Category II. Test start: 1155 – Door open 1 minute 30 seconds, Primary fully open. At 5 mins Primary air set to 0.212", fan off. Fan set to high at 1215. Front Filter change at 1255. END test: 1705 – Run time 5 hours, 10 minutes.
Run 2	Primary set to 0.165". Start at 1249	Category II. Test start: 1350 – Door open 2 minutes, Primary fully open. At 5 mins Primary air set to 0.165", fan off. Fan set to high at 1410. Front Filter change at 1450. END test: 1900 – Run time 5 hours, 10 minutes.
Run 3	Primary set to 0.720". Start at 2037	Category III: Test start: 2138 – Door open 1 minute 30 seconds, Primary fully open. At 5 mins Primary set to 0.0720", fan off. Fan set to high at 2158. Front filter change at 2238. END Test: 0048 – Run time 3 hours 10 mins.
Run 4	Primary fully open. Start at 0309	Category IV: Test start: 0415. Door Open 1 minute 30 seconds, Primary air fully open and left open. Fan on high. Front filter changed at 0515. END test: 0645 – Run Time: 2 hours 30 minutes.
Run 5	Primary set to 0.125". Start at 1348	Category II (average below 1.00 kg/hr): Test start: 1450 – Door open 1 minute 30 seconds, At 5 mins primary set to 0.125", fan off. Fan set to high at 1510. Front filter changed at 1550. END test: 2030 – Run time 5 hours 20 minutes.
Run 6	Primary set to 0.125". Start at 1230	Fan Confirmation – Fan OFF. Category II: Test start: 1341. Door open 1 minute 30 seconds, Primary open for 5 minutes, fan off. Fan remained off for entire test. Changed front filter at 1441. END test: 1841 – Run time: 5 hours.

Test Fuel Properties:



Fuel consisted of 2"x4"x18.25" and 4"x4"x18.25" Green, Douglas fir. Detailed fuel load specifications for each run can be found in the corresponding digital folders submitted with this report.

Fuel Load Run Pictures:



Run 1



Run 2



Run 3



Run 4





Run 5

Detailed fuel data for all runs in appendix.

Sampling Locations and Descriptions:

Sample ports are located 16.5 feet downstream from any disturbances and 1 foot upstream from any disturbances. Flow rate traverse data was collected 12 feet downstream from any disturbances and 5.5 feet upstream from any disturbances. (See below)

Sample Points



Sampling Methods:

EPA ASTM E2515-11 was used in collecting particulate samples. The dilution tunnel is 6 inches in diameter. All sampling conditions per ASTM E2515-11 were followed. No alternate procedures were used.

Analytical Methods Description:

All sample recovery and analysis procedures followed EPA ASTM E2515-11 procedures. At the end of each test run, filters and probes were removed from their housings, dessicated for 24 hours, and then weighed at 6 hour intervals to a constant weight per ASTM E2515-11 section 11.0.

Calibration, Quality Control and Assurances:

Calibration procedures and results were conducted per EPA Method 28R, ASTM E2515-11 and ASTM E2780-10. Test method quality control procedures (leak checks, volume meter checks, stratification checks, proportionality results) followed the procedures outlined.

Appliance Sealing and Storage:

Following securing with metal strapping and the seal below, the appliance was placed into storage at client facilities located at: 2975 Allenby Road, Duncan, BC, Canada, V9L 6V8.

Sealing Label

ATTENTION:	
THIS SEAL IS NOT TO BE BROKEN WITHOUT PRIOR AUTHORIZATION FROM THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY.	
THIS APPLIANCE HAS BEEN SEALED IN ACCORDANCE WITH REQUIREMENTS OF 40 CFR PART 60 SUBPART AAA §60.535(g)	
REPORT # _____	DATE SEALED _____
MANUFACTURER _____	MODEL # _____

Sealed Unit





Appendices:

Appendix A:

Sampling and Analytical Procedures

All Sampling and analytical procedures were performed by Ben Nelke and Gary Nelke. All procedures used were directly from EPA Method 28R, ASTM 2515-11 and ASTM E2780-10. No alternative procedures were used for this test series.

Appendix B:

Participants

The following personnel performed all testing:

- Ben Nelke, Gary Nelke, CMfgE

Analysis and Report Writing

The following people were involved with analysis and report writing:

- Ben Nelke, Gary Nelke, CMfgE, Doug Towne

Observers:

The following people were observers during testing:

- Ken Davis

Appendix C:

Appliance Updates

No updates to the appliance were made.

Appendix D:

Test Equipment Calibration Audit:

- Calibrations for the platform scale and bench scale were performed with Certified Class F weights
- Moisture meter calibration was performed with Delmhorst moisture meter calibrator
- Gas Analyzer calibration performed with certified EPA Protocol gases
- 47mm filters weighed to a constant weight with calibrated analytical balance

All equipment calibration data submitted in separate digital file along with this report.

Appendix E:

*Accreditations:***CERTIFICATE OF ACCREDITATION**


This certifies that:



Dirigo Laboratories, Inc.

Has satisfied the requirements for laboratory accreditation for the certification of wood heaters pursuant to subpart AAA of 40 CFR Part 60, New Source Performance Standards For Residential Wood Heaters and subpart QQQQ of 40 CFR Part 60, Standards of Performance for New Hydronic Heaters and Forced Air Furnaces.

October 21, 2015 - October 21, 2020
EFFECTIVE DATE


MEASUREMENT TECHNOLOGY GROUP
GROUP LEADER

Methods 28R, 28 WHI, 28 WHI-PTS,
All Methods listed in Sections 60.534 and 60.5476
METHODS

4
CERTIFICATE NUMBER



American Association for Laboratory Accreditation

Accredited Inspection Body

A2LA has accredited

DIRIGO LABORATORIES, INC.

Clackamas, OR

for technical competence as an

Inspection Body

This inspection body is accredited in accordance with the recognized International Standard
ISO/IEC 17020:2012 *Conformity Assessment – Requirements for the operation of various types of bodies performing inspection*.
This accreditation demonstrates technical competence for a defined scope and the operation of a quality management system.

Presented this 17th day of October 2014.



Peter Mayne

President & CEO
For the Accreditation Council
Certificate Number 3726.03
Valid to December 31, 2016

For the inspections to which this accreditation applies, please refer to the organization's Inspection Body Scope of Accreditation.



American Association for Laboratory Accreditation

Accredited Laboratory

A2LA has accredited

DIRIGO LABORATORIES, INC.

Clakamas, OR

for technical competence in the field of

Mechanical Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 *General requirements for the competence of testing and calibration laboratories*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated 8 January 2009).

Presented this 17th day of October 2014.

A handwritten signature in black ink, reading "Peter M. Meyer", is positioned above the title of the signatory.

President & CEO
For the Accreditation Council
Certificate Number 3726.01
Valid to December 31, 2016



For the tests or types of tests to which this accreditation applies, please refer to the laboratory's Mechanical Scope of Accreditation.



American Association for Laboratory Accreditation

Accredited Product Certification Body

A2LA has accredited

DIRIGO LABORATORIES, INC.

Clackamas, OR

for technical competence as a

Product Certification Body

This product certification body is accredited in accordance with the recognized International Standard
ISO/IEC 17065:2012 *Conformity Assessment – Requirements for Bodies Certifying Products, Processes and Services*.
This accreditation demonstrates technical competence for a defined scope and the operation of a quality management system.

Presented this 17th day of October 2014.



President & CEO
For the Accreditation Council
Certificate Number 3726.02
Valid to December 31, 2016

For the product certification schemes to which this accreditation applies, please refer to the organization's Product Certification Scope of Accreditation

CSA B415.1-10 Weighted Average



Weighted Average: **72.7** %

Client: Pacific Energy
Model: TN20 (series B)
Tracking No.: 74
Project No.: 034-S-74-1
Test Dates: 12/13/16 - 12/20/16

Burn Rate Category 2
Burn Rate (kg/hr-dry) 0.97
OA Efficiency % 72.2
Emissions Rate Cap (g/hr) 15
Weighting Factor 24.47%
Run Number 5

Burn Rate Category 2
Burn Rate (kg/hr-dry) 1.01
OA Efficiency % 72.9
Emissions Rate Cap (g/hr) 15
Weighting Factor 3.01%
Run Number 2

Burn Rate Category 2
Burn Rate (kg/hr-dry) 1.03
OA Efficiency % 74.5
Emissions Rate Cap (g/hr) 15
Weighting Factor 27.59%
Run Number 1

Burn Rate Category 3
Burn Rate (kg/hr-dry) 1.64
OA Efficiency % 72.2
Emissions Rate Cap (g/hr) 18
Weighting Factor 33.51%
Run Number 3


Burn Rate Category 4
Burn Rate (kg/hr-dry) 2.09
Emissions Rate (g/hr) 70.6
Emissions Rate Cap (g/hr) 18
Weighting Factor 11.43%
Run Number 4

CSA B415.1-10 - Weighted Average



Client: Pacific Energy
Model: TN20 (series B)
Tracking No.: 74
Project No.: 034-S-74-1
Test Dates: 12/13/16 - 12/20/16

EPA Method 28 - Weighted Average



VERSION: 2.4

4/15/2010

Manufacturer: Pacific Energy

Appliance Type: Non-Cat (Cat, Non-Cat, Pe

Model: TN20

Date: 12/22/2016

Run: 6

Temp. Units: F (F or C)

Weight Units: lb (kg or lb)

Control #: 034-S-74-1

Test Duration: 300

Burn Category: 2

Wood Moisture (% DRY): 19.7

Wood Moisture (% wet): 16.46

Load Weight (lb wet): 13.60

Burn Rate (dry kg/h): 1.03

Total Particulate Emissions: 10.82 g

Fuel Data

D. Fir

HHV: 19,810 kJ/kg

%C: 48.73

%H: 6.87

%O: 43.90

%Ash: 0.50

Averages

280.1

75.0

13.16

7.10

0.95

Temp. (F)

Elapsed Time (min)	Fuel Weight Remaining (lb)	Flue Gas Temp (F)	Room Temp (F)	Flue Gas Composition (%)		
		O2	CO2	CO		
0	13.6	240.0	77.0	16.67	3.20	0.92
10	12.7	292.0	77.0	14.57	6.03	0.67
20	11.7	350.0	76.0	11.24	9.59	0.48
30	10.5	386.0	76.0	9.28	11.64	0.68
40	9.0	439.0	76.0	7.58	13.37	0.89
50	7.5	448.0	76.0	7.59	13.21	1.09
60	6.2	437.0	76.0	8.50	12.67	0.48
70	5.1	417.0	77.0	9.37	11.57	0.36
80	4.3	385.0	77.0	10.13	10.21	0.59
90	3.7	353.0	76.0	11.53	9.03	0.40
100	3.2	324.0	76.0	12.40	7.98	0.51
110	2.8	312.0	76.0	11.78	8.57	0.54
120	2.5	296.0	76.0	12.92	7.11	0.70
130	2.4	272.0	76.0	13.55	6.52	0.76
140	2.2	258.0	75.0	13.74	6.42	0.80
150	2.0	248.0	75.0	13.91	6.18	0.89
160	1.8	242.0	75.0	13.88	6.19	1.13
170	1.7	237.0	75.0	14.11	5.75	1.43
180	1.5	231.0	74.0	14.38	5.49	1.36
190	1.4	225.0	74.0	14.44	5.44	1.37
200	1.3	220.0	74.0	14.51	5.48	1.28
210	1.2	216.0	74.0	14.62	5.42	1.19
220	0.9	214.0	74.0	14.77	5.32	1.12
230	0.9	213.0	74.0	14.76	5.34	1.17
240	0.7	211.0	74.0	14.92	5.18	1.19
250	0.6	209.0	74.0	15.09	4.96	1.25
260	0.5	207.0	73.0	15.27	4.75	1.26
270	0.5	204.0	73.0	15.36	4.59	1.33
280	0.3	201.0	73.0	15.64	4.32	1.30
290	0.2	199.0	73.0	15.70	4.35	1.25
300	0.0	196.0	73.0	15.86	4.22	1.21

Manufacturer: Pacific Energy

Model: TN20

Date: 12/22/2016

Run: 6

Control #: 034-S-74-1

Test Duration: 300 min

Overall Heating Efficiency:

Combustion Efficiency:

Heat Transfer Efficiency:

	HHV	LHV
Eff	73.0%	78.9%
Comb Eff	93.4%	93.4%
HT Eff	78.1%	84.4%
Output	14,901	kJ/h
Burn Rate	1.03	kg/h
Grams CO	481	g
Input	20,424	kJ/h
MC wet	16.46	
Averages	0.95	7.10

Heat Output: 14,135

Heat Input: 19,375

Ultimate CO2

CO2-ult 19.64

Burn Duration: 5

Fo

1.061

Burn Rate: 2.3

Stack Temp: 281.4

INPUT DATA				Oxygen Calculation			Input Data		Combust	Heat
Elapsed Time	Weight Remaining (kg)	% CO [e]	% CO2 [d]	Excess Air EA	Total O2	Calc. % O2 [g]	Flue Gas (°C)	Room Temp (°C)	Eff %	Transfer %
0	6.17	0.92	3.20	376.8%	20.67	17.01	115.6	25.0	82.7%	71.9%
10	5.76	0.67	6.03	193.2%	20.50	14.13	144.4	25.0	92.2%	76.6%
20	5.31	0.48	9.59	95.1%	20.28	10.45	176.7	24.4	96.3%	78.6%
30	4.76	0.68	11.64	59.4%	20.13	8.15	196.7	24.4	95.5%	79.0%
40	4.08	0.89	13.37	37.7%	20.00	6.18	226.1	24.4	94.9%	78.4%
50	3.40	1.09	13.21	37.4%	20.00	6.24	231.1	24.4	93.7%	78.0%
60	2.81	0.48	12.67	49.4%	20.07	7.16	225.0	24.4	97.1%	78.1%
70	2.31	0.36	11.57	64.7%	20.15	8.40	213.9	25.0	97.6%	78.0%
80	1.95	0.59	10.21	81.9%	20.23	9.72	196.1	25.0	95.6%	77.9%
90	1.68	0.40	9.03	108.3%	20.32	11.09	178.3	24.4	96.8%	78.0%
100	1.45	0.51	7.98	131.4%	20.38	12.14	162.2	24.4	95.3%	78.0%
110	1.27	0.54	8.57	115.6%	20.34	11.50	155.6	24.4	95.4%	79.2%
120	1.13	0.70	7.11	151.5%	20.42	12.96	146.7	24.4	92.9%	78.1%
130	1.09	0.76	6.52	169.8%	20.46	13.56	133.3	24.4	91.8%	78.5%
140	1.00	0.80	6.42	172.1%	20.46	13.64	125.6	23.9	91.3%	79.0%

150	0.91	0.89	6.18	177.8%	20.47	13.85	120.0	23.9	90.0%	79.2%
160	0.82	1.13	6.19	168.3%	20.46	13.70	116.7	23.9	87.7%	79.4%
170	0.77	1.43	5.75	173.6%	20.47	14.00	113.9	23.9	84.1%	78.9%
180	0.68	1.36	5.49	186.8%	20.49	14.32	110.6	23.3	84.1%	78.8%
190	0.64	1.37	5.44	188.4%	20.49	14.37	107.2	23.3	83.9%	79.1%
200	0.59	1.28	5.48	190.6%	20.49	14.37	104.4	23.3	84.9%	79.5%
210	0.54	1.19	5.42	197.2%	20.50	14.49	102.2	23.3	85.7%	79.7%
220	0.41	1.12	5.32	205.0%	20.51	14.63	101.1	23.3	86.2%	79.7%
230	0.41	1.17	5.34	201.7%	20.51	14.59	100.6	23.3	85.7%	79.8%
240	0.32	1.19	5.18	208.4%	20.52	14.74	99.4	23.3	85.1%	79.6%
250	0.27	1.25	4.96	216.3%	20.53	14.94	98.3	23.3	84.0%	79.3%
260	0.23	1.26	4.75	226.8%	20.54	15.16	97.2	22.8	83.4%	79.0%
270	0.23	1.33	4.59	231.8%	20.55	15.29	95.6	22.8	82.2%	78.8%
280	0.14	1.30	4.32	249.5%	20.57	15.60	93.9	22.8	81.7%	78.5%
290	0.09	1.25	4.35	250.8%	20.57	15.60	92.8	22.8	82.3%	78.8%
300	0.00	1.21	4.22	261.7%	20.58	15.76	91.1	22.8	82.4%	78.7%

		Air Fuel Ratio (A/F)	
73.0%		Dry Molecular Weight (Md)	29.65
93.4%		Dry Moles Exhaust Gas (Nr):	453.34
78.1%		Air Fuel Ratio (A/F)	12.93

%HC
1.32

Combustion Efficiency: 93.4%
Total Input (kJ): 102,122
Total Output (kJ): 74,505
Efficiency: 73.0%
Total CO (g): 480.73

Btu/h 14,901 kJ/h
Btu/h 20,424 kJ/h

h

lb/h 1.0 kg/h

Deg. F 138.6 Deg. C

70.0%	15.7	1.65	73.22	0.04	73.22	102873	4.06	6.87	2.74	19810.00	16.46
Net Eff %	Air Fuel Ratio	Wet Wt Now Wt	% Wet Consumed x	Dry Wt. Now Wtdn	% Dry Comsumed y	Fuel Properties			Oxygen /16= [c]	Calorific Value	Mw Moisture Fuel Burnt
						Total Input	Carbon /12= [a]	Hydrogen /1= [b]			
59.4%	27.8	6.17	0.00	5.16	0.00	0	4.06	6.87	2.74	19810.00	16.46
70.6%	17.4	5.76	6.62	4.81	6.62	10513	4.06	6.87	2.74	19810.00	16.46
75.7%	11.7	5.31	13.97	4.43	13.97	8260	4.06	6.87	2.74	19810.00	16.46
75.5%	9.5	4.76	22.79	3.98	22.79	10137	4.06	6.87	2.74	19810.00	16.46
74.4%	8.2	4.08	33.82	3.41	33.82	11263	4.06	6.87	2.74	19810.00	16.46
73.1%	8.2	3.40	44.85	2.84	44.85	10513	4.06	6.87	2.74	19810.00	16.46
75.8%	9.0	2.81	54.41	2.35	54.41	9011	4.06	6.87	2.74	19810.00	16.46
76.2%	9.9	2.31	62.50	1.93	62.50	7133	4.06	6.87	2.74	19810.00	16.46
74.5%	10.9	1.95	68.38	1.63	68.38	5256	4.06	6.87	2.74	19810.00	16.46
75.4%	12.5	1.68	72.79	1.40	72.79	4130	4.06	6.87	2.74	19810.00	16.46
74.3%	13.8	1.45	76.47	1.21	76.47	3379	4.06	6.87	2.74	19810.00	16.46
75.5%	12.9	1.27	79.41	1.06	79.41	2628	4.06	6.87	2.74	19810.00	16.46
72.6%	15.0	1.13	81.62	0.95	81.62	1502	4.06	6.87	2.74	19810.00	16.46
72.0%	16.0	1.09	82.35	0.91	82.35	1126	4.06	6.87	2.74	19810.00	16.46
72.1%	16.1	1.00	83.82	0.83	83.82	1502	4.06	6.87	2.74	19810.00	16.46

71.3%	16.4	0.91	85.29	0.76	85.29	1502	4.06	6.87	2.74	19810.00	16.46
69.6%	15.8	0.82	86.76	0.68	86.76	1126	4.06	6.87	2.74	19810.00	16.46
66.3%	15.9	0.77	87.50	0.64	87.50	1126	4.06	6.87	2.74	19810.00	16.46
66.3%	16.7	0.68	88.97	0.57	88.97	1126	4.06	6.87	2.74	19810.00	16.46
66.4%	16.8	0.64	89.71	0.53	89.71	751	4.06	6.87	2.74	19810.00	16.46
67.5%	17.0	0.59	90.44	0.49	90.44	751	4.06	6.87	2.74	19810.00	16.46
68.3%	17.4	0.54	91.18	0.45	91.18	1502	4.06	6.87	2.74	19810.00	16.46
68.7%	17.9	0.41	93.38	0.34	93.38	1126	4.06	6.87	2.74	19810.00	16.46
68.4%	17.7	0.41	93.38	0.34	93.38	751	4.06	6.87	2.74	19810.00	16.46
67.8%	18.0	0.32	94.85	0.27	94.85	1126	4.06	6.87	2.74	19810.00	16.46
66.6%	18.4	0.27	95.59	0.23	95.59	751	4.06	6.87	2.74	19810.00	16.46
65.9%	19.0	0.23	96.32	0.19	96.32	375	4.06	6.87	2.74	19810.00	16.46
64.8%	19.3	0.23	96.32	0.19	96.32	751	4.06	6.87	2.74	19810.00	16.46
64.1%	20.3	0.14	97.79	0.11	97.79	1126	4.06	6.87	2.74	19810.00	16.46
64.9%	20.4	0.09	98.53	0.08	98.53	1877	4.06	6.87	2.74	19810.00	16.46
64.9%	21.0	0.00	100.00	0.00	100.00	751	4.06	6.87	2.74	19810.00	16.46

Moisture Content MCwb: 16.46

96,857	(Btu)	Moisture of Wood (wet basis):	16.46	Dry kg :	5.16
70,665	(Btu)	Initial Dry Weight Wtdo (kg):	5.16	CA:	48.73
		Moisture Content Dry	19.70	HY:	6.87
				OX:	43.90

Load Weight (kg):	6.17				
Fuel Heating:	HHV	LHV		HHV	LHV
Value in kJ/kg - CV:	19810.00	18328.69	Btu/lb	8522.48	7885.21

79.11	20.99	2.01	6.68	0.12	0.20	34.65	73.98	5.48	0.68	430.40	33.16
Mass Balance (moles/100 mole dry flue gas)					kg Wood per 100 mole dfp Nk	Moles per kg of Dry Wood					
[h]	[u]	[w]	[j]	[k]		CO2	O2	CO	HC	N2	H2O
78.87	20.92	1.04	3.36	0.11	0.10	30.90	164.22	8.88	1.03	761.57	32.46
79.17	21.00	1.67	5.58	0.07	0.17	36.32	85.14	4.04	0.45	476.91	33.62
79.48	21.08	2.49	8.46	0.05	0.25	38.66	42.11	1.94	0.21	320.45	34.09
79.53	21.10	3.06	10.32	0.09	0.30	38.29	26.80	2.24	0.28	261.64	33.96
79.56	21.10	3.54	11.92	0.12	0.35	37.95	17.55	2.53	0.34	225.80	33.84
79.46	21.08	3.56	11.92	0.15	0.35	37.31	17.63	3.08	0.42	224.44	33.68
79.69	21.14	3.25	11.06	0.06	0.32	39.15	22.13	1.48	0.18	246.23	34.16
79.67	21.13	2.95	10.05	0.04	0.29	39.45	28.65	1.23	0.13	271.66	34.26
79.48	21.08	2.68	9.05	0.07	0.27	38.33	36.50	2.22	0.26	298.40	33.99
79.48	21.08	2.33	7.93	0.04	0.23	38.91	47.78	1.72	0.17	342.53	34.17
79.37	21.05	2.10	7.12	0.05	0.21	38.11	58.01	2.44	0.26	379.07	34.00
79.39	21.06	2.26	7.64	0.06	0.22	38.14	51.17	2.40	0.27	353.33	33.99
79.23	21.01	1.94	6.51	0.08	0.19	36.77	67.05	3.62	0.42	409.75	33.68
79.16	21.00	1.81	6.06	0.09	0.18	36.11	75.10	4.21	0.49	438.42	33.54
79.14	20.99	1.80	6.00	0.09	0.18	35.82	76.12	4.46	0.53	441.55	33.47

79.08	20.98	1.77	5.86	0.11	0.18	35.14	78.74	5.06	0.61	449.67	33.30
78.98	20.95	1.84	6.03	0.14	0.18	33.85	74.93	6.18	0.78	431.92	32.96
78.82	20.91	1.81	5.86	0.19	0.18	31.86	77.57	7.92	1.03	436.71	32.46
78.83	20.91	1.73	5.59	0.18	0.17	31.89	83.18	7.90	1.02	457.97	32.49
78.82	20.91	1.72	5.56	0.18	0.17	31.78	83.92	8.00	1.03	460.46	32.46
78.87	20.92	1.70	5.53	0.16	0.17	32.30	84.73	7.55	0.96	464.90	32.60
78.90	20.93	1.66	5.42	0.15	0.17	32.72	87.47	7.18	0.91	476.34	32.71
78.93	20.94	1.62	5.29	0.14	0.16	33.00	90.78	6.95	0.87	489.55	32.79
78.90	20.93	1.64	5.34	0.15	0.16	32.74	89.42	7.17	0.90	483.74	32.72
78.89	20.92	1.61	5.22	0.15	0.16	32.43	92.30	7.45	0.94	493.81	32.65
78.85	20.91	1.57	5.07	0.16	0.16	31.79	95.78	8.01	1.01	505.30	32.50
78.83	20.91	1.52	4.90	0.16	0.15	31.42	100.31	8.34	1.05	521.47	32.42
78.79	20.90	1.50	4.81	0.17	0.15	30.76	102.51	8.91	1.13	528.05	32.25
78.78	20.90	1.42	4.56	0.16	0.14	30.48	110.06	9.17	1.16	555.85	32.20
78.80	20.90	1.42	4.56	0.16	0.14	30.84	110.56	8.86	1.11	558.65	32.29
78.81	20.91	1.37	4.42	0.15	0.14	30.86	115.22	8.85	1.10	576.34	32.31

10.94	410.96	4564.04	3423.14	3325.90	3289.63	4419.04	3979.06	297.04	5060.45	6634.92	48571.16
Moisture Present	Stack Temp K	Heat Content Change - Ambient to Stack Temperature						Room Temp K	Energy		
		Flue Gas Constituent							CO2	O2	CO
		CO2	O2	CO	N2	CH4	H2O				
10.94	388.71	3576.89	2705.15	2633.83	2603.95	3414.21	3152.83	298.15	110.52	444.25	2537.04
10.94	417.59	4768.02	3583.67	3483.73	3445.35	4600.03	4168.48	298.15	173.20	305.10	1156.25
10.94	449.82	6146.35	4588.79	4453.22	4405.76	5997.33	5326.12	297.59	237.64	193.24	556.25
10.94	469.82	7003.84	5207.20	5047.96	4995.30	6881.74	6035.72	297.59	268.19	139.55	644.35
10.94	499.26	8287.37	6124.18	5927.63	5867.74	8224.56	7084.56	297.59	314.48	107.48	729.81
10.94	504.26	8507.83	6280.67	6077.49	6016.43	8457.41	7263.15	297.59	317.45	110.71	890.00
10.94	498.15	8238.48	6089.44	5894.34	5834.72	8173.01	7044.89	297.59	322.53	134.75	428.46
10.94	487.04	7730.32	5726.23	5545.88	5489.13	7641.74	6629.39	298.15	304.98	164.06	354.20
10.94	469.26	6958.65	5173.60	5015.40	4963.07	6837.35	5996.78	298.15	266.75	188.84	637.98
10.94	451.48	6217.36	4640.19	4502.70	4454.80	6070.17	5385.17	297.59	241.94	221.71	495.58
10.94	435.37	5534.26	4144.40	4025.08	3981.53	5372.52	4815.05	297.59	210.94	240.40	699.15
10.94	428.71	5253.80	3939.93	3827.87	3786.17	5088.08	4579.57	297.59	200.39	201.62	689.31
10.94	419.82	4881.86	3667.93	3565.31	3526.11	4712.71	4266.00	297.59	179.52	245.94	1037.44
10.94	406.48	4328.24	3261.26	3172.31	3136.94	4157.94	3796.48	297.59	156.29	244.91	1204.53
10.94	398.71	4028.88	3041.14	2959.53	2926.25	3858.44	3542.26	297.04	144.32	231.50	1276.38

10.94	393.15	3800.98	2872.55	2796.31	2764.69	3632.64	3347.17	297.04	133.57	226.19	1446.30
10.94	389.82	3664.67	2771.54	2698.46	2667.85	3498.00	3230.20	297.04	124.06	207.68	1765.52
10.94	387.04	3551.32	2687.43	2616.97	2587.20	3386.27	3132.78	297.04	113.14	208.48	2262.95
10.94	383.71	3436.79	2602.96	2535.25	2506.29	3272.25	3035.12	296.48	109.61	216.51	2255.90
10.94	380.37	3301.40	2502.23	2437.58	2409.65	3139.37	2918.33	296.48	104.91	209.98	2284.27
10.94	377.59	3188.81	2418.36	2356.23	2329.16	3029.11	2821.05	296.48	103.01	204.91	2153.06
10.94	375.37	3098.91	2351.31	2291.19	2264.80	2941.21	2743.27	296.48	101.40	205.67	2049.56
10.94	374.26	3054.01	2317.81	2258.67	2232.64	2897.37	2704.38	296.48	100.78	210.40	1981.67
10.94	373.71	3031.57	2301.06	2242.42	2216.55	2875.47	2684.94	296.48	99.25	205.75	2045.96
10.94	372.59	2986.72	2267.57	2209.92	2184.40	2831.73	2646.07	296.48	96.85	209.29	2124.53
10.94	371.48	2941.91	2234.09	2177.42	2152.25	2788.06	2607.20	296.48	93.52	213.98	2284.51
10.94	370.37	2918.32	2216.98	2160.95	2135.93	2763.93	2587.54	295.93	91.70	222.39	2376.88
10.94	368.71	2851.23	2166.80	2112.23	2087.73	2698.65	2529.26	295.93	87.71	222.11	2541.46
10.94	367.04	2784.21	2116.65	2063.52	2039.55	2633.53	2471.00	295.93	84.86	232.96	2614.62
10.94	365.93	2739.58	2083.22	2031.06	2007.44	2590.21	2432.17	295.93	84.48	230.31	2525.68
10.94	364.26	2672.70	2033.11	1982.39	1959.29	2525.35	2373.94	295.93	82.48	234.26	2521.57

SUMS				AVERAGE	SUMS					
39790.63	18847.71	49321.71	16267.84	5951.43	27616	6737	20879.90	75256	6737	480.73
Flue Gas Constituent				Total Loss Rate	Heat Losses (kJ/kg of Dry Fuel)					
N2	CH4	H2O Comb	H2O Fuel MC		Total Loss	Chemical Loss 1	Sensible and Latent Loss	Total Output	Chem Loss 2	Grams Pro CO
1983.09	920.99	1529.63	515.73	8041.25	0	0	0.00	0	0	0.00
1643.11	403.86	1618.38	526.84	5826.74	3092	819	2272.72	7420	819	59.97
1411.83	192.08	1680.66	539.51	4811.21	2006	308	1698.16	6254	308	22.59
1306.99	253.83	1697.99	547.28	4858.19	2486	453	2033.17	7651	453	32.05
1324.91	305.43	1727.79	558.76	5068.64	2882	579	2303.39	8382	579	40.21
1350.34	377.81	1725.59	560.71	5332.61	2830	661	2168.88	7683	661	45.75
1436.66	162.23	1742.71	558.32	4785.66	2177	264	1912.76	6834	264	18.89
1491.15	119.27	1733.35	553.78	4720.77	1700	168	1532.25	5434	168	12.38
1480.97	236.96	1698.55	546.85	5056.90	1342	229	1113.04	3914	229	16.46
1525.88	156.30	1686.62	540.16	4868.19	1015	134	880.84	3115	134	10.06
1509.29	234.41	1658.61	533.92	5086.71	868	157	710.32	2511	157	11.63
1337.78	239.92	1650.00	531.34	4850.37	643	122	521.61	1985	122	8.93
1444.81	375.72	1624.69	527.91	5436.02	412	106	306.10	1090	106	7.68
1375.31	440.67	1601.92	522.77	5546.40	315	93	222.69	811	93	6.70
1292.07	472.20	1590.02	519.99	5526.49	419	131	287.56	1083	131	9.47

1243.21	546.11	1575.66	517.85	5688.89	431	150	281.47	1071	150	10.74
1152.30	697.29	1555.78	516.57	6019.21	342	139	203.31	784	139	9.84
1129.86	920.48	1529.03	515.51	6679.45	380	180	200.15	747	180	12.61
1147.81	909.39	1527.02	514.44	6680.68	380	179	201.20	746	179	12.58
1109.54	921.49	1521.94	513.16	6665.29	253	121	131.99	498	121	8.49
1082.83	860.63	1525.15	512.10	6441.68	244	113	130.72	507	113	8.01
1078.82	809.60	1527.94	511.24	6284.24	476	215	261.10	1025	215	15.25
1093.00	773.94	1530.39	510.82	6200.99	353	156	196.93	774	156	11.06
1072.24	805.27	1526.48	510.61	6265.55	237	107	130.13	513	107	7.61
1078.68	837.05	1521.88	510.18	6378.46	363	167	195.36	764	167	11.86
1087.54	905.14	1513.51	509.75	6607.94	250	120	130.34	500	120	8.50
1113.83	940.83	1509.14	509.54	6764.32	128	62	65.72	247	62	4.42
1102.43	1012.93	1499.74	508.90	6975.28	264	134	130.50	486	134	9.46
1133.68	1035.60	1495.49	508.26	7105.47	404	206	197.71	722	206	14.60
1121.46	994.37	1498.52	507.84	6962.66	660	332	328.21	1217	332	23.51
1129.22	985.91	1497.51	507.20	6958.15	264	132	131.57	487	132	9.39

33.75
roduced HC

0.00
3.83
1.43
2.32
3.09
3.57
1.31
0.77
1.12
0.58
0.71
0.57
0.51
0.45
0.64

0.74
0.71
0.94
0.93
0.63
0.58
1.10
0.79
0.55
0.85
0.61
0.32
0.69
1.06
1.69
0.67

Dirigo Laboratories, Inc.

Manufacturer: Pacific Energy
Model: TN20
Date: 12/22/2016
Run: 6
Control #: 034-S-74-1
Test Duration: 300
Output Category: 2

	HHV Basis	LHV Basis
Overall Efficiency	73.0%	78.9%
Combustion Efficiency	93.4%	93.4%
Heat Transfer Efficiency	78.1%	84.4%

HHV Output Rate (kJ/h)	14,901	14,135	(Btu/h)
Burn Rate (kg/h)	1.03	2.27	(lb/h)
Input (kJ/h)	20,424	19,375	(Btu/h)

Test Load Weight (dry kg)	5.2	11.4	dry lb
MC wet (%)	16.46		
MC dry (%)	19.70		
Particulate (g)	10.82		
CO (g)	481		
Test Duration (h)	5		

Emissions	Particulate	CO
g/MJ Output	0.15	6.45
g/kg Dry Fuel	2.10	93.25
g/h	2.16	96.15
lb/MM Btu Output	0.34	15.00

Air/Fuel Ratio (A/F)	12.93
----------------------	-------

Test Results in Accordance with CSA B415.1-10

Default Fuel Values

	D. Fir	Oak
HHV (kJ/kg)	19,810	19,887
%C	48.73	50
%H	6.87	6.6
%O	43.9	42.9
%Ash	0.5	0.5

VERSION: 2.4

4/15/2010

Manufacturer: Pacific Energy

Model: TN20

Date: 12/20/2016

Run: 4

Control #: 034-S-74-1

Test Duration: 150

Burn Category: 4

Wood Moisture (% DRY):

19.9

Wood Moisture (% wet):

16.60

Load Weight (lb wet):

13.80

Burn Rate (dry kg/h):

2.09

Total Particulate Emissions:

5.11

g

Appliance Type:

Non-Cat

(Cat, Non-Cat, Pellet)

Temp. Units

F

(F or C)

Weight Units

lb

(kg or lb)

Fuel Data

D. Fir

HHV

19,810

kJ/kg

%C

48.73

%H

6.87

%O

43.90

%Ash

0.50

Averages

451.8

74.9

11.85

8.50

0.53

Temp. (F)

Elapsed Time (min)	Fuel Weight Remaining (lb)	Flue Gas Temp (F)	Room Temp (F)	Flue Gas Composition (%)		
				O2	CO2	CO
0	13.8	321.0	75.0	16.94	2.96	0.85
10	12.5	503.0	74.0	9.92	10.96	0.44
20	10.0	663.0	75.0	4.80	15.67	0.78
30	7.6	667.0	75.0	4.59	15.90	0.54
40	5.9	600.0	76.0	7.45	13.33	0.12
50	4.3	578.0	76.0	8.02	12.85	0.12
60	3.0	540.0	75.0	9.89	10.78	0.03
70	2.2	489.0	75.0	11.58	8.94	0.02
80	1.7	440.0	75.0	13.27	7.08	0.14
90	1.5	392.0	75.0	14.27	5.83	0.59
100	1.2	365.0	75.0	14.60	5.55	0.66
110	1.0	348.0	75.0	14.89	5.25	0.76
120	0.7	347.0	75.0	14.21	5.99	0.45
130	0.5	333.0	74.0	15.10	4.96	0.83
140	0.3	325.0	74.0	15.02	5.00	1.04
150	0.0	317.0	74.0	15.05	4.89	1.09

Manufacturer: Pacific Energy

Model: TN20

Date: 12/20/2016

Run: 4

Control #: 034-S-74-1

Test Duration: 150 min

Overall Heating Efficiency:

Combustion Efficiency:

Heat Transfer Efficiency:

	HHV	LHV
Eff	70.6%	76.3%
Comb Eff	96.9%	96.9%
HT Eff	72.8%	78.7%
Output	29,208	kJ/h
Burn Rate	2.09	kg/h
Grams CO	233	g
Input	41,380	kJ/h
MC wet	16.60	
Averages	0.53	8.50

Heat Output: 27,707

Heat Input: 39,254

Ultimate CO2

CO2-ult 19.64

Burn Duration: 2.5

Fo

1.062

Burn Rate: 4.6

Stack Temp: 460.5

INPUT DATA				Oxygen Calculation			Input Data		Combust	Heat
Elapsed Time	Weight Remaining (kg)	% CO [e]	% CO2 [d]	Excess Air EA	Total O2	Calc. % O2 [g]	Flue Gas (°C)	Room Temp (°C)	Eff %	Transfer %
0	6.26	0.85	2.96	415.6%	20.69	17.30	160.6	23.9	82.8%	61.4%
10	5.67	0.44	10.96	72.3%	20.19	9.01	261.7	23.3	97.0%	74.1%
20	4.54	0.78	15.67	19.4%	19.85	3.79	350.6	23.9	96.1%	73.4%
30	3.45	0.54	15.90	19.5%	19.85	3.68	352.8	23.9	97.3%	73.6%
40	2.68	0.12	13.33	46.0%	20.05	6.66	315.6	24.4	99.4%	73.5%
50	1.95	0.12	12.85	51.4%	20.08	7.17	303.3	24.4	99.4%	73.7%
60	1.36	0.03	10.78	81.7%	20.23	9.43	282.2	23.9	100.0%	72.6%
70	1.00	0.02	8.94	119.2%	20.35	11.40	253.9	23.9	100.2%	71.9%
80	0.77	0.14	7.08	172.1%	20.46	13.31	226.7	23.9	98.9%	70.5%
90	0.68	0.59	5.83	206.0%	20.52	14.39	200.0	23.9	92.9%	69.8%
100	0.54	0.66	5.55	216.3%	20.53	14.65	185.0	23.9	91.8%	70.7%
110	0.45	0.76	5.25	226.8%	20.54	14.91	175.6	23.9	90.1%	70.8%
120	0.32	0.45	5.99	205.0%	20.51	14.30	175.0	23.9	94.7%	73.1%
130	0.23	0.83	4.96	239.3%	20.56	15.18	167.2	23.3	88.8%	70.8%
140	0.14	1.04	5.00	225.2%	20.54	15.02	162.8	23.3	86.4%	71.5%

150	0.00	1.09	4.89	228.5%	20.55	15.11	158.3	23.3	85.6%	71.7%
-----	------	------	------	--------	-------	-------	-------	------	-------	-------

		Air Fuel Ratio (A/F)	
70.6%	Dry Molecular Weight (Md)	29.82	
96.9%	Dry Moles Exhaust Gas (Nr):	410.83	%HC
72.8%	Air Fuel Ratio (A/F)	11.74	1.32

Combustion Efficiency: 96.9%
Total Input (kJ): 103,451
Total Output (kJ): 73,019
Efficiency: 70.6%
Total CO (g): 233.36

Btu/h 29,208 kJ/h
Btu/h 41,380 kJ/h

h

lb/h 2.1 kg/h

Deg. F 238.0 Deg. C

67.1%	15.4	1.88	70.02	0.03	70.02	104575	4.06	6.87	2.74	19810.00	16.60
Net Eff %	Air Fuel Ratio	Wet Wt Now Wt	% Wet Consumed x	Dry Wt. Now Wtdn	% Dry Comsumed y	Fuel Properties			Oxygen /16= [c]	Calorific Value	Mw Moisture Fuel Burnt
						Total Input	Carbon /12= [a]	Hydrogen /1= [b]			
50.8%	30.1	6.26	0.00	5.22	0.00	0	4.06	6.87	2.74	19810.00	16.60
71.8%	10.4	5.67	9.42	4.73	9.42	19116	4.06	6.87	2.74	19810.00	16.60
70.5%	7.2	4.54	27.54	3.78	27.54	18366	4.06	6.87	2.74	19810.00	16.60
71.6%	7.2	3.45	44.93	2.88	44.93	15368	4.06	6.87	2.74	19810.00	16.60
73.0%	8.8	2.68	57.25	2.23	57.25	12369	4.06	6.87	2.74	19810.00	16.60
73.2%	9.2	1.95	68.84	1.63	68.84	10870	4.06	6.87	2.74	19810.00	16.60
72.6%	11.0	1.36	78.26	1.14	78.26	7871	4.06	6.87	2.74	19810.00	16.60
72.1%	13.3	1.00	84.06	0.83	84.06	4873	4.06	6.87	2.74	19810.00	16.60
69.7%	16.4	0.77	87.68	0.64	87.68	2624	4.06	6.87	2.74	19810.00	16.60
64.8%	18.2	0.68	89.13	0.57	89.13	1874	4.06	6.87	2.74	19810.00	16.60
64.8%	18.8	0.54	91.30	0.45	91.30	1874	4.06	6.87	2.74	19810.00	16.60
63.8%	19.3	0.45	92.75	0.38	92.75	1874	4.06	6.87	2.74	19810.00	16.60
69.2%	18.2	0.32	94.93	0.26	94.93	1874	4.06	6.87	2.74	19810.00	16.60
62.9%	20.0	0.23	96.38	0.19	96.38	1499	4.06	6.87	2.74	19810.00	16.60
61.7%	19.1	0.14	97.83	0.11	97.83	2999	4.06	6.87	2.74	19810.00	16.60

61.3%	19.2	0.00	100.00	0.00	100.00	1124	4.06	6.87	2.74	19810.00	16.60
-------	------	------	--------	------	--------	------	------	------	------	----------	-------

Moisture Content MCwb: 16.60

98,118	(Btu)	Moisture of Wood (wet basis):	16.60	Dry kg :	5.22
69,255	(Btu)	Initial Dry Weight Wtdo (kg):	5.22	CA:	48.73
		Moisture Content Dry	19.90	HY:	6.87
				OX:	43.90

Load Weight (kg):	6.26				
Fuel Heating:	HHV	LHV		HHV	LHV
Value in kJ/kg - CV:	19810.00	18328.69	Btu/lb	8522.48	7885.21

79.39	21.06	2.24	7.57	0.06	0.22	37.25	69.89	3.20	0.35	421.71	33.81
Mass Balance (moles/100 mole dry flue gas)					kg Wood per 100 mole dfp Nk	Moles per kg of Dry Wood					
[h]	[u]	[w]	[j]	[k]		CO2	O2	CO	HC	N2	H2O
78.89	20.92	0.96	3.11	0.10	0.10	30.93	180.79	8.88	1.00	824.24	32.52
79.59	21.11	2.82	9.59	0.05	0.28	39.07	32.11	1.57	0.18	283.71	34.17
79.76	21.16	4.08	13.79	0.11	0.41	38.62	9.35	1.92	0.27	196.59	33.99
79.88	21.19	4.07	13.82	0.07	0.40	39.30	9.11	1.33	0.18	197.42	34.16
79.89	21.19	3.31	11.37	0.01	0.33	40.43	20.20	0.36	0.02	242.29	34.48
79.86	21.18	3.20	10.96	0.01	0.32	40.42	22.56	0.38	0.02	251.17	34.49
79.76	21.16	2.66	9.16	-0.01	0.26	40.74	35.64	0.11	-0.04	301.42	34.60
79.64	21.13	2.20	7.60	-0.02	0.22	40.79	52.01	0.09	-0.07	363.39	34.66
79.47	21.08	1.78	6.11	0.00	0.18	40.03	75.27	0.79	-0.01	449.26	34.53
79.19	21.01	1.60	5.36	0.06	0.16	36.70	90.60	3.71	0.40	498.53	33.73
79.14	20.99	1.55	5.17	0.07	0.15	36.05	95.17	4.29	0.47	514.10	33.58
79.08	20.98	1.50	4.98	0.09	0.15	35.14	99.83	5.09	0.58	529.35	33.36
79.26	21.02	1.60	5.40	0.04	0.16	37.71	90.03	2.83	0.27	499.00	33.99
79.03	20.96	1.45	4.79	0.10	0.14	34.39	105.26	5.75	0.67	547.91	33.18
78.94	20.94	1.52	4.96	0.13	0.15	33.09	99.40	6.88	0.84	522.37	32.84

78.91	20.93	1.51	4.90	0.13	0.15	32.64	100.85	7.28	0.90	526.69	32.73
-------	-------	------	------	------	------	-------	--------	------	------	--------	-------

11.06	506.34	8690.62	6385.11	6170.90	6110.52	8705.92	7372.35	296.97	5295.66	5741.73	14757.15
Moisture Present	Stack Temp K	Heat Content Change - Ambient to Stack Temperature						Room Temp K	Energy		
		Flue Gas Constituent							CO2	O2	CO
		CO2	O2	CO	N2	CH4	H2O				
11.06	433.71	5485.23	4109.61	3991.77	3948.48	5320.69	4775.35	297.04	169.64	743.00	2548.38
11.06	534.82	9913.20	7274.61	7028.36	6960.06	9949.80	8396.06	296.48	387.28	233.56	454.87
11.06	623.71	14010.99	10102.28	9715.09	9630.23	14455.60	11591.15	297.04	541.17	94.47	562.76
11.06	625.93	14116.90	10174.29	9783.23	9698.01	14574.40	11672.09	297.04	554.76	92.65	390.75
11.06	588.71	12340.59	8957.59	8629.59	8550.96	12601.44	10300.95	297.59	498.90	180.98	106.13
11.06	576.48	11773.05	8566.17	8257.74	8181.38	11976.93	9858.76	297.59	475.82	193.28	109.93
11.06	555.37	10824.16	7909.61	7633.43	7561.02	10937.45	9116.16	297.04	440.97	281.92	32.95
11.06	527.04	9542.50	7012.78	6777.97	6711.55	9555.39	8097.75	297.04	389.25	364.73	26.44
11.06	499.82	8333.03	6157.93	5960.29	5900.07	8269.88	7123.59	297.04	333.54	463.48	228.70
11.06	473.15	7169.09	5326.98	5163.32	5109.61	7050.84	6173.41	297.04	263.12	482.62	1070.30
11.06	458.15	6523.43	4862.39	4716.77	4666.92	6382.62	5640.71	297.04	235.19	462.74	1233.53
11.06	448.71	6120.25	4570.91	4436.26	4388.90	5968.36	5305.96	297.04	215.09	456.31	1462.30
11.06	448.15	6096.61	4553.79	4419.78	4372.56	5944.15	5286.29	297.04	229.91	409.96	814.26
11.06	440.37	5787.85	4330.75	4205.18	4159.86	5626.48	5030.22	296.48	199.03	455.87	1652.69
11.06	435.93	5600.08	4194.19	4073.56	4029.45	5435.34	4873.08	296.48	185.29	416.91	1975.62

11.06	431.48	5412.89	4057.81	3942.04	3899.16	5245.30	4716.05	296.48	176.67	409.25	2087.54
-------	--------	---------	---------	---------	---------	---------	---------	--------	--------	--------	---------

SUMS				AVERAGE	SUMS					
36421.71	5089.13	27795.52	9081.79	6511.42	30431	3192	27238.73	74144	3192	233.36
Flue Gas Constituent				Total Loss Rate	Heat Losses (kJ/kg of Dry Fuel)					
N2	CH4	H2O Comb	H2O Fuel MC		Total Loss	Chemical Loss 1	Sensible and Latent Loss	Total Output	Chem Loss 2	Grams Pro CO
3254.51	898.81	1584.93	538.90	9738.18	0	0	0.00	0	0	0.00
1974.63	159.29	1789.24	578.93	5577.80	5382	580	4802.06	13734	580	42.38
1893.20	239.91	1888.61	614.25	5834.37	5409	723	4685.86	12957	723	49.91
1914.56	162.76	1900.86	615.15	5631.49	4369	417	3951.42	10999	417	28.99
2071.80	18.55	1871.31	599.99	5347.67	3339	76	3263.28	9030	76	6.36
2054.89	16.89	1856.26	595.10	5302.16	2909	68	2841.56	7960	68	5.80
2279.08	-36.78	1836.97	586.89	5422.01	2154	-2	2156.05	5717	-2	1.26
2438.91	-63.32	1804.81	575.63	5536.45	1362	-9	1370.86	3511	-9	0.63
2650.69	-5.14	1764.43	564.86	6000.57	795	29	765.76	1829	29	2.94
2547.29	355.00	1691.37	554.36	6964.05	659	133	526.07	1215	133	9.84
2399.26	423.04	1665.84	548.47	6968.06	659	155	504.69	1215	155	11.36
2323.25	520.63	1643.84	544.77	7166.19	678	185	492.82	1196	185	13.48
2181.90	240.27	1674.01	544.55	6094.86	577	98	478.17	1298	98	7.50
2279.22	599.70	1625.97	541.72	7354.21	557	168	388.24	943	168	12.19
2104.87	755.23	1603.78	539.98	7581.67	1148	408	739.19	1851	408	29.17

2053.66 804.30 1593.27 538.24 7662.93 435 162 272.71 689 162 11.56

14.99
roduced HC

0.00

2.73

3.93

2.23

0.21

0.16

-0.26

-0.28

-0.01

0.60

0.71

0.88

0.41

0.81

2.04

0.82

Dirigo Laboratories, Inc.

Manufacturer: Pacific Energy
Model: TN20
Date: 12/20/2016
Run: 4
Control #: 034-S-74-1
Test Duration: 150
Output Category: 4

	HHV Basis	LHV Basis
Overall Efficiency	70.6%	76.3%
Combustion Efficiency	96.9%	96.9%
Heat Transfer Efficiency	72.8%	78.7%

HHV Output Rate (kJ/h)	29,208	27,707	(Btu/h)
Burn Rate (kg/h)	2.09	4.60	(lb/h)
Input (kJ/h)	41,380	39,254	(Btu/h)

Test Load Weight (dry kg)	5.2	11.5	dry lb
MC wet (%)	16.60		
MC dry (%)	19.90		
Particulate (g)	5.11		
CO (g)	233		
Test Duration (h)	2.5		

Emissions	Particulate	CO
g/MJ Output	0.07	3.20
g/kg Dry Fuel	0.98	44.69
g/h	2.04	93.35
lb/MM Btu Output	0.16	7.43

Air/Fuel Ratio (A/F)	11.74
----------------------	-------

Test Results in Accordance with CSA B415.1-10

Default Fuel Values

	D. Fir	Oak
HHV (kJ/kg)	19,810	19,887
%C	48.73	50
%H	6.87	6.6
%O	43.9	42.9
%Ash	0.5	0.5

VERSION: 2.4

4/15/2010

Manufacturer: Pacific Energy

Model: TN20

Date: 12/20/2016

Run: 3

Control #: 034-S-74-1

Test Duration: 190

Burn Category: 3

Wood Moisture (% DRY): 19.8

Wood Moisture (% wet): 16.53

Load Weight (lb wet): 13.70

Burn Rate (dry kg/h): 1.64

Total Particulate Emissions: 6.97 g

Appliance Type: Non-Cat (Cat, Non-Cat, Pellet)

Temp. Units: F (F or C)

Weight Units: lb (kg or lb)

Fuel Data

D. Fir

HHV: 19,810 kJ/kg

%C: 48.73

%H: 6.87

%O: 43.90

%Ash: 0.50

Averages

377.5

73.3

12.17

8.26

0.61

Temp. (F)

Elapsed Time (min)	Fuel Weight Remaining (lb)	Flue Gas Temp (F)	Room Temp (F)	Flue Gas Composition (%)		
				O2	CO2	CO
0	13.7	300.0	74.0	16.29	3.79	0.74
10	12.0	531.0	74.0	7.92	12.84	0.43
20	9.9	591.0	74.0	5.52	15.10	0.92
30	7.7	587.0	74.0	5.01	15.41	1.14
40	5.9	563.0	74.0	5.77	14.84	0.37
50	4.4	540.0	74.0	7.46	13.02	0.33
60	3.4	465.0	74.0	10.80	9.87	0.09
70	2.7	415.0	74.0	12.06	8.53	0.10
80	2.3	378.0	74.0	12.75	7.65	0.17
90	1.9	350.0	74.0	13.41	6.80	0.44
100	1.7	321.0	73.0	13.75	6.53	0.58
110	1.5	306.0	73.0	13.80	6.54	0.69
120	1.2	297.0	73.0	13.94	6.46	0.71
130	1.0	292.0	73.0	14.07	6.31	0.61
140	0.8	284.0	73.0	14.59	5.85	0.73
150	0.6	277.0	72.0	14.94	5.48	0.73
160	0.4	269.0	72.0	14.98	5.40	0.81
170	0.2	266.0	72.0	15.05	5.32	0.86
180	0.1	261.0	72.0	15.36	4.98	0.86
190	0.0	256.0	72.0	15.85	4.49	0.88

Manufacturer: Pacific Energy

Model: TN20

Date: 12/20/2016

Run: 3

Control #: 034-S-74-1

Test Duration: 190 min

Overall Heating Efficiency:

Combustion Efficiency:

Heat Transfer Efficiency:

	HHV	LHV
Eff	72.2%	78.1%
Comb Eff	96.1%	96.1%
HT Eff	75.2%	81.2%
Output	23,451	kJ/h
Burn Rate	1.64	kg/h
Grams CO	287	g
Input	32,459	kJ/h
MC wet	16.53	
Averages	0.61	8.26

Heat Output: 22,246

Heat Input: 30,791

Ultimate CO2

CO2-ult 19.64

Burn Duration: 3.166666667

Fo

1.062

Burn Rate: 3.6

Stack Temp: 381.5

INPUT DATA				Oxygen Calculation			Input Data		Combust	Heat
Elapsed Time	Weight Remaining (kg)	% CO [e]	% CO2 [d]	Excess Air EA	Total O2	Calc. % O2 [g]	Flue Gas (°C)	Room Temp (°C)	Eff %	Transfer %
0	6.22	0.74	3.79	333.6%	20.64	16.48	148.9	23.3	87.4%	68.8%
10	5.44	0.43	12.84	48.0%	20.06	7.01	277.2	23.3	97.4%	75.1%
20	4.49	0.92	15.10	22.6%	19.88	4.32	310.6	23.3	95.2%	75.0%
30	3.49	1.14	15.41	18.7%	19.85	3.87	308.3	23.3	94.3%	75.3%
40	2.68	0.37	14.84	29.1%	19.94	4.91	295.0	23.3	98.0%	75.8%
50	2.00	0.33	13.02	47.1%	20.06	6.87	282.2	23.3	98.1%	75.0%
60	1.54	0.09	9.87	97.2%	20.28	10.37	240.6	23.3	99.5%	74.3%
70	1.23	0.10	8.53	127.6%	20.37	11.79	212.8	23.3	99.4%	74.5%
80	1.04	0.17	7.65	151.2%	20.42	12.69	192.2	23.3	98.6%	74.8%
90	0.86	0.44	6.80	171.3%	20.46	13.44	176.7	23.3	95.4%	74.6%
100	0.77	0.58	6.53	176.3%	20.47	13.65	160.6	22.8	93.7%	75.6%
110	0.68	0.69	6.54	171.7%	20.46	13.58	152.2	22.8	92.5%	76.4%
120	0.54	0.71	6.46	174.0%	20.47	13.65	147.2	22.8	92.2%	76.8%
130	0.45	0.61	6.31	183.9%	20.48	13.87	144.4	22.8	93.2%	76.9%
140	0.36	0.73	5.85	198.5%	20.51	14.29	140.0	22.8	91.3%	76.4%

150	0.27	0.73	5.48	216.3%	20.53	14.68	136.1	22.2	90.8%	76.0%
160	0.18	0.81	5.40	216.3%	20.53	14.72	131.7	22.2	89.8%	76.3%
170	0.09	0.86	5.32	217.8%	20.53	14.78	130.0	22.2	89.1%	76.3%
180	0.05	0.86	4.98	236.4%	20.55	15.14	127.2	22.2	88.4%	75.8%
190	0.00	0.88	4.49	265.8%	20.59	15.66	124.4	22.2	87.2%	74.9%

		Air Fuel Ratio (A/F)	
72.2%	Dry Molecular Weight (Md)	29.79	
96.1%	Dry Moles Exhaust Gas (Nr):	417.08	%HC
75.2%	Air Fuel Ratio (A/F)	11.92	1.32

Combustion Efficiency: 96.1%
 Total Input (kJ): 102,787
 Total Output (kJ): 74,261
 Efficiency: 72.2%
 Total CO (g): 286.61

Btu/h 23,451 kJ/h
 Btu/h 32,459 kJ/h

h

lb/h 1.6 kg/h

Deg. F 194.2 Deg. C

70.4%	15.2	1.62	73.94	0.03	73.94	103162	4.06	6.87	2.74	19810.00	16.53
Net Eff %	Air Fuel Ratio	Wet Wt Now Wt	% Wet Consumed x	Dry Wt. Now Wtdn	% Dry Comsumed y	Fuel Properties			Oxygen /16= [c]	Calorific Value	Mw Moisture Fuel Burnt
						Total Input	Carbon /12= [a]	Hydrogen /1= [b]			
60.1%	25.5	6.22	0.00	5.19	0.00	0	4.06	6.87	2.74	19810.00	16.53
73.2%	8.9	5.44	12.41	4.54	12.41	20632	4.06	6.87	2.74	19810.00	16.53
71.5%	7.3	4.49	27.74	3.75	27.74	16131	4.06	6.87	2.74	19810.00	16.53
71.0%	7.1	3.49	43.80	2.92	43.80	15005	4.06	6.87	2.74	19810.00	16.53
74.3%	7.8	2.68	56.93	2.23	56.93	12379	4.06	6.87	2.74	19810.00	16.53
73.6%	8.9	2.00	67.88	1.67	67.88	9378	4.06	6.87	2.74	19810.00	16.53
74.0%	11.9	1.54	75.18	1.29	75.18	6377	4.06	6.87	2.74	19810.00	16.53
74.1%	13.7	1.23	80.29	1.02	80.29	4126	4.06	6.87	2.74	19810.00	16.53
73.8%	15.1	1.04	83.21	0.87	83.21	3001	4.06	6.87	2.74	19810.00	16.53
71.2%	16.2	0.86	86.13	0.72	86.13	2251	4.06	6.87	2.74	19810.00	16.53
70.9%	16.5	0.77	87.59	0.64	87.59	1501	4.06	6.87	2.74	19810.00	16.53
70.7%	16.1	0.68	89.05	0.57	89.05	1876	4.06	6.87	2.74	19810.00	16.53
70.8%	16.3	0.54	91.24	0.45	91.24	1876	4.06	6.87	2.74	19810.00	16.53
71.6%	16.9	0.45	92.70	0.38	92.70	1501	4.06	6.87	2.74	19810.00	16.53
69.8%	17.7	0.36	94.16	0.30	94.16	1501	4.06	6.87	2.74	19810.00	16.53

69.0%	18.7	0.27	95.62	0.23	95.62	1501	4.06	6.87	2.74	19810.00	16.53
68.5%	18.7	0.18	97.08	0.15	97.08	1501	4.06	6.87	2.74	19810.00	16.53
67.9%	18.7	0.09	98.54	0.08	98.54	1125	4.06	6.87	2.74	19810.00	16.53
67.1%	19.8	0.05	99.27	0.04	99.27	1125	4.06	6.87	2.74	19810.00	16.53
65.3%	21.5	0.00	100.00	0.00	100.00	375	4.06	6.87	2.74	19810.00	16.53

Moisture Content MCwb: 16.53

97,488	(Btu)	Moisture of Wood (wet basis):	16.53	Dry kg :	5.19
70,433	(Btu)	Initial Dry Weight Wtdo (kg):	5.19	CA:	48.73
		Moisture Content Dry	19.80	HY:	6.87
				OX:	43.90

Load Weight (kg):	6.22				
Fuel Heating:	HHV	LHV		HHV	LHV
Value in kJ/kg - CV:	19810.00	18328.69	Btu/lb	8522.48	7885.21

79.34	21.05	2.20	7.42	0.07	0.22	37.12	68.39	3.32	0.37	415.72	33.77
Mass Balance (moles/100 mole dry flue gas)					kg Wood per 100 mole dfp Nk	Moles per kg of Dry Wood					
[h]	[u]	[w]	[j]	[k]		CO2	O2	CO	HC	N2	H2O
78.99	20.95	1.14	3.74	0.08	0.11	33.54	145.86	6.55	0.72	699.09	33.08
79.72	21.15	3.28	11.17	0.05	0.33	39.34	21.47	1.32	0.16	244.24	34.21
79.66	21.13	3.98	13.40	0.13	0.40	38.17	10.92	2.33	0.32	201.34	33.88
79.58	21.11	4.11	13.81	0.16	0.41	37.64	9.45	2.78	0.39	194.37	33.74
79.88	21.19	3.76	12.81	0.05	0.37	39.70	13.14	0.99	0.12	213.69	34.28
79.78	21.16	3.30	11.25	0.04	0.33	39.69	20.95	1.01	0.11	243.21	34.30
79.67	21.13	2.45	8.43	0.00	0.24	40.46	42.50	0.37	-0.01	326.59	34.55
79.58	21.11	2.12	7.31	0.00	0.21	40.36	55.79	0.47	-0.02	376.53	34.56
79.49	21.09	1.93	6.61	0.00	0.19	39.90	66.18	0.89	0.02	414.63	34.48
79.32	21.04	1.79	6.08	0.04	0.18	38.11	75.33	2.47	0.24	444.51	34.05
79.24	21.02	1.77	5.94	0.06	0.18	37.16	77.67	3.30	0.36	450.88	33.81
79.19	21.01	1.80	6.02	0.08	0.18	36.52	75.82	3.85	0.44	442.21	33.64
79.18	21.00	1.79	5.97	0.08	0.18	36.36	76.83	4.00	0.46	445.62	33.60
79.21	21.01	1.72	5.78	0.07	0.17	36.86	81.01	3.56	0.39	462.72	33.74
79.13	20.99	1.64	5.47	0.08	0.16	35.83	87.53	4.47	0.51	484.66	33.50

79.11	20.98	1.55	5.16	0.08	0.15	35.54	95.24	4.73	0.54	513.04	33.45
79.07	20.97	1.55	5.14	0.09	0.15	34.96	95.32	5.24	0.61	511.84	33.30
79.04	20.97	1.55	5.11	0.10	0.15	34.56	96.04	5.59	0.66	513.52	33.20
79.02	20.96	1.46	4.82	0.10	0.15	34.21	104.04	5.91	0.69	542.81	33.14
78.97	20.95	1.35	4.42	0.10	0.13	33.48	116.74	6.56	0.77	588.91	32.99

11.00	465.07	6920.77	5124.66	4962.78	4912.10	6845.63	5932.22	296.07	5231.87	5595.19	19057.59
Moisture Present	Stack Temp K	Heat Content Change - Ambient to Stack Temperature						Room Temp K	Energy		
		Flue Gas Constituent							CO2	O2	CO
		CO2	O2	CO	N2	CH4	H2O				
11.00	422.04	5017.02	3768.59	3662.94	3622.71	4845.14	4382.74	296.48	168.29	549.70	1877.13
11.00	550.37	10617.48	7767.18	7498.15	7426.57	10709.78	8955.31	296.48	417.67	166.78	382.69
11.00	583.71	12150.29	8830.03	8509.40	8431.29	12383.96	10158.34	296.48	463.72	96.46	677.84
11.00	581.48	12047.10	8758.86	8441.79	8364.09	12270.41	10077.94	296.48	453.42	82.73	811.45
11.00	568.15	11430.97	8332.79	8036.71	7961.56	11594.93	9596.14	296.48	453.80	109.47	288.06
11.00	555.37	10845.35	7925.97	7649.44	7576.84	10956.94	9135.36	296.48	430.49	166.09	292.40
11.00	513.71	8968.61	6609.61	6392.96	6329.33	8940.06	7639.28	296.48	362.85	280.89	106.76
11.00	485.93	7745.43	5740.71	5560.72	5503.64	7649.48	6647.39	296.48	312.61	320.25	136.53
11.00	465.37	6854.68	5102.19	4947.63	4895.71	6722.28	5916.23	296.48	273.52	337.69	255.33
11.00	449.82	6188.74	4621.52	4485.25	4437.39	6036.33	5364.51	296.48	235.84	348.14	708.87
11.00	433.71	5527.60	4142.34	4023.80	3980.11	5359.66	4813.74	295.93	205.38	321.74	947.22
11.00	425.37	5177.63	3886.94	3777.40	3736.03	5005.28	4519.51	295.93	189.09	294.70	1104.93
11.00	420.37	4968.61	3734.00	3629.75	3589.79	4794.52	4343.17	295.93	180.65	286.89	1145.33
11.00	417.59	4852.81	3649.13	3547.78	3508.61	4678.04	4245.26	295.93	178.87	295.62	1021.04
11.00	413.15	4667.98	3513.48	3416.73	3378.83	4492.56	4088.70	295.93	167.26	307.53	1280.58

11.00	409.26	4527.90	3411.30	3318.15	3281.18	4350.64	3970.99	295.37	160.93	324.89	1355.53
11.00	404.82	4344.15	3275.98	3187.30	3151.63	4167.24	3814.64	295.37	151.86	312.28	1500.63
11.00	403.15	4275.39	3225.29	3138.26	3103.08	4098.75	3756.03	295.37	147.78	309.76	1598.77
11.00	400.37	4160.97	3140.85	3056.56	3022.19	3984.94	3658.40	295.37	142.35	326.76	1689.95
11.00	397.59	4046.78	3056.48	2974.90	2941.36	3871.57	3560.80	295.37	135.49	356.82	1876.55

SUMS				AVERAGE	SUMS					
35925.68	6696.78	33723.36	10978.36	5860.44	28525	3994	24531.92	74636	3994	286.61
y Losses (kJ/kg of Dry Fuel)				Total Loss Rate						
Flue Gas Constituent					Total Loss	Chemical Loss 1	Sensible and Latent Loss	Total Output	Chem Loss 2	Grams Pro CO
N2	CH4	H2O Comb	H2O Fuel MC							
2532.59	644.41	1599.60	531.87	7903.59	0	0	0.00	0	0	0.00
1813.86	141.87	1810.42	582.17	5315.46	5536	534	5001.82	15096	534	38.42
1697.53	290.06	1833.83	595.41	5654.85	4605	769	3835.81	11526	769	53.02
1625.75	352.55	1823.61	594.52	5744.04	4351	860	3490.65	10654	860	59.05
1701.31	111.05	1836.02	589.22	5088.93	3180	244	2936.56	9199	244	17.32
1842.77	101.77	1821.31	584.15	5238.97	2480	182	2297.83	6898	182	13.34
2067.07	-13.12	1783.16	567.70	5155.30	1660	29	1630.18	4718	29	3.33
2072.31	-18.66	1749.51	556.78	5129.34	1068	24	1044.42	3058	24	2.76
2029.92	20.43	1719.90	548.74	5185.52	786	41	744.48	2216	41	3.76
1972.47	213.51	1679.62	542.67	5701.13	648	103	544.38	1603	103	7.84
1794.54	318.90	1649.36	536.61	5773.77	437	95	342.59	1063	95	7.00
1652.13	393.57	1631.31	533.38	5799.10	549	140	408.78	1327	140	10.21
1599.70	410.67	1623.52	531.44	5778.20	547	146	401.35	1329	146	10.59
1623.50	348.17	1626.96	530.36	5624.52	426	103	323.42	1074	103	7.56
1637.57	457.10	1609.97	528.64	5988.64	454	130	323.33	1047	130	9.48

1683.38	480.27	1603.53	527.34	6135.89	465	138	327.08	1036	138	10.04
1613.13	546.43	1591.22	525.62	6241.18	473	154	319.15	1028	154	11.12
1593.50	590.18	1584.60	524.98	6349.57	361	123	237.51	765	123	8.89
1640.47	620.36	1578.13	523.91	6521.92	371	130	240.44	755	130	9.40
1732.19	687.26	1567.78	522.83	6878.92	130	48	82.14	245	48	3.48

19.72
roduced HC

0.00
2.62
4.19
4.73
1.23
0.86
-0.08
-0.07
0.06
0.43
0.43
0.67
0.70
0.47
0.62

0.65
0.74
0.60
0.63
0.23

Dirigo Laboratories, Inc.

Manufacturer: Pacific Energy
Model: TN20
Date: 12/20/2016
Run: 3
Control #: 034-S-74-1
Test Duration: 190
Output Category: 3

	HHV Basis	LHV Basis
Overall Efficiency	72.2%	78.1%
Combustion Efficiency	96.1%	96.1%
Heat Transfer Efficiency	75.2%	81.2%

HHV Output Rate (kJ/h)	23,451	22,246	(Btu/h)
Burn Rate (kg/h)	1.64	3.61	(lb/h)
Input (kJ/h)	32,459	30,791	(Btu/h)

Test Load Weight (dry kg)	5.2	11.4	dry lb
MC wet (%)	16.53		
MC dry (%)	19.80		
Particulate (g)	6.97		
CO (g)	287		
Test Duration (h)	3.166666667		

Emissions	Particulate	CO
g/MJ Output	0.09	3.86
g/kg Dry Fuel	1.34	55.24
g/h	2.20	90.51
lb/MM Btu Output	0.22	8.97

Air/Fuel Ratio (A/F)	11.92
----------------------	-------

Test Results in Accordance with CSA B415.1-10

Default Fuel Values

	D. Fir	Oak
HHV (kJ/kg)	19,810	19,887
%C	48.73	50
%H	6.87	6.6
%O	43.9	42.9
%Ash	0.5	0.5

VERSION: 2.4

4/15/2010

Manufacturer: Pacific Energy

Appliance Type: Non-Cat (Cat, Non-Cat, Pe

Model: TN20

Date: 12/20/2016

Run: 2

Control #: 034-S-74-1

Test Duration: 310

Burn Category 2

Wood Moisture (% DRY): 19.6

Wood Moisture (% wet): 16.39

Load Weight (lb wet): 13.80

Burn Rate (dry kg/h): 1.01

Total Particulate Emissions: 7.11 g

Temp. Units F (F or C)

Weight Units lb (kg or lb)

Fuel Data

D. Fir

HHV 19,810 kJ/kg

%C 48.73

%H 6.87

%O 43.90

%Ash 0.50

Averages

253.1

69.6

12.94

7.03

1.11

Temp. (F)

Elapsed Time (min)	Fuel Weight Remaining (lb)	Flue Gas Temp (F)	Room Temp (F)	Flue Gas Composition (%)		
				O2	CO2	CO
0	13.8	244.0	70.0	16.15	3.57	1.00
10	12.6	343.0	70.0	13.62	6.99	0.61
20	11.3	399.0	70.0	9.96	10.85	0.61
30	9.8	423.0	70.0	8.26	12.49	1.06
40	8.2	428.0	69.0	7.74	13.02	1.19
50	6.8	430.0	70.0	7.42	13.43	0.70
60	5.5	405.0	70.0	8.50	12.33	0.43
70	4.7	363.0	70.0	10.40	10.35	0.26
80	4.1	318.0	70.0	12.34	8.05	0.50
90	3.6	305.0	70.0	11.40	9.00	0.38
100	3.0	319.0	70.0	10.13	9.81	0.59
110	2.7	282.0	70.0	12.38	7.26	0.61
120	2.5	254.0	70.0	12.70	7.12	0.72
130	2.3	238.0	70.0	12.77	7.21	0.71
140	2.1	228.0	70.0	13.05	6.94	0.74
150	1.8	220.0	70.0	13.32	6.65	0.78
160	1.8	212.0	70.0	13.71	6.09	1.10
170	1.6	206.0	70.0	13.67	6.07	1.22
180	1.5	200.0	69.0	14.07	5.65	1.33
190	1.3	196.0	69.0	13.90	5.78	1.45
200	1.2	192.0	69.0	14.07	5.59	1.52
210	1.1	188.0	68.0	14.19	5.45	1.54
220	0.9	185.0	68.0	14.20	5.45	1.59
230	0.8	183.0	68.0	14.54	5.06	1.78
240	0.7	180.0	68.0	14.79	4.82	1.58
250	0.6	175.0	69.0	14.78	4.76	1.72
260	0.5	172.0	69.0	15.14	4.52	1.48
270	0.4	168.0	70.0	15.30	4.13	1.75
280	0.3	164.0	70.0	15.31	4.21	1.58
290	0.2	161.0	70.0	15.49	3.98	1.69
300	0.1	160.0	71.0	15.27	4.20	1.75
310	0.0	157.0	71.0	15.45	4.04	1.67

Manufacturer: Pacific Energy

Model: TN20

Date: 12/20/2016

Run: 2

Control #: 034-S-74-1

Test Duration: 310 min

Overall Heating Efficiency:

Combustion Efficiency:

Heat Transfer Efficiency:

	HHV	LHV
Eff	72.9%	78.8%
Comb Eff	93.1%	93.1%
HT Eff	78.3%	84.7%
Output	14,633	kJ/h
Burn Rate	1.01	kg/h
Grams CO	511	g
Input	20,073	kJ/h
MC wet	16.39	
Averages	1.11	7.03

Heat Output: 13,881

Heat Input: 19,041

Ultimate CO2

CO2-ult 19.64

Burn Duration: 5.166666667

Fo

1.061

Burn Rate: 2.2

Stack Temp: 253.4

INPUT DATA				Oxygen Calculation			Input Data		Combust	Heat
Elapsed Time	Weight Remaining (kg)	% CO [e]	% CO2 [d]	Excess Air EA	Total O2	Calc. % O2 [g]	Flue Gas (°C)	Room Temp (°C)	Eff %	Transfer %
0	6.26	1.00	3.57	329.8%	20.64	16.57	117.8	21.1	82.9%	72.5%
10	5.72	0.61	6.99	158.5%	20.44	13.14	172.8	21.1	93.7%	75.1%
20	5.13	0.61	10.85	71.4%	20.18	9.03	203.9	21.1	95.7%	77.7%
30	4.45	1.06	12.49	45.0%	20.05	7.03	217.2	21.1	93.6%	78.1%
40	3.72	1.19	13.02	38.2%	20.00	6.39	220.0	20.6	93.1%	78.3%
50	3.09	0.70	13.43	39.0%	20.01	6.23	221.1	21.1	95.9%	78.7%
60	2.50	0.43	12.33	53.9%	20.10	7.55	207.2	21.1	97.3%	78.8%
70	2.13	0.26	10.35	85.1%	20.24	9.76	183.9	21.1	98.2%	78.7%
80	1.86	0.50	8.05	129.7%	20.38	12.08	158.9	21.1	95.5%	78.1%
90	1.63	0.38	9.00	109.4%	20.32	11.13	151.7	21.1	96.9%	79.8%
100	1.36	0.59	9.81	88.9%	20.25	10.15	159.4	21.1	95.5%	79.8%
110	1.23	0.61	7.26	149.6%	20.42	12.86	138.9	21.1	93.9%	78.8%
120	1.13	0.72	7.12	150.5%	20.42	12.94	123.3	21.1	92.8%	80.0%
130	1.04	0.71	7.21	148.0%	20.42	12.85	114.4	21.1	92.9%	80.9%
140	0.95	0.74	6.94	155.8%	20.43	13.12	108.9	21.1	92.4%	81.1%

150	0.82	0.78	6.65	164.4%	20.45	13.41	104.4	21.1	91.7%	81.2%
160	0.82	1.10	6.09	173.2%	20.47	13.83	100.0	21.1	87.8%	80.8%
170	0.73	1.22	6.07	169.5%	20.46	13.78	96.7	21.1	86.6%	81.0%
180	0.68	1.33	5.65	181.4%	20.48	14.16	93.3	20.6	84.8%	80.7%
190	0.59	1.45	5.78	171.7%	20.46	13.96	91.1	20.6	83.9%	81.0%
200	0.54	1.52	5.59	176.3%	20.47	14.12	88.9	20.6	82.9%	81.0%
210	0.50	1.54	5.45	181.0%	20.48	14.26	86.7	20.0	82.4%	80.9%
220	0.41	1.59	5.45	179.0%	20.48	14.23	85.0	20.0	81.9%	81.1%
230	0.36	1.78	5.06	187.2%	20.49	14.54	83.9	20.0	79.2%	80.5%
240	0.32	1.58	4.82	206.9%	20.52	14.91	82.2	20.0	80.3%	80.5%
250	0.27	1.72	4.76	203.1%	20.51	14.89	79.4	20.6	78.8%	80.7%
260	0.23	1.48	4.52	227.4%	20.54	15.28	77.8	20.6	80.4%	80.7%
270	0.18	1.75	4.13	234.1%	20.55	15.55	75.6	21.1	76.4%	80.1%
280	0.14	1.58	4.21	239.3%	20.56	15.56	73.3	21.1	78.4%	80.7%
290	0.09	1.69	3.98	246.4%	20.57	15.74	71.7	21.1	76.4%	80.4%
300	0.05	1.75	4.20	230.1%	20.55	15.47	71.1	21.7	76.7%	81.0%
310	0.00	1.67	4.04	244.0%	20.56	15.69	69.4	21.7	76.8%	81.0%

		Air Fuel Ratio (A/F)	
72.9%	Dry Molecular Weight (Md)	29.64	
93.1%	Dry Moles Exhaust Gas (Nr):	449.22	%HC
78.3%	Air Fuel Ratio (A/F)	12.80	1.32

Combustion Efficiency: 93.1%
 Total Input (kJ): 103,710
 Total Output (kJ): 75,606
 Efficiency: 72.9%
 Total CO (g): 511.42

Btu/h 14,633 kJ/h
 Btu/h 20,073 kJ/h

h

lb/h 1.0 kg/h

Deg. F 123.0 Deg. C

69.6%	15.3	1.53	75.59	0.04	75.59	104086	4.06	6.87	2.74	19810.00	16.39
Net Eff %	Air Fuel Ratio	Wet Wt Now Wt	% Wet Consumed x	Dry Wt. Now Wtdn	% Dry Comsumed y	Fuel Properties			Oxygen /16= [c]	Calorific Value	Mw Moisture Fuel Burnt
						Total Input	Carbon /12= [a]	Hydrogen /1= [b]			
60.1%	25.0	6.26	0.00	5.24	0.00	0	4.06	6.87	2.74	19810.00	16.39
70.4%	15.4	5.72	8.70	4.78	8.70	13903	4.06	6.87	2.74	19810.00	16.39
74.4%	10.3	5.13	18.12	4.29	18.12	10521	4.06	6.87	2.74	19810.00	16.39
73.1%	8.6	4.45	28.99	3.72	28.99	11649	4.06	6.87	2.74	19810.00	16.39
72.9%	8.2	3.72	40.58	3.11	40.58	11273	4.06	6.87	2.74	19810.00	16.39
75.5%	8.3	3.09	50.72	2.58	50.72	10146	4.06	6.87	2.74	19810.00	16.39
76.7%	9.3	2.50	60.14	2.09	60.14	7891	4.06	6.87	2.74	19810.00	16.39
77.3%	11.2	2.13	65.94	1.78	65.94	5261	4.06	6.87	2.74	19810.00	16.39
74.5%	13.7	1.86	70.29	1.56	70.29	4133	4.06	6.87	2.74	19810.00	16.39
77.3%	12.6	1.63	73.91	1.37	73.91	4133	4.06	6.87	2.74	19810.00	16.39
76.2%	11.3	1.36	78.26	1.14	78.26	3382	4.06	6.87	2.74	19810.00	16.39
74.0%	14.9	1.23	80.43	1.02	80.43	1879	4.06	6.87	2.74	19810.00	16.39
74.2%	14.9	1.13	81.88	0.95	81.88	1503	4.06	6.87	2.74	19810.00	16.39
75.2%	14.7	1.04	83.33	0.87	83.33	1503	4.06	6.87	2.74	19810.00	16.39
74.9%	15.2	0.95	84.78	0.80	84.78	1879	4.06	6.87	2.74	19810.00	16.39

74.4%	15.7	0.82	86.96	0.68	86.96	1127	4.06	6.87	2.74	19810.00	16.39
70.9%	16.1	0.82	86.96	0.68	86.96	752	4.06	6.87	2.74	19810.00	16.39
70.2%	15.8	0.73	88.41	0.61	88.41	1127	4.06	6.87	2.74	19810.00	16.39
68.4%	16.4	0.68	89.13	0.57	89.13	1127	4.06	6.87	2.74	19810.00	16.39
68.0%	15.8	0.59	90.58	0.49	90.58	1127	4.06	6.87	2.74	19810.00	16.39
67.1%	16.0	0.54	91.30	0.46	91.30	752	4.06	6.87	2.74	19810.00	16.39
66.7%	16.3	0.50	92.03	0.42	92.03	1127	4.06	6.87	2.74	19810.00	16.39
66.4%	16.2	0.41	93.48	0.34	93.48	1127	4.06	6.87	2.74	19810.00	16.39
63.8%	16.5	0.36	94.20	0.30	94.20	752	4.06	6.87	2.74	19810.00	16.39
64.6%	17.7	0.32	94.93	0.27	94.93	752	4.06	6.87	2.74	19810.00	16.39
63.6%	17.5	0.27	95.65	0.23	95.65	752	4.06	6.87	2.74	19810.00	16.39
64.9%	18.9	0.23	96.38	0.19	96.38	752	4.06	6.87	2.74	19810.00	16.39
61.2%	19.2	0.18	97.10	0.15	97.10	752	4.06	6.87	2.74	19810.00	16.39
63.3%	19.5	0.14	97.83	0.11	97.83	752	4.06	6.87	2.74	19810.00	16.39
61.4%	19.9	0.09	98.55	0.08	98.55	752	4.06	6.87	2.74	19810.00	16.39
62.1%	18.9	0.05	99.28	0.04	99.28	1127	4.06	6.87	2.74	19810.00	16.39
62.2%	19.7	0.00	100.00	0.00	100.00	376	4.06	6.87	2.74	19810.00	16.39

Moisture Content MCwb: 16.39

98,364	(Btu)	Moisture of Wood (wet basis):	16.39	Dry kg :	5.24
71,709	(Btu)	Initial Dry Weight Wtdo (kg):	5.24	CA:	48.73
		Moisture Content Dry	19.60	HY:	6.87
				OX:	43.90

Load Weight (kg):	6.26				
Fuel Heating:	HHV	LHV		HHV	LHV
Value in kJ/kg - CV:	19810.00	18328.69	Btu/lb	8522.48	7885.21

79.04	20.97	2.04	6.72	0.14	0.20	33.70	71.75	6.31	0.80	419.49	32.91
Mass Balance (moles/100 mole dry flue gas)					kg Wood per 100 mole dfp Nk	Moles per kg of Dry Wood					
[h]	[u]	[w]	[j]	[k]		CO2	O2	CO	HC	N2	H2O
78.86	20.92	1.15	3.73	0.12	0.11	31.07	144.20	8.70	1.04	686.39	32.45
79.26	21.02	1.89	6.35	0.07	0.19	37.20	69.96	3.25	0.36	421.85	33.80
79.51	21.09	2.84	9.61	0.07	0.28	38.39	31.95	2.16	0.26	281.34	34.00
79.42	21.07	3.37	11.30	0.14	0.34	37.23	20.94	3.16	0.43	236.72	33.67
79.40	21.06	3.54	11.83	0.16	0.35	36.97	18.14	3.38	0.46	225.46	33.60
79.64	21.13	3.50	11.85	0.09	0.35	38.54	17.87	2.01	0.26	228.55	33.99
79.69	21.14	3.15	10.74	0.05	0.31	39.28	24.06	1.37	0.16	253.87	34.20
79.63	21.12	2.62	8.95	0.02	0.26	39.73	37.46	1.00	0.09	305.67	34.35
79.37	21.05	2.12	7.17	0.05	0.21	38.19	57.28	2.37	0.25	376.53	34.02
79.49	21.08	2.32	7.89	0.04	0.23	39.00	48.24	1.65	0.16	344.48	34.20
79.45	21.07	2.58	8.72	0.07	0.26	38.24	39.56	2.30	0.27	309.71	33.98
79.27	21.03	1.95	6.58	0.07	0.19	37.33	66.09	3.14	0.35	407.57	33.82
79.22	21.01	1.95	6.53	0.08	0.19	36.67	66.66	3.71	0.43	408.00	33.66
79.23	21.02	1.97	6.60	0.08	0.20	36.77	65.54	3.62	0.42	404.04	33.68
79.20	21.01	1.91	6.40	0.09	0.19	36.47	68.96	3.89	0.46	416.16	33.61

79.16	21.00	1.85	6.18	0.09	0.18	36.08	72.75	4.23	0.50	429.50	33.52
78.98	20.95	1.80	5.92	0.14	0.18	33.92	77.00	6.13	0.77	439.89	32.98
78.93	20.94	1.83	5.99	0.16	0.18	33.27	75.53	6.69	0.85	432.65	32.82
78.86	20.92	1.76	5.71	0.17	0.18	32.25	80.84	7.59	0.98	450.04	32.57
78.81	20.91	1.83	5.90	0.19	0.18	31.80	76.78	7.98	1.04	433.56	32.44
78.77	20.89	1.80	5.78	0.20	0.18	31.21	78.85	8.49	1.11	439.85	32.30
78.75	20.89	1.77	5.68	0.20	0.18	30.93	80.92	8.74	1.14	446.92	32.24
78.73	20.88	1.79	5.71	0.21	0.18	30.68	80.12	8.95	1.18	443.26	32.17
78.62	20.85	1.74	5.51	0.24	0.17	29.18	83.85	10.27	1.36	453.46	31.80
78.69	20.87	1.63	5.18	0.21	0.16	29.78	92.09	9.76	1.27	486.14	31.97
78.63	20.86	1.65	5.22	0.23	0.16	28.97	90.62	10.47	1.38	478.47	31.76
78.72	20.88	1.52	4.85	0.19	0.15	29.80	100.75	9.76	1.26	518.90	32.00
78.57	20.84	1.50	4.71	0.23	0.15	27.59	103.84	11.69	1.54	524.83	31.45
78.65	20.86	1.48	4.66	0.21	0.15	28.66	105.91	10.76	1.40	535.42	31.73
78.59	20.85	1.45	4.54	0.22	0.14	27.57	109.05	11.71	1.53	544.46	31.46
78.58	20.84	1.52	4.77	0.23	0.15	27.74	102.17	11.56	1.52	518.91	31.48
78.60	20.85	1.46	4.58	0.22	0.15	27.81	108.00	11.50	1.50	541.13	31.52

10.89	395.96	4065.91	3056.91	2971.89	2939.11	3920.58	3556.11	294.05	4613.66	5765.21	57604.54
Moisture Present	Stack Temp K	Heat Content Change - Ambient to Stack Temperature						Room Temp K	Energy		
		Flue Gas Constituent							CO2	O2	CO
		CO2	O2	CO	N2	CH4	H2O				
10.89	390.93	3815.94	2886.98	2811.12	2779.17	3640.11	3365.14	294.26	118.57	416.32	2487.26
10.89	445.93	6108.03	4567.12	4433.90	4386.29	5944.77	5303.56	294.26	227.25	319.50	933.21
10.89	477.04	7443.41	5529.55	5359.34	5303.67	7323.43	6407.68	294.26	285.76	176.64	622.37
10.89	490.37	8024.31	5944.69	5757.62	5698.67	7930.88	6882.56	294.26	298.72	124.47	912.25
10.89	493.15	8167.13	6047.72	5856.73	5796.90	8078.09	7000.81	293.71	301.94	109.68	976.02
10.89	494.26	8194.71	6066.07	5873.97	5814.08	8109.92	7021.26	294.26	315.82	108.40	580.27
10.89	480.37	7588.16	5633.18	5458.82	5402.31	7474.36	6526.30	294.26	298.07	135.54	395.15
10.89	457.04	6581.73	4909.84	4763.80	4713.24	6430.93	5697.26	294.26	261.49	183.93	287.19
10.89	432.04	5520.94	4140.27	4022.51	3978.68	5346.80	4812.43	294.26	210.83	237.17	680.76
10.89	424.82	5217.87	3919.00	3809.01	3767.20	5040.12	4557.48	294.26	203.51	189.04	472.31
10.89	432.59	5544.32	4157.31	4038.95	3994.96	5370.51	4832.06	294.26	212.02	164.46	660.15
10.89	412.04	4685.36	3528.66	3432.00	3393.83	4504.69	4107.14	294.26	174.88	233.22	898.27
10.89	396.48	4043.48	3055.46	2974.27	2940.66	3865.21	3560.16	294.26	148.28	203.67	1060.45
10.89	387.59	3679.84	2786.03	2713.31	2682.38	3505.88	3248.21	294.26	135.31	182.60	1034.49
10.89	382.04	3453.74	2618.00	2550.44	2521.20	3283.54	3053.48	294.26	125.95	180.53	1110.34

10.89	377.59	3273.49	2483.78	2420.27	2392.40	3106.91	2897.82	294.26	118.11	180.71	1207.87
10.89	373.15	3093.82	2349.73	2290.20	2263.71	2931.39	2742.27	294.26	104.93	180.92	1747.71
10.89	369.82	2959.45	2249.32	2192.73	2167.28	2800.48	2625.68	294.26	98.47	169.88	1907.11
10.89	366.48	2846.54	2165.35	2111.32	2086.73	2689.60	2528.34	293.71	91.79	175.04	2164.09
10.89	364.26	2757.35	2098.52	2046.41	2022.52	2603.08	2450.69	293.71	87.67	161.13	2273.66
10.89	362.04	2668.30	2031.74	1981.54	1958.35	2516.84	2373.07	293.71	83.29	160.20	2418.76
10.89	359.82	2600.53	1981.36	1932.69	1910.01	2450.27	2314.66	293.15	80.43	160.33	2490.13
10.89	358.15	2533.95	1931.34	1884.07	1861.93	2385.98	2256.49	293.15	77.75	154.74	2550.21
10.89	357.04	2489.61	1898.00	1851.66	1829.88	2343.21	2217.71	293.15	72.66	159.15	2924.34
10.89	355.37	2423.16	1848.02	1803.07	1781.82	2279.18	2159.56	293.15	72.15	170.19	2779.86
10.89	352.59	2291.45	1748.43	1706.11	1685.96	2153.41	2043.50	293.71	66.37	158.45	2979.85
10.89	350.93	2225.21	1698.52	1657.55	1637.95	2089.80	1985.39	293.71	66.30	171.13	2777.12
10.89	348.71	2115.88	1615.66	1576.84	1558.16	1985.81	1888.76	294.26	58.37	167.78	3326.38
10.89	346.48	2027.83	1549.19	1512.15	1494.20	1901.51	1811.33	294.26	58.12	164.07	3060.06
10.89	344.82	1961.89	1499.37	1463.66	1446.25	1838.46	1753.29	294.26	54.10	163.51	3330.46
10.89	344.26	1918.77	1466.42	1431.49	1414.46	1798.06	1714.75	294.82	53.22	149.83	3286.96
10.89	342.59	1852.94	1416.63	1383.01	1366.54	1735.22	1656.72	294.82	51.54	153.00	3269.48

SUMS				AVERAGE	SUMS					
35344.82	22989.76	50100.82	16559.99	6030.59	28104	7202	20901.91	75982	7202	511.42
Flue Gas Constituent				Total Loss Rate	Flue Gas Losses (kJ/kg of Dry Fuel)					
N2	CH4	H2O Comb	H2O Fuel MC		Total Loss	Chemical Loss 1	Sensible and Latent Loss	Total Output	Chem Loss 2	Grams Pro CO
1907.58	926.61	1535.95	515.42	7907.71	0	0	0.00	0	0	0.00
1850.36	323.25	1665.47	536.53	5855.56	4110	870	3239.38	9794	870	63.80
1492.12	236.24	1712.61	548.55	5074.30	2695	449	2246.17	7826	449	32.10
1349.01	383.34	1712.12	553.72	5333.63	3136	749	2387.12	8512	749	52.02
1306.99	416.22	1712.37	555.01	5378.23	3060	779	2281.61	8212	779	53.84
1328.80	237.20	1733.39	555.23	4859.10	2489	412	2077.04	7657	412	28.81
1371.50	144.50	1726.97	549.84	4621.58	1841	212	1629.43	6050	212	15.28
1440.68	76.40	1706.14	540.81	4496.65	1194	95	1098.97	4067	95	7.42
1498.10	227.08	1659.32	531.18	5044.44	1053	187	865.38	3081	187	13.86
1297.73	145.42	1659.50	528.40	4495.91	938	127	810.67	3195	127	9.62
1237.30	243.23	1658.23	531.39	4706.78	804	152	651.13	2578	152	10.99
1383.22	313.86	1625.98	523.50	5152.94	489	114	374.92	1390	114	8.33
1199.79	387.39	1599.64	517.54	5116.76	388	109	279.34	1115	109	7.88
1083.80	377.44	1590.18	514.15	4917.96	373	106	266.87	1130	106	7.69
1049.23	407.30	1580.47	512.03	4965.84	471	143	328.11	1408	143	10.33

1027.53	446.49	1571.11	510.33	5062.15	288	93	194.59	839	93	6.74
995.78	686.90	1540.74	508.64	5765.63	219	92	126.99	533	92	6.51
937.68	761.94	1529.05	507.37	5911.50	336	151	185.48	791	151	10.66
939.12	871.78	1514.41	506.31	6262.53	356	172	184.67	771	172	12.09
876.88	927.76	1506.05	505.46	6338.62	361	181	179.60	767	181	12.71
861.37	991.20	1496.94	504.62	6516.38	247	129	118.59	504	129	9.02
853.62	1020.94	1491.96	503.98	6601.39	376	199	176.97	752	199	13.93
825.32	1049.64	1487.10	503.35	6648.11	378	204	174.58	749	204	14.26
829.78	1215.24	1468.71	502.93	7172.81	272	156	115.91	479	156	10.91
866.22	1137.55	1474.88	502.29	7003.16	266	148	117.84	486	148	10.37
806.68	1231.31	1461.49	501.03	7205.17	273	159	114.37	478	159	11.12
849.93	1124.28	1470.66	500.40	6959.82	264	147	116.74	487	147	10.36
817.77	1371.08	1442.18	499.34	7682.90	291	177	114.07	460	177	12.42
800.02	1246.61	1452.50	498.50	7279.88	276	163	113.51	475	163	11.42
787.42	1365.85	1438.43	497.87	7637.63	290	177	112.34	462	177	12.44
733.98	1355.94	1438.23	497.45	7515.60	428	263	164.57	700	263	18.41
739.48	1339.75	1438.05	496.82	7488.11	142	87	54.96	234	87	6.11

36.54
roduced HC

0.00
4.05
2.24
4.02
4.22
2.16
1.03
0.36
0.85
0.54
0.74
0.53
0.53
0.51
0.69

0.46
0.47
0.78
0.89
0.95
0.67
1.04
1.07
0.83
0.77
0.84
0.76
0.93
0.85
0.93
1.38
0.46

Dirigo Laboratories, Inc.

Manufacturer: Pacific Energy
Model: TN20
Date: 12/20/2016
Run: 2
Control #: 034-S-74-1
Test Duration: 310
Output Category: 2

	HHV Basis	LHV Basis
Overall Efficiency	72.9%	78.8%
Combustion Efficiency	93.1%	93.1%
Heat Transfer Efficiency	78.3%	84.7%

HHV Output Rate (kJ/h)	14,633	13,881	(Btu/h)
Burn Rate (kg/h)	1.01	2.23	(lb/h)
Input (kJ/h)	20,073	19,041	(Btu/h)

Test Load Weight (dry kg)	5.2	11.5	dry lb
MC wet (%)	16.39		
MC dry (%)	19.60		
Particulate (g)	7.11		
CO (g)	511		
Test Duration (h)	5.166666667		

Emissions	Particulate	CO
g/MJ Output	0.09	6.76
g/kg Dry Fuel	1.36	97.69
g/h	1.38	98.99
lb/MM Btu Output	0.22	15.72

Air/Fuel Ratio (A/F)	12.80
----------------------	-------

Test Results in Accordance with CSA B415.1-10

Default Fuel Values

	D. Fir	Oak
HHV (kJ/kg)	19,810	19,887
%C	48.73	50
%H	6.87	6.6
%O	43.9	42.9
%Ash	0.5	0.5

VERSION: 2.4

4/15/2010

Manufacturer: Pacific Energy

Appliance Type: Non-Cat (Cat, Non-Cat, Pe

Model: TN20

Date: 12/20/2016

Run: 1

Control #: 034-S-74-1

Test Duration: 310

Burn Category 2

Wood Moisture (% DRY):

19.7

Wood Moisture (% wet):

16.46

Load Weight (lb wet):

14.00

Burn Rate (dry kg/h):

1.03

Total Particulate Emissions:

4.62

g

Fuel Data

D. Fir

HHV

19,810

kJ/kg

%C

48.73

%H

6.87

%O

43.90

%Ash

0.50

Averages

255.8

70.1

12.89

7.30

0.94

Temp. (F)

Elapsed Time (min)	Fuel Weight Remaining (lb)	Flue Gas Temp. (F)	Room Temp	Flue Gas Composition (%)		
				O2	CO2	CO
0	14.0	247.0	70.0	16.02	3.84	0.78
10	12.8	354.0	70.0	12.43	8.36	0.45
20	11.4	395.0	70.0	10.15	10.83	0.37
30	10.1	413.0	70.0	8.47	12.57	0.72
40	8.6	424.0	71.0	8.31	12.81	0.64
50	7.5	382.0	71.0	10.34	10.95	0.39
60	6.4	384.0	71.0	9.54	11.83	0.28
70	5.4	370.0	71.0	10.69	10.38	0.25
80	4.7	336.0	71.0	11.56	9.14	0.38
90	4.1	311.0	70.0	12.16	8.44	0.32
100	3.7	295.0	70.0	12.11	8.39	0.40
110	3.2	299.0	70.0	11.51	9.11	0.31
120	2.8	282.0	70.0	12.58	7.16	1.02
130	2.6	245.0	70.0	13.21	6.54	1.01
140	2.4	226.0	70.0	13.32	6.50	1.02
150	2.2	215.0	70.0	13.59	6.34	1.02
160	2.1	207.0	70.0	13.64	6.20	1.19
170	1.9	202.0	70.0	13.59	6.25	1.21
180	1.8	200.0	70.0	13.49	6.42	1.18
190	1.6	198.0	70.0	13.74	6.12	1.25
200	1.5	194.0	70.0	13.99	5.82	1.34
210	1.3	191.0	70.0	14.00	5.80	1.29
220	1.2	189.0	70.0	14.00	5.78	1.38
230	1.0	187.0	70.0	14.02	5.71	1.42
240	0.9	185.0	70.0	14.28	5.44	1.37
250	0.8	183.0	70.0	14.31	5.40	1.39
260	0.6	181.0	70.0	14.35	5.29	1.46
270	0.5	180.0	70.0	14.43	5.28	1.50
280	0.4	180.0	70.0	14.39	5.40	1.44
290	0.2	178.0	70.0	14.50	5.46	1.00
300	0.1	177.0	69.0	14.59	5.40	1.09
310	0.0	176.0	69.0	15.30	4.61	1.27

Manufacturer: Pacific Energy
 Model: TN20
 Date: 12/20/2016
 Run: 1
 Control #: 034-S-74-1
 Test Duration: 310 min

	HHV	LHV
Eff	74.5%	80.5%
Comb Eff	94.6%	94.6%
HT Eff	78.8%	85.2%
Output	15,161	kJ/h
Burn Rate	1.03	kg/h
Grams CO	410	g
Input	20,347	kJ/h
MC wet	16.46	
Averages	0.94	7.30

Ultimate CO:
 CO2-ult 19.64
 Fo
 1.061

INPUT DATA				Oxygen Calculation			Input
Elapsed Time	Weight Remaining (kg)	% CO [e]	% CO2 [d]	Excess Air EA	Total O2	Calc. % O2 [g]	Flue Gas (°C)
0	6.35	0.78	3.84	325.2%	20.63	16.40	119.4
10	5.81	0.45	8.36	123.0%	20.36	11.77	178.9
20	5.17	0.37	10.83	75.4%	20.20	9.19	201.7
30	4.58	0.72	12.57	47.8%	20.06	7.13	211.7
40	3.90	0.64	12.81	46.0%	20.05	6.92	217.8
50	3.40	0.39	10.95	73.2%	20.19	9.05	194.4
60	2.90	0.28	11.83	62.2%	20.14	8.17	195.6
70	2.45	0.25	10.38	84.8%	20.24	9.73	187.8
80	2.13	0.38	9.14	106.3%	20.31	10.98	168.9
90	1.86	0.32	8.44	124.2%	20.36	11.76	155.0
100	1.68	0.40	8.39	123.5%	20.36	11.77	146.1
110	1.45	0.31	9.11	108.5%	20.32	11.05	148.3
120	1.27	1.02	7.16	140.1%	20.40	12.73	138.9
130	1.18	1.01	6.54	160.2%	20.44	13.40	118.3
140	1.09	1.02	6.50	161.2%	20.44	13.43	107.8
150	1.00	1.02	6.34	166.9%	20.45	13.60	101.7
160	0.95	1.19	6.20	165.8%	20.45	13.66	97.2
170	0.86	1.21	6.25	163.3%	20.45	13.59	94.4
180	0.82	1.18	6.42	158.5%	20.44	13.43	93.3
190	0.73	1.25	6.12	166.5%	20.45	13.71	92.2
200	0.68	1.34	5.82	174.3%	20.47	13.98	90.0
210	0.59	1.29	5.80	177.1%	20.47	14.03	88.3
220	0.54	1.38	5.78	174.3%	20.47	14.00	87.2
230	0.45	1.42	5.71	175.5%	20.47	14.05	86.1
240	0.41	1.37	5.44	188.4%	20.49	14.37	85.0
250	0.36	1.39	5.40	189.3%	20.49	14.40	83.9
260	0.27	1.46	5.29	191.0%	20.49	14.47	82.8

270	0.23	1.50	5.28	189.7%	20.49	14.46	82.2
280	0.18	1.44	5.40	187.2%	20.49	14.37	82.2
290	0.09	1.00	5.46	204.1%	20.51	14.55	81.1
300	0.05	1.09	5.40	202.7%	20.51	14.57	80.6
310	0.00	1.27	4.61	234.1%	20.55	15.31	80.0

		Air Fuel Ratio (A/F)			
Overall Heating Efficiency:	74.5%	Dry Molecular Weight (Md)		29.67	
Combustion Efficiency:	94.6%	Dry Moles Exhaust Gas (Nr):		444.52	%HC
Heat Transfer Efficiency:	78.8%	Air Fuel Ratio (A/F)		12.68	1.32

Heat Output: 14,382 Btu/h 15,161 kJ/h
Heat Input: 19,301 Btu/h 20,347 kJ/h

2

Burn Duration: 5.166666667 h

Burn Rate: 2.3 lb/h 1.0 kg/h

Stack Temp: 256.1 Deg. F 124.5 Deg. C

21.2	89.8%	80.0%	71.8%	14.9	1.67	73.71	0.05	73.71
Data	Combust	Heat	Net	Air	Wet Wt	% Wet	Dry Wt.	% Dry
Room	Eff	Transfer	Eff	Fuel	Now	Consumed	Now	Consumed
Temp (°C)	%	%	%	Ratio	Wt	x	Wtdn	y
21.1	86.9%	73.4%	63.8%	25.0	6.35	0.00	5.31	0.00
21.1	96.1%	76.8%	73.8%	13.4	5.81	8.57	4.85	8.57
21.1	97.4%	77.9%	75.9%	10.5	5.17	18.57	4.32	18.57
21.1	95.6%	78.6%	75.1%	8.9	4.58	27.86	3.83	27.86
21.7	96.1%	78.5%	75.4%	8.8	3.90	38.57	3.26	38.57
21.7	97.3%	78.5%	76.4%	10.4	3.40	46.43	2.84	46.43
21.7	98.2%	79.2%	77.8%	9.8	2.90	54.29	2.43	54.29
21.7	98.3%	78.5%	77.2%	11.1	2.45	61.43	2.05	61.43
21.7	97.0%	78.6%	76.2%	12.4	2.13	66.43	1.78	66.43
21.1	97.3%	78.9%	76.8%	13.5	1.86	70.71	1.55	70.71
21.1	96.5%	79.6%	76.8%	13.4	1.68	73.57	1.40	73.57
21.1	97.6%	80.1%	78.2%	12.5	1.45	77.14	1.21	77.14
21.1	90.0%	78.4%	70.6%	14.2	1.27	80.00	1.06	80.00
21.1	89.3%	79.5%	71.0%	15.3	1.18	81.43	0.99	81.43
21.1	89.2%	80.5%	71.8%	15.4	1.09	82.86	0.91	82.86
21.1	89.0%	80.9%	72.0%	15.7	1.00	84.29	0.83	84.29
21.1	87.1%	81.1%	70.7%	15.6	0.95	85.00	0.80	85.00
21.1	87.0%	81.4%	70.9%	15.4	0.86	86.43	0.72	86.43
21.1	87.6%	81.8%	71.6%	15.2	0.82	87.14	0.68	87.14
21.1	86.4%	81.5%	70.4%	15.6	0.73	88.57	0.61	88.57
21.1	85.0%	81.3%	69.1%	16.0	0.68	89.29	0.57	89.29
21.1	85.5%	81.5%	69.6%	16.2	0.59	90.71	0.49	90.71
21.1	84.6%	81.5%	68.9%	16.0	0.54	91.43	0.45	91.43
21.1	84.1%	81.5%	68.5%	16.0	0.45	92.86	0.38	92.86
21.1	83.9%	81.3%	68.3%	16.8	0.41	93.57	0.34	93.57
21.1	83.7%	81.4%	68.1%	16.8	0.36	94.29	0.30	94.29
21.1	82.7%	81.3%	67.3%	16.9	0.27	95.71	0.23	95.71

21.1	82.3%	81.3%	67.0%	16.8	0.23	96.43	0.19	96.43
21.1	83.2%	81.6%	67.8%	16.7	0.18	97.14	0.15	97.14
21.1	87.7%	82.1%	72.0%	17.9	0.09	98.57	0.08	98.57
20.6	86.7%	81.9%	71.0%	17.7	0.05	99.29	0.04	99.29
20.6	82.9%	80.7%	66.9%	19.4	0.00	100.00	0.00	100.00

Combustion Efficiency: 94.6%
 Total Input (kJ): 105,125 99,706 (Btu)
 Total Output (kJ): 78,332 74,294 (Btu)
 Efficiency: 74.5%
 Total CO (g): 410.23

Load Weight (kg):
 Fuel Heating:
 Value in kJ/kg - CV:

105501	4.06	6.87	2.74	19810.00	16.46	79.13	20.99	2.06
Fuel Properties			Oxygen /16= [c]	Calorific Value	Mw Moisture Fuel Burnt	Mass Balance (moles/100 mole dry		
Total Input	Carbon /12= [a]	Hydrogen /1= [b]				[h]	[u]	[w]
0	4.06	6.87	2.74	19810.00	16.46	78.98	20.95	1.16
14267	4.06	6.87	2.74	19810.00	16.46	79.42	21.07	2.18
10137	4.06	6.87	2.74	19810.00	16.46	79.61	21.12	2.77
10513	4.06	6.87	2.74	19810.00	16.46	79.58	21.11	3.30
9762	4.06	6.87	2.74	19810.00	16.46	79.63	21.12	3.33
8260	4.06	6.87	2.74	19810.00	16.46	79.61	21.12	2.80
7884	4.06	6.87	2.74	19810.00	16.46	79.72	21.15	2.99
6383	4.06	6.87	2.74	19810.00	16.46	79.64	21.12	2.62
4881	4.06	6.87	2.74	19810.00	16.46	79.50	21.09	2.35
3754	4.06	6.87	2.74	19810.00	16.46	79.48	21.08	2.16
3379	4.06	6.87	2.74	19810.00	16.46	79.44	21.07	2.17
3379	4.06	6.87	2.74	19810.00	16.46	79.53	21.09	2.33
2253	4.06	6.87	2.74	19810.00	16.46	79.09	20.98	2.05
1502	4.06	6.87	2.74	19810.00	16.46	79.05	20.97	1.89
1502	4.06	6.87	2.74	19810.00	16.46	79.05	20.97	1.88
1126	4.06	6.87	2.74	19810.00	16.46	79.04	20.96	1.84
1126	4.06	6.87	2.74	19810.00	16.46	78.95	20.94	1.86
1126	4.06	6.87	2.74	19810.00	16.46	78.95	20.94	1.88
1126	4.06	6.87	2.74	19810.00	16.46	78.97	20.95	1.91
1126	4.06	6.87	2.74	19810.00	16.46	78.92	20.93	1.85
1126	4.06	6.87	2.74	19810.00	16.46	78.86	20.92	1.81
1126	4.06	6.87	2.74	19810.00	16.46	78.88	20.92	1.79
1126	4.06	6.87	2.74	19810.00	16.46	78.84	20.91	1.81
1126	4.06	6.87	2.74	19810.00	16.46	78.82	20.91	1.80
751	4.06	6.87	2.74	19810.00	16.46	78.82	20.91	1.72
1126	4.06	6.87	2.74	19810.00	16.46	78.81	20.91	1.72
1126	4.06	6.87	2.74	19810.00	16.46	78.78	20.90	1.71

751	4.06	6.87	2.74	19810.00	16.46	78.76	20.89	1.72
1126	4.06	6.87	2.74	19810.00	16.46	78.79	20.90	1.73
1126	4.06	6.87	2.74	19810.00	16.46	78.99	20.95	1.62
1126	4.06	6.87	2.74	19810.00	16.46	78.94	20.94	1.63
375	4.06	6.87	2.74	19810.00	16.46	78.81	20.91	1.49

Moisture Content MCwb: 16.46

Moisture of Wood (wet basis): 16.46
Initial Dry Weight Wtdo (kg): 5.31
Moisture Content Dry 19.70

Dry kg : 5.31
CA: 48.73
HY: 6.87
OX: 43.90

6.35
HHV LHV HHV LHV
19810.00 18328.69 Btu/lb 8522.48 7885.21

6.84	0.12	0.20	35.02	67.58	5.15	0.64	407.17	33.24
flue gas)		kg Wood per 100 mole dfp	Moles per kg of Dry Wood					
[j]	[k]	Nk	CO2	O2	CO	HC	N2	H2O
3.81	0.09	0.12	33.29	142.23	6.76	0.76	684.71	33.01
7.40	0.05	0.22	38.52	54.25	2.07	0.21	365.96	34.09
9.43	0.04	0.28	39.33	33.35	1.34	0.14	289.10	34.24
11.13	0.09	0.33	38.33	21.75	2.20	0.29	242.67	33.95
11.28	0.08	0.33	38.63	20.88	1.93	0.25	240.15	34.03
9.54	0.04	0.28	39.26	32.44	1.40	0.15	285.46	34.22
10.21	0.03	0.30	39.78	27.47	0.94	0.09	268.05	34.34
8.97	0.02	0.26	39.77	37.30	0.96	0.08	305.16	34.36
8.01	0.04	0.23	39.03	46.89	1.62	0.16	339.47	34.20
7.38	0.03	0.22	39.20	54.62	1.49	0.13	369.12	34.27
7.39	0.04	0.22	38.78	54.40	1.85	0.18	367.20	34.16
7.94	0.03	0.23	39.35	47.75	1.34	0.12	343.55	34.29
6.77	0.13	0.20	35.17	62.53	5.01	0.63	388.51	33.26
6.24	0.13	0.19	34.77	71.23	5.37	0.67	420.34	33.19
6.21	0.13	0.19	34.69	71.69	5.44	0.68	421.87	33.17
6.08	0.13	0.18	34.56	74.16	5.56	0.69	430.84	33.14
6.08	0.15	0.18	33.55	73.91	6.44	0.82	427.27	32.88
6.13	0.15	0.19	33.50	72.85	6.49	0.83	423.14	32.87
6.26	0.15	0.19	33.81	70.71	6.21	0.79	415.85	32.94
6.05	0.16	0.18	33.17	74.30	6.77	0.87	427.74	32.79
5.86	0.17	0.18	32.39	77.79	7.46	0.96	438.93	32.60
5.81	0.17	0.18	32.63	78.90	7.26	0.93	443.72	32.66
5.85	0.18	0.18	32.14	77.84	7.67	0.99	438.47	32.54
5.82	0.18	0.18	31.86	78.39	7.92	1.03	439.80	32.46
5.56	0.18	0.17	31.78	83.92	8.00	1.03	460.46	32.46
5.54	0.18	0.17	31.62	84.31	8.14	1.05	461.52	32.42
5.49	0.19	0.17	31.11	85.13	8.59	1.11	463.29	32.29

5.51	0.20	0.17	30.89	84.62	8.78	1.14	460.80	32.24
5.57	0.19	0.17	31.36	83.45	8.36	1.08	457.63	32.35
5.32	0.12	0.16	33.85	90.24	6.20	0.76	489.74	33.01
5.33	0.14	0.16	33.26	89.73	6.71	0.83	486.29	32.85
4.79	0.16	0.15	31.15	103.42	8.58	1.08	532.50	32.35

10.94	397.49	4113.42	3093.98	3008.26	2975.00	3963.44	3599.74	294.31
Moisture Present	Stack Temp K	Heat Content Change - Ambient to Stack Temperature Flue Gas Constituent						Room Temp K
		CO2	O2	CO	N2	CH4	H2O	
10.94	392.59	3884.11	2937.50	2860.04	2827.60	3707.46	3423.63	294.26
10.94	452.04	6368.12	4755.48	4615.26	4566.01	6211.30	5520.01	294.26
10.94	474.82	7347.10	5460.51	5293.06	5237.94	7223.16	6328.63	294.26
10.94	484.82	7781.65	5771.52	5591.55	5533.95	7676.56	6684.57	294.26
10.94	490.93	8027.47	5945.67	5758.23	5699.34	7936.98	6883.18	294.82
10.94	467.59	7013.91	5220.11	5061.83	5008.74	6879.75	6052.73	294.82
10.94	468.71	7061.81	5254.55	5094.92	5041.55	6929.41	6092.20	294.82
10.94	460.93	6727.22	5013.71	4863.42	4812.04	6583.29	5816.03	294.82
10.94	442.04	5921.93	4431.07	4302.60	4256.23	5756.82	5146.75	294.82
10.94	428.15	5357.56	4021.06	3907.51	3864.77	5181.30	4675.12	294.26
10.94	419.26	4985.76	3749.11	3644.98	3604.74	4806.20	4361.57	294.26
10.94	421.48	5078.49	3817.03	3710.57	3669.70	4899.56	4439.91	294.26
10.94	412.04	4685.36	3528.66	3432.00	3393.83	4504.69	4107.14	294.26
10.94	391.48	3838.65	2903.82	2827.42	2795.31	3662.54	3384.63	294.26
10.94	380.93	3408.62	2584.43	2517.89	2488.99	3239.28	3014.55	294.26
10.94	374.82	3161.13	2399.98	2338.96	2311.96	2997.08	2800.58	294.26
10.94	370.37	2981.82	2266.04	2208.97	2183.35	2822.26	2645.11	294.26
10.94	367.59	2870.04	2182.43	2127.78	2103.04	2713.55	2547.99	294.26
10.94	366.48	2825.39	2149.00	2095.32	2070.92	2670.19	2509.15	294.26
10.94	365.37	2780.78	2115.58	2062.86	2038.82	2626.90	2470.33	294.26
10.94	363.15	2691.66	2048.78	1997.97	1974.63	2540.52	2392.69	294.26
10.94	361.48	2624.91	1998.71	1949.32	1926.51	2475.92	2334.48	294.26
10.94	360.37	2580.46	1965.34	1916.89	1894.44	2432.94	2295.69	294.26
10.94	359.26	2536.04	1931.99	1884.47	1862.37	2390.03	2256.90	294.26
10.94	358.15	2491.66	1898.64	1852.06	1830.32	2347.18	2218.12	294.26
10.94	357.04	2447.32	1865.31	1819.65	1798.27	2304.41	2179.34	294.26
10.94	355.93	2403.01	1831.98	1787.26	1766.23	2261.70	2140.58	294.26

10.94	355.37	2380.87	1815.33	1771.06	1750.21	2240.38	2121.19	294.26
10.94	355.37	2380.87	1815.33	1771.06	1750.21	2240.38	2121.19	294.26
10.94	354.26	2336.61	1782.02	1738.67	1718.19	2197.78	2082.44	294.26
10.94	353.71	2335.65	1781.72	1738.49	1717.98	2195.91	2082.25	293.71
10.94	353.15	2313.54	1765.07	1722.30	1701.97	2174.65	2062.87	293.71

SUMS							AVERAGE
4784.91	5750.66	47044.26	35687.11	18357.73	50629.68	16659.76	5591.07
Energy Losses (kJ/kg of Dry Fuel)							Total
Flue Gas Constituent							Loss
CO2	O2	CO	N2	CH4	H2O Comb	H2O Fuel MC	Rate
129.31	417.80	1932.89	1936.10	676.61	1564.37	518.69	7175.77
245.32	258.00	596.40	1670.98	192.71	1687.21	541.63	5192.25
288.94	182.14	387.33	1514.30	127.60	1722.10	550.48	4772.88
298.28	125.53	633.62	1342.92	255.93	1719.82	554.38	4930.48
310.14	124.12	557.35	1368.72	222.53	1730.35	556.55	4869.77
275.38	169.32	402.81	1429.81	136.04	1711.71	547.46	4672.54
280.90	144.36	271.23	1351.41	83.46	1718.93	547.90	4398.19
267.57	186.99	275.76	1468.43	71.41	1710.78	544.87	4525.82
231.12	207.78	466.18	1444.85	144.32	1679.78	537.55	4711.58
210.00	219.65	426.38	1426.55	115.28	1666.80	532.39	4597.04
193.36	203.96	529.98	1323.66	162.87	1650.91	528.96	4593.69
199.86	182.26	383.95	1260.74	105.97	1659.74	529.81	4322.33
164.79	220.66	1435.15	1318.55	563.43	1599.16	526.17	5827.91
133.48	206.84	1534.94	1174.97	597.27	1571.49	518.26	5737.25
118.25	185.29	1554.25	1050.03	605.88	1558.27	514.21	5586.18
109.25	177.98	1586.52	996.09	617.35	1549.95	511.87	5549.02
100.05	167.48	1836.68	932.88	732.09	1532.81	510.17	5812.16
96.14	159.00	1849.12	889.89	739.43	1528.84	509.11	5771.53
95.52	151.96	1771.45	861.20	707.12	1530.93	508.68	5626.85
92.24	157.18	1931.20	872.09	774.96	1522.59	508.26	5858.51
87.19	159.38	2125.47	866.72	858.76	1511.33	507.41	6116.26
85.64	157.70	2067.63	854.83	830.86	1512.32	506.77	6015.75
82.95	152.99	2186.57	830.65	886.77	1505.25	506.35	6151.52
80.80	151.45	2257.15	819.07	918.29	1500.72	505.92	6233.40
79.18	159.33	2279.59	842.78	920.67	1499.21	505.50	6286.25
77.39	157.26	2318.29	829.94	937.86	1496.17	505.07	6321.98
74.76	155.95	2445.26	818.28	994.76	1489.03	504.65	6482.68

73.55	153.61	2499.20	806.51	1020.17	1485.78	504.44	6543.24
74.67	151.49	2381.68	800.95	968.16	1491.15	504.44	6372.54
79.10	160.80	1765.41	841.46	676.96	1519.94	504.01	5547.70
77.69	159.87	1911.78	835.43	744.56	1512.96	504.01	5746.31
72.06	182.54	2443.06	906.30	967.65	1489.31	503.80	6564.71

SUMS						
26793	5699	21094.37	78708	5699	410.23	27.91
Total Loss	Chemical Loss 1	Sensible and Latent Loss	Total Output	Chem Loss 2	Grams Produced CO HC	
0	0	0.00	0	0	0.00	0.00
3739	560	3178.96	10528	560	41.82	2.48
2442	259	2183.02	7695	259	19.25	1.16
2616	464	2152.06	7896	464	32.62	2.42
2400	378	2021.79	7362	378	26.63	1.95
1948	221	1726.94	6312	221	16.33	1.01
1750	139	1611.48	6134	139	10.49	0.59
1458	110	1347.99	4924	110	8.64	0.41
1161	148	1012.38	3720	148	11.19	0.64
871	101	769.82	2883	101	7.89	0.39
784	117	666.67	2595	117	8.83	0.50
737	83	654.65	2642	83	6.40	0.32
663	225	437.73	1590	225	15.95	1.15
435	160	274.63	1067	160	11.40	0.81
423	163	260.93	1078	163	11.56	0.82
316	124	191.05	811	124	8.85	0.63
330	145	185.35	796	145	10.25	0.75
328	146	181.89	798	146	10.32	0.75
320	140	179.86	806	140	9.89	0.72
333	153	180.16	793	153	10.79	0.79
348	169	179.06	779	169	11.87	0.88
342	164	178.17	784	164	11.55	0.85
350	174	175.99	777	174	12.22	0.90
354	180	174.86	772	180	12.61	0.94
238	121	117.63	513	121	8.49	0.63
359	184	175.29	767	184	12.96	0.96
369	195	174.01	758	195	13.67	1.01

248	133	115.31	503	133	9.31	0.69
362	189	172.84	764	189	13.31	0.99
315	138	177.27	811	138	9.87	0.69
327	150	176.45	800	150	10.69	0.76
124	64	60.10	251	64	4.55	0.33

Dirigo Laboratories, Inc.

Manufacturer: Pacific Energy
Model: TN20
Date: 12/20/2016
Run: 1
Control #: 034-S-74-1
Test Duration: 310
Output Category: 2

	HHV Basis	LHV Basis
Overall Efficiency	74.5%	80.5%
Combustion Efficiency	94.6%	94.6%
Heat Transfer Efficiency	78.8%	85.2%

HHV Output Rate (kJ/h)	15,161	14,382	(Btu/h)
Burn Rate (kg/h)	1.03	2.26	(lb/h)
Input (kJ/h)	20,347	19,301	(Btu/h)

Test Load Weight (dry kg)	5.3	11.7	dry lb
MC wet (%)	16.46		
MC dry (%)	19.70		
Particulate (g)	4.62		
CO (g)	410		
Test Duration (h)	5.166666667		

Emissions	Particulate	CO
g/MJ Output	0.06	5.24
g/kg Dry Fuel	0.87	77.30
g/h	0.89	79.40
lb/MM Btu Output	0.14	12.17

Air/Fuel Ratio (A/F)	12.68
----------------------	-------

Test Results in Accordance with CSA B415.1-10

Default Fuel Values

	D. Fir	Oak
HHV (kJ/kg)	19,810	19,887
%C	48.73	50
%H	6.87	6.6
%O	43.9	42.9
%Ash	0.5	0.5

EPA Method 28 - Weighted Average



Weighted Average: **1.6** (g/hr)

Client: Pacific Energy
 Model: TN20 (series B)
 Tracking No.: 74
 Project No.: 034-S-74-1
 Test Dates: 12/13/16 - 12/20/16

Burn Rate Category	2
Burn Rate (kg/hr-dry)	0.97
Emissions Rate (g/hr)	1.4
Emissions Rate Cap (g/hr)	15
Weighting Factor	24.47%
Run Number	5

Burn Rate Category	2
Burn Rate (kg/hr-dry)	1.01
Emissions Rate (g/hr)	1.4
Emissions Rate Cap (g/hr)	15
Weighting Factor	3.01%
Run Number	2

Burn Rate Category	2
Burn Rate (kg/hr-dry)	1.03
Emissions Rate (g/hr)	0.9
Emissions Rate Cap (g/hr)	15
Weighting Factor	27.59%
Run Number	1

Burn Rate Category	3
Burn Rate (kg/hr-dry)	1.64
Emissions Rate (g/hr)	2.2
Emissions Rate Cap (g/hr)	18
Weighting Factor	33.51%
Run Number	3


Burn Rate Category	4
Burn Rate (kg/hr-dry)	2.09
Emissions Rate (g/hr)	2.0
Emissions Rate Cap (g/hr)	18
Weighting Factor	11.43%
Run Number	4

EPA Method 28 - Weighted Average



Client: Pacific Energy
Model: TN20 (series B)
Tracking No.: 74
Project No.: 034-S-74-1
Test Dates: 12/13/16 - 12/20/16

EPA Method 28 - Weighted Average



PREBURN

JOB # 034_S_74_1 Model Designation TN20

TECHNICIAN GENBTN

DATE: 12_20_16

RUN #: 6

READING INTERVAL: 10

.

Run Time: 70

Tunnel Traverse Information								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.045	0.044	0.049	0.045	0.042	0.044	0.046	0.039
Temperature	110	110	110	110	110	110	110	110

0.044

110.000

			1	2	3	4	5	
			TEMPERATURES					
ET	SCALE READING	FLUE DRAFT	LEFT SIDE	RIGHT SIDE	BACK	TOP	BOTTOM	STOVE AVG T
0	7.7	-0.082	542	567	513	849	446	583.4
10	6.2	-0.067	551	577	518	765	441	570.4
20	5.2	-0.058	540	567	513	673	431	544.8
30	4.3	-0.056	535	571	518	659	418	540.2
40	4	-0.044	524	553	515	574	409	515
50	3.4	-0.038	503	525	507	484	406	485
60	3.3	-0.026	464	473	463	411	402	442.6
70	3.2	-0.029	428	431	429	362	394	408.8

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
Dilution Tunnel MW(wet): 28.78 lb/lb-mole
Dilution Tunnel H2O: 2.00 %
Dilution Tunnel Static: -0.400 In H2O
Tunnel Area: 0.196 ft²
Pitot Tube Cp: 0.99

Tunnel Velocity: 14.1761 ft/sec.
Intial Tunnel Flow: 155.4647 scfm
Average Tunnel Flow: 157.1129 scfm

Run # 6
 Date: 12/20/16

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Dilution Tunnel H2O: 2.00 %
 Dilution Tunnel Static: -0.400 In H2O
 Tunnel Area: 0.196 ft²
 Pitot Tube Cp: 0.99

Dilution Tunnel Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.045	0.044	0.049	0.045	0.042	0.044	0.046	0.039
Temperature	110	110	110	110	110	110	110	110

0.044
110.000

Tunnel Velocity: 14.176 ft/sec.
 Intial Tunnel Flow: 155.46 scfm
 Average Tunnel Flow: 157.11 scfm

JOB #	034_S_74_1															
TECHNICIAN	GENBTN							ROOM TEMP (F)	75.0				BEG	MID	END	AVG
DATE:	12_20_16							BAROMETRIC					30.3	30.3	30.3	30.3
RUN #:	6															
READING INTERVAL:	10															
SAMPLE BOX :	A	METER Y FACTOR:	1.007							PROBE MATERIAL:		SS				
FRONT FILTER #:	3022&3027					REAR FILTER #	REAR FILTER #:	3023								
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG			FINAL LEAK RATE (CFM)	<0.01	@	19	IN-HG					
Run Time:	300			AMBIENT FILTER #:	3026	VOLUME	1565.189	LITERS		FUEL MOISTURE DB		19.7	%			
				FINAL LEAK RATE (CFM):	<0.01	@	15	IN-HG								
TEST START TIME:	13:41								1	2	3	4	5	6		
									TEMPERATURES							
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
0	0.000	0.000	0.044	0	-0.11		NA	13.6	0	97	240	76	426	4172.13	83	77
10	1.376	0.138	0.044	2.01	-1.4	14.154	101	12.7	0.9	98	292	81	381	4172.45	84	77
20	2.764	0.139	0.044	2.01	-1.17	14.205	102	11.7	1	102	350	82	342	4172.62	87	76
30	4.159	0.140	0.044	2.02	-0.91	14.230	102	10.5	1.2	104	386	82	329	4172.7	90	76
40	5.563	0.140	0.044	2.01	-0.82	14.306	103	9	1.5	110	439	83	342	4172.74	93	76
50	6.966	0.140	0.044	2	-1.48	14.331	102	7.5	1.5	112	448	84	365	4172.78	96	76
60	8.372	0.141	0.044	2.01	-0.73	14.318	102	6.2	1.3	111	437	85	390	4172.74	98	76
70	9.788	0.142	0.044	2.02	-1.34	14.306	102	5.1	1.1	110	417	85	411	4172.7	100	77
80	11.200	0.141	0.044	2.03	-0.71	14.268	101	4.3	0.8	107	385	84	430	4172.8	101	77
90	12.621	0.142	0.044	2.01	-0.73	14.230	102	3.7	0.6	104	353	84	448	4172.85	102	76
100	14.039	0.142	0.044	2.03	-0.8	14.192	101	3.2	0.5	101	324	83	454	4172.86	103	76
110	15.462	0.142	0.044	2.02	-1.53	14.167	101	2.8	0.4	99	312	83	457	4172.82	104	76
120	16.880	0.142	0.044	2.02	-1.32	14.154	100	2.5	0.3	98	296	82	455	4172.69	104	76
130	18.301	0.142	0.044	2.04	-0.68	14.129	100	2.4	0.1	96	272	81	448	4172.53	105	76
140	19.719	0.142	0.044	2.04	-1.5	14.103	100	2.2	0.2	94	258	81	440	4172.33	105	75
150	21.138	0.142	0.044	2.02	-1.36	14.091	100	2	0.2	93	248	80	432	4172.09	105	75
160	22.555	0.142	0.044	2.02	-1.53	14.078	100	1.8	0.2	92	242	80	424	4171.88	105	75
170	23.972	0.142	0.044	2.02	-0.79	14.065	100	1.7	0.1	91	237	79	416	4171.63	105	75
180	25.385	0.141	0.044	2.02	-1.07	14.052	99	1.5	0.2	90	231	79	410	4171.4	105	74
190	26.799	0.141	0.044	2.02	-1.47	14.052	99	1.4	0.1	90	225	78	405	4171.17	105	74
200	28.211	0.141	0.044	2.01	-1.46	14.040	99	1.3	0.1	89	220	78	400	4170.9	105	74
210	29.627	0.142	0.044	2.01	-1.39	14.027	99	1.2	0.1	88	216	78	396	4170.59	105	74
220	31.041	0.141	0.044	2.01	-1.46	14.027	99	0.9	0.3	88	214	78	394	4170.27	104	74
230	32.463	0.142	0.044	2.02	-1.12	14.027	100	0.9	0	88	213	78	391	4169.95	104	74
240	33.877	0.141	0.044	2.03	-0.86	14.027	99	0.7	0.2	88	211	77	388	4169.65	104	74
250	35.296	0.142	0.044	2.01	-0.72	14.014	100	0.6	0.1	87	209	77	385	4169.31	104	74
260	36.703	0.141	0.044	2.03	-1.06	14.014	99	0.5	0.1	87	207	77	381	4169.08	104	73
270	38.116	0.141	0.044	2.03	-0.83	14.014	99	0.5	0	87	204	77	376	4168.87	104	73

[illegible]

TEST START TIME:		13:41								1	2	3	4	5	6	
										TEMPERATURES						
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
	42.348		0.044	2.02		14.121	100.3			95	280				101	75

JOB #	034_S_74_1							
TECHNICIAN	GENBTN							
DATE:	12_20_16							
RUN #:	6							
READING INTERVAL:	10							
SAMPLE BOX :	B	METER Y FACTOR:	1.002	PROBE MATERIAL:				SS
FRONT FILTER #:	3024				REAR FILTER #:	3025		
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG	FINAL LEAK RATE (CFM):	<0.01	@	19 IN-HG

Run Time: 300 Firebox Delta T 74.6

							1	2	3	4	5	6		
							TEMPERATURES							
ET	GAS METER VOLUME	SAMPLE RATE(FT3/MIN)	PROPORTIONAL RATE	FLUE DRAFT	ORIFICE DELTA H	FILTER VAC	LEFT SIDE	RIGHT SIDE	FILTER	FB TOP	FB BOT	METER	STOVE AVG T	
0	0	0	NA	0	0	1	426	428	77	359	393	83	406	
10	1.360	0.136	101	-0.04	1.96	1.49	389	381	81	379	382	84	382	
20	2.732	0.137	101	-0.05	2	1.68	366	348	81	444	370	87	374	
30	4.107	0.138	101	-0.06	1.98	1.96	365	350	82	494	357	90	379	
40	5.486	0.138	102	-0.07	1.98	1.93	397	377	83	606	346	92	414	
50	6.870	0.138	102	-0.07	1.98	1.39	439	409	84	656	337	95	441	
60	8.263	0.139	102	-0.07	2	1.59	472	439	84	666	331	97	460	
70	9.659	0.140	102	-0.06	1.99	1.34	490	461	84	654	327	99	469	
80	11.058	0.140	102	-0.05	2	1.93	491	476	84	615	322	100	467	
90	12.461	0.140	101	-0.05	2.01	1.72	490	488	83	566	319	101	462	
100	13.864	0.140	101	-0.04	2.01	1.98	484	486	83	522	318	102	453	
110	15.268	0.140	101	-0.05	2	1.7	478	487	82	485	319	103	445	
120	16.672	0.140	101	-0.04	2	1.67	470	486	82	474	321	103	441	
130	18.076	0.140	100	-0.03	2.01	1.59	460	471	81	434	325	103	428	
140	19.479	0.140	100	-0.03	2	1.72	450	452	80	402	328	104	414	
150	20.887	0.141	100	-0.03	2.01	1.65	441	438	80	381	330	104	404	
160	22.289	0.140	100	-0.03	1.99	1.62	432	427	79	367	332	104	396	
170	23.692	0.140	100	-0.03	1.99	1.71	424	416	79	356	334	104	389	
180	25.095	0.140	100	-0.03	1.99	1.36	418	406	79	346	334	104	383	
190	26.494	0.140	99	-0.03	2	1.64	409	400	78	335	334	104	377	
200	27.899	0.141	100	-0.02	1.98	1.69	400	395	78	326	333	104	371	

[illegible]

[illegible]

Ambient Sample Results:

JOB NUMBER: 034_S_74_1
 TECHNICIAN: GENBTN
 DATE: 12_20_16
 RUN NUMBER: 6

METER Y FACTOR: **1.003**

	<u>Sample Volume (L)</u>	<u>Meter Temp °F</u>	<u>ΔH</u>	<u>ΔP</u>
Start	0	90	0	0
End	1565.189	101	0	0

Total Sample Volume - Vm
 Total Sample Volume - Vm
 Average Sample Rate
 Sample Time
 Average Meter Temperature
 Total Sample Volume (Standard Conditions) - Vmstd

Total Particulates

Particulate Concentration (dry-standard)
 Particulate Emission Rate

SAMPLE INFORMATION	
1565.189	Liters
55.274	ft ³
0.18	ft ³ /min
300.00	Minutes
95.5	°F
53.365	dscf
0.5	mg
0.000009369	grams/dscf
0.000100000	grams/hour

JOB NUMBER

034_S_74_1

RUN #

6

DATE:

12_20_16

BURN RATE

1.03

KG/HR DRY

FILTER A
PARTICULATE

10.2

mg

FILTER B
PARTICULATE

9.2

mg

Total Sample Volume - Vm

Average Gas Velocity in Dilution Tunnel - vs

Average Gas Flow Rate in Dilution Tunnel - Qsd

Total Sample Volume (Standard Conditions) - Vmstd

Average Tunnel Temperature

Average Delta p

Average Gas Meter Temperature

Average Delta H

Total Time of Test

Total Particulates

Particulate Concentration (dry-standard)

Ambient Train (dry-standard)

Net (dry-standard)

Particulate Emission Rate

Total PM Emissions

Average Total PM Emissions

AVERAGE PARTICULATE

EMISSIONS RATE

% OF AVERAGE

Emissions Factor

SAMPLE A
INFORMATION

42.35

14.18

9426.77

40.86

feet/second

dscf/hour

dscf

95.5

F

0.044

101

F

2.02

in-h20

300

min

10.2

mg

0.00025

grams/dscf

0.000009369

grams/dscf

0.000240285

grams/dscf

2.27

grams/hour

11.33

grams

10.82

grams

2.16

grams/hour

104.7

2.198

g/Kg -Dry

SAMPLE B
INFORMATION

41.93

14.18

9426.77

40.31

feet/second

dscf/hour

dscf

95.5

F

0.044

100

F

2.00

in-h20

300

min

9.2

mg

0.00023

grams/dscf

0.000009369

grams/dscf

0.00021887

grams/dscf

2.06

grams/hour

10.32

grams

PREBURN

JOB # 034_S_74_1 Model Designation TN20

TECHNICIAN GENBTN

DATE: 12_16_16

RUN #: 5

READING INTERVAL: 10

.

Run Time: 60

Tunnel Traverse Information								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.041	0.043	0.047	0.044	0.043	0.047	0.040	0.039
Temperature	100	100	100	100	100	100	100	100

0.043

100.000

			1	2	3	4	5	
			TEMPERATURES					
ET	SCALE READING	FLUE DRAFT	LEFT SIDE	RIGHT SIDE	BACK	TOP	BOTTOM	STOVE AVG T
0	7.2	-0.085	548	578	484	829	487	585.2
10	5.7	-0.064	560	587	222	687	482	507.6
20	4.7	-0.059	543	561	202	584	468	471.6
30	4	-0.044	529	551	197	506	448	446.2
40	3.8	-0.036	500	524	190	410	431	411
50	3.4	-0.032	475	494	181	344	420	382.8
60	3.2	-0.032	451	462	175	300	418	361.2

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
Dilution Tunnel MW(wet): 28.78 lb/lb-mole
Dilution Tunnel H2O: 2.00 %
Dilution Tunnel Static: -0.400 In H2O
Tunnel Area: 0.196 ft²
Pitot Tube Cp: 0.99

Tunnel Velocity: 13.96826 ft/sec.
Intial Tunnel Flow: 154.1486 scfm
Average Tunnel Flow: 155.8268 scfm

Run # 5
 Date: 12/16/16

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Dilution Tunnel H2O: 2.00 %
 Dilution Tunnel Static: -0.400 In H2O
 Tunnel Area: 0.196 ft²
 Pitot Tube Cp: 0.99

Dilution Tunnel Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.041	0.043	0.047	0.044	0.043	0.047	0.040	0.039
Temperature	100	100	100	100	100	100	100	100

0.043
100.000

Tunnel Velocity: 13.968 ft/sec.
 Intial Tunnel Flow: 154.15 scfm
 Average Tunnel Flow: 155.83 scfm

JOB #	034_S_74_1															
TECHNICIAN	GENBTN							ROOM TEMP (F)	71.2				BEG	MID	END	AVG
DATE:	12_16_16							BAROMETRIC					30.12	30.12	30.12	30.12
RUN #:	5															
READING INTERVAL:	10															
SAMPLE BOX :	A	METER Y FACTOR:		1.007						PROBE MATERIAL:		SS				
FRONT FILTER #:	3016&3021					REAR FILTER #	REAR FILTER #:		3017							
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG			FINAL LEAK RATE (CFM)		<0.01	@	19	IN-HG				
Run Time:		320		AMBIENT FILTER #:		3020	VOLUME	1721.635	LITERS	FUEL MOISTURE DB			19.7	%		
				FINAL LEAK RATE (CFM):		<0.01	@	15	IN-HG							
TEST START TIME:	14:50									1	2	3	4	5	6	
										TEMPERATURES						
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
0	0.000	0.000	0.043	0.01	-0.06		NA	13.7	0	89	229	74	177	4164.07	80	71
10	1.634	0.163	0.043	2.02	-1	14.009	119	12.7	1	96	302	77	323	4164.08	81	71
20	3.030	0.140	0.043	2.02	-1.08	14.059	102	11.5	1.2	100	379	77	320	4164.1	83	71
30	4.428	0.140	0.043	2	-0.94	14.059	102	10.3	1.2	100	399	78	147	4163.97	86	71
40	5.830	0.140	0.043	2.02	-0.68	14.097	101	8.8	1.5	103	428	78	145	4163.78	90	71
50	7.241	0.141	0.043	2.02	-1.1	14.059	101	7.6	1.2	100	397	78	151	4163.63	92	70
60	8.649	0.141	0.043	2.03	-1.19	14.059	101	6.5	1.1	100	399	78	156	4163.38	94	70
70	10.069	0.142	0.043	2.03	-1.17	14.047	101	5.4	1.1	99	391	78	162	4163.23	96	70
80	11.485	0.142	0.043	2.03	-1.47	13.996	100	4.7	0.7	95	337	77	167	4163.07	97	70
90	12.909	0.142	0.043	2.04	-1.03	13.959	100	4.1	0.6	92	304	77	168	4162.83	98	70
100	14.329	0.142	0.043	2.04	-1.47	13.933	100	3.6	0.5	90	294	76	168	4162.59	98	70
110	15.752	0.142	0.043	2.04	-0.92	13.921	100	3.1	0.5	89	297	75	171	4162.33	99	69
120	17.170	0.142	0.043	2.03	-0.9	13.895	99	2.8	0.3	87	274	75	172	4162.1	99	70
130	18.592	0.142	0.043	2.02	-1.33	13.870	99	2.5	0.3	85	247	74	169	4161.8	99	69
140	20.014	0.142	0.043	2.02	-0.71	13.857	99	2.4	0.1	84	230	74	166	4161.51	100	69
150	21.434	0.142	0.043	2.04	-1.48	13.895	99	2.2	0.2	87	217	74	166	4161.68	100	70
160	22.858	0.142	0.043	2.01	-0.7	13.882	100	2.1	0.1	86	211	75	164	4162.07	100	71
170	24.276	0.142	0.043	2.01	-0.75	13.870	99	1.9	0.2	85	204	75	161	4162.46	100	71
180	25.701	0.143	0.043	2.02	-1.51	13.870	99	1.8	0.1	85	198	75	159	4162.86	101	72
190	27.123	0.142	0.043	2.02	-0.89	13.870	99	1.6	0.2	85	193	76	156	4163.28	101	72
200	28.550	0.143	0.043	2.05	-0.67	13.870	99	1.5	0.1	85	188	76	153	4163.73	102	73
210	29.971	0.142	0.043	2.02	-0.74	13.870	99	1.4	0.1	85	183	76	150	4164.1	102	73
220	31.397	0.143	0.043	2.03	-0.73	13.870	99	1.2	0.2	85	179	76	148	4164.51	102	73
230	32.825	0.143	0.043	2.04	-1.38	13.857	99	1.1	0.1	84	177	76	146	4164.78	102	73
240	34.247	0.142	0.043	2.04	-0.69	13.857	99	1	0.1	84	176	76	144	4165.08	103	73
250	35.678	0.143	0.043	2.03	-1.47	13.844	99	0.8	0.2	83	178	76	143	4165.33	103	72
260	37.102	0.142	0.043	2.04	-0.73	13.844	99	0.7	0.1	83	178	76	143	4165.45	103	72
270	38.530	0.143	0.043	2.03	-1.2	13.844	99	0.5	0.2	83	178	76	142	4165.53	103	72

[illegible]

TEST START TIME:		14:50								1	2	3	4	5	6	
										TEMPERATURES						
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
	45.669		0.043	2.03		13.915	100.3			89	249				98	71

JOB #	034_S_74_1							
TECHNICIAN	GENBTN							
DATE:	12_16_16							
RUN #:	5							
READING INTERVAL:	10							
SAMPLE BOX :	B	METER Y FACTOR:	1.002	PROBE MATERIAL:				SS
FRONT FILTER #:	3018				REAR FILTER #:	3019		
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG	FINAL LEAK RATE (CFM):	<0.01	@	19 IN-HG

Run Time: 320 Firebox Delta T 101

							1	2	3	4	5	6		
							TEMPERATURES							
ET	GAS METER VOLUME	SAMPLE RATE(FT3/MIN)	PROPORTIONAL RATE	FLUE DRAFT	ORIFICE DELTA H	FILTER VAC	LEFT SIDE	RIGHT SIDE	FILTER	FB TOP	FB BOT	METER	STOVE AVG T	
0	0	0	NA	0	0	1	447	456	73	293	418	80	358	
10	1.364	0.136	102	-0.05	1.98	1.66	415	407	76	404	418	81	393	
20	2.738	0.137	102	-0.06	2	1.63	390	363	76	465	410	83	390	
30	4.114	0.138	102	-0.06	1.97	1.56	394	371	77	495	396	86	361	
40	5.497	0.138	102	-0.06	2	1.95	419	385	77	535	381	89	373	
50	6.885	0.139	102	-0.06	1.99	1.3	436	405	77	535	368	92	379	
60	8.277	0.139	102	-0.06	1.98	1.42	442	419	77	526	356	93	380	
70	9.668	0.139	101	-0.05	1.99	1.51	453	434	77	532	345	95	385	
80	11.062	0.139	101	-0.05	1.99	1.37	457	446	76	475	334	96	376	
90	12.461	0.140	101	-0.05	1.99	1.84	445	442	75	416	326	97	359	
100	13.859	0.140	100	-0.04	1.99	1.29	432	434	75	385	320	98	348	
110	15.256	0.140	100	-0.04	1.99	1.38	431	441	74	388	316	98	349	
120	16.657	0.140	100	-0.04	1.98	1.96	430	441	74	370	314	99	345	
130	18.060	0.140	100	-0.03	1.99	1.47	423	431	73	334	314	99	334	
140	19.459	0.140	100	-0.03	2	1.63	415	419	73	302	317	99	324	
150	20.861	0.140	100	-0.03	1.98	1.88	408	411	74	283	321	99	318	
160	22.264	0.140	100	-0.03	1.99	1.2	402	404	74	271	324	99	313	
170	23.663	0.140	100	-0.02	1.99	1.96	394	397	75	261	327	100	308	
180	25.066	0.140	100	-0.02	2	1.31	385	389	75	253	328	100	303	
190	26.469	0.140	100	-0.02	2	1.97	375	380	75	244	329	101	297	
200	27.870	0.140	100	-0.02	1.98	1.97	364	372	75	236	329	101	291	

Page 2 of 3

[illegible]

Ambient Sample Results:

JOB NUMBER: 034_S_74_1
TECHNICIAN: GENBTN
DATE: 12_16_16
RUN NUMBER: 5

METER Y FACTOR: **1.003**

	<u>Sample Volume (L)</u>	<u>Meter Temp °F</u>	<u>ΔH</u>	<u>ΔP</u>
Start	0	90.5	0	0
End	1721.635	100.7	0	0

Total Sample Volume - Vm
Total Sample Volume - Vm
Average Sample Rate
Sample Time
Average Meter Temperature
Total Sample Volume (Standard Conditions) - Vmstd

Total Particulates

Particulate Concentration (dry-standard)

Particulate Emission Rate

SAMPLE INFORMATION	
1721.635	Liters
60.799	ft³
0.19	ft³/min
320.00	Minutes
95.6	°F
58.339	dscf
0.0	mg
0.000000000	grams/dscf
0.000000000	grams/hour

RUN #		5						
DATE:		12_16_16						

PREBURN

JOB # 034_S_74_1 Model Designation TN20

TECHNICIAN GENBTN

DATE: 12_15_16

RUN #: 4

READING INTERVAL: 10

.

Run Time: 60

Tunnel Traverse Information								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.037	0.044	0.045	0.043	0.043	0.044	0.044	0.039
Temperature	155	155	155	155	155	155	155	155

0.042

155.000

			1	2	3	4	5	
			TEMPERATURES					
ET	SCALE READING	FLUE DRAFT	LEFT SIDE	RIGHT SIDE	BACK	TOP	BOTTOM	STOVE AVG T
0	11	-0.081	547	563	477	593	479	531.8
10	8.1	-0.082	535	571	224	754	479	512.6
20	5.5	-0.08	560	608	231	787	466	530.4
30	4	-0.069	599	651	238	699	463	530
40	3.9	-0.065	583	636	226	570	456	494.2
50	3.3	-0.051	548	580	208	455	446	447.4
60	3.1	-0.048	500	513	188	375	434	402

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
Dilution Tunnel MW(wet): 28.78 lb/lb-mole
Dilution Tunnel H2O: 2.00 %
Dilution Tunnel Static: -0.400 In H2O
Tunnel Area: 0.196 ft²
Pitot Tube Cp: 0.99

Tunnel Velocity: 14.25454 ft/sec.
Intial Tunnel Flow: 145.5136 scfm
Average Tunnel Flow: 149.1462 scfm

Run # 4
 Date: 12/15/16

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Dilution Tunnel H2O: 2.00 %
 Dilution Tunnel Static: -0.400 In H2O
 Tunnel Area: 0.196 ft²
 Pitot Tube Cp: 0.99

Dilution Tunnel Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.037	0.044	0.045	0.043	0.043	0.044	0.044	0.039
Temperature	155	155	155	155	155	155	155	155

0.042
155.000

Tunnel Velocity:	14.255	ft/sec.
Intial Tunnel Flow:	145.51	scfm
Average Tunnel Flow	149.15	scfm

Page 1 of 3

[illegible]

TEST START TIME:		4:15								1	2	3	4	5	6	
										TEMPERATURES						
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
	21.316		0.042	2.02		14.208	100.3			121	452				97	75

JOB #	034_S_74_1							
TECHNICIAN	GENBTN							
DATE:	12_15_16							
RUN #:	4							
READING INTERVAL:	10							
SAMPLE BOX :	B	METER Y FACTOR:	1.002	PROBE MATERIAL:				SS
FRONT FILTER #:	3012				REAR FILTER #:	3013		
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG	FINAL LEAK RATE (CFM):	<0.01	@	19 IN-HG

Run Time: 150 Firebox Delta T 29.4

							1	2	3	4	5	6		
							TEMPERATURES							
ET	GAS METER VOLUME	SAMPLE RATE(FT3/MIN)	PROPORTIONAL RATE	FLUE DRAFT	ORIFICE DELTA H	FILTER VAC	LEFT SIDE	RIGHT SIDE	FILTER	FB TOP	FB BOT	METER	STOVE AVG T	
0	0	0	NA	0	0	1	472	477	69	339	425	84	378	
10	1.371	0.137	101	-0.07	1.96	1.8	421	421	77	389	412	84	359	
20	2.748	0.138	103	-0.08	1.98	1.74	425	450	81	629	396	86	410	
30	4.131	0.138	103	-0.08	1.99	1.78	482	514	84	733	383	89	454	
40	5.521	0.139	102	-0.08	1.99	2.1	532	547	83	674	376	92	459	
50	6.918	0.140	102	-0.07	1.99	1.61	563	572	83	650	372	95	467	
60	8.322	0.140	102	-0.07	1.99	2.23	581	590	83	629	372	97	473	
70	9.725	0.140	100	-0.06	1.99	1.66	575	589	85	559	373	99	460	
80	11.130	0.141	100	-0.06	1.99	2.02	556	574	84	489	375	100	440	
90	12.538	0.141	99	-0.05	1.99	1.65	524	550	84	422	379	101	415	
100	13.945	0.141	99	-0.05	1.98	1.57	493	526	83	374	382	102	393	
110	15.357	0.141	99	-0.05	1.98	1.83	467	504	82	344	383	102	376	
120	16.767	0.141	99	-0.05	1.98	1.89	449	488	81	329	383	103	366	
130	18.181	0.141	99	-0.04	1.99	2.16	444	482	81	322	383	103	362	
140	19.592	0.141	99	-0.04	1.99	1.92	433	474	81	310	384	103	355	
150	21.004	0.141	98	-0.04	1.99	1.47	425	464	80	300	383	104	349	

[illegible]

Page 3 of 3

Ambient Sample Results:

JOB NUMBER: 034_S_74_1
TECHNICIAN: GENBTN
DATE: 12_15_16
RUN NUMBER: 4

METER Y FACTOR: **1.003**

	<u>Sample Volume (L)</u>	<u>Meter Temp °F</u>	<u>ΔH</u>	<u>ΔP</u>
Start	0	86.8	0	0
End	833.188	104	0	0

Total Sample Volume - Vm
Total Sample Volume - Vm
Average Sample Rate
Sample Time
Average Meter Temperature
Total Sample Volume (Standard Conditions) - Vmstd

Total Particulates

Particulate Concentration (dry-standard)

Particulate Emission Rate

SAMPLE INFORMATION	
833.188	Liters
29.424	ft³
0.20	ft³/min
150.00	Minutes
95.4	°F
28.047	dscf
0.1	mg
0.000003565	grams/dscf
0.000040000	grams/hour

JOB NUMBER

034_S_74_1

RUN #

4

DATE:

12_15_16

BURN RATE

2.09

KG/HR DRY

FILTER A
PARTICULATE

4.7

mg

FILTER B
PARTICULATE

4.7

mg

Total Sample Volume - Vm

Average Gas Velocity in Dilution Tunnel - vs

Average Gas Flow Rate in Dilution Tunnel - Qsd

Total Sample Volume (Standard Conditions) - Vmstd

Average Tunnel Temperature

Average Delta p

Average Gas Meter Temperature

Average Delta H

Total Time of Test

Total Particulates

Particulate Concentration (dry-standard)

Ambient Train (dry-standard)

Net (dry-standard)

Particulate Emission Rate

Total PM Emissions

Average Total PM Emissions

AVERAGE PARTICULATE

EMISSIONS RATE

% OF AVERAGE

Emissions Factor

SAMPLE A
INFORMATION

21.32

14.25

8948.77

20.45

feet/second

dscf/hour

dscf

120.8

F

0.042

97

F

2.02

in-h20

150

min

4.7

mg

0.00023

grams/dscf

0.000003565

grams/dscf

0.000226225

grams/dscf

2.02

grams/hour

5.06

grams

5.11

grams

2.04

grams/hour

99.0

0.969

g/Kg -Dry

SAMPLE B
INFORMATION

21.00

14.25

8948.77

20.06

feet/second

dscf/hour

dscf

120.8

F

0.042

97

F

1.99

in-h20

150

min

4.7

mg

0.00023

grams/dscf

0.000003565

grams/dscf

0.00023074

grams/dscf

2.06

grams/hour

5.16

grams

PREBURN

JOB # 034_S_74_1 Model Designation TN 20

TECHNICIAN BTN GEN

DATE: 12_14_16

RUN #: 3

READING INTERVAL: 10

.

Run Time: 60

Tunnel Traverse Information								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.042	0.045	0.042	0.041	0.038	0.044	0.044	0.038
Temperature	125	125	125	125	125	125	125	125

0.042

125.000

			1	2	3	4	5	
			TEMPERATURES					
ET	SCALE READING	FLUE DRAFT	LEFT SIDE	RIGHT SIDE	BACK	TOP	BOTTOM	STOVE AVG T
0	7.6	-0.082	508	556	437	868	359	545.6
10	5.4	-0.075	537	580	218	788	360	496.6
20	4.3	-0.065	552	592	207	649	362	472.4
30	3.8	-0.056	537	576	201	517	361	438.4
40	3.5	-0.044	521	549	195	428	360	410.6
50	3.3	-0.039	503	522	187	373	361	389.2
60	3	-0.036	487	502	186	336	365	375.2

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
Dilution Tunnel MW(wet): 28.78 lb/lb-mole
Dilution Tunnel H2O: 2.00 %
Dilution Tunnel Static: -0.400 In H2O
Tunnel Area: 0.196 ft²
Pitot Tube Cp: 0.99

Tunnel Velocity: 14.08156 ft/sec.
Intial Tunnel Flow: 148.2256 scfm
Average Tunnel Flow: 150.9783 scfm

Run # 3
 Date: 12/14/16

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Dilution Tunnel H2O: 2.00 %
 Dilution Tunnel Static: -0.400 In H2O
 Tunnel Area: 0.196 ft²
 Pitot Tube Cp: 0.99

Dilution Tunnel Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.042	0.045	0.042	0.041	0.038	0.044	0.044	0.038
Temperature	125	125	125	125	125	125	125	125

0.042
125.000

Tunnel Velocity:	14.082	ft/sec.
Intial Tunnel Flow:	148.23	scfm
Average Tunnel Flow	150.98	scfm

Page 1 of 3

[illegible]

TEST START TIME:		21:38								1	2	3	4	5	6	
										TEMPERATURES						
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
	27.042		0.042	2.02		14.029	100.3			108	377				97	73

JOB #	034_S_74_1							
TECHNICIAN	BTN GEN							
DATE:	12_14_16							
RUN #:	3							
READING INTERVAL:	10							
SAMPLE BOX :	B	METER Y FACTOR:	1.002	PROBE MATERIAL:				SS
FRONT FILTER #:	3006				REAR FILTER #:	3007		
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG	FINAL LEAK RATE (CFM):	<0.01	@	19 IN-HG

Run Time: 190 Firebox Delta T 63.6

							1	2	3	4	5	6		
							TEMPERATURES							
ET	GAS METER VOLUME	SAMPLE RATE(FT3/MIN)	PROPORTIONAL RATE	FLUE DRAFT	ORIFICE DELTA H	FILTER VAC	LEFT SIDE	RIGHT SIDE	FILTER	FB TOP	FB BOT	METER	STOVE AVG T	
0	0	0	NA	0	0	1	486	499	69	340	366	83	383	
10	1.368	0.137	101	-0.07	1.97	1.79	460	447	77	552	371	84	436	
20	2.751	0.138	103	-0.08	1.99	1.71	463	446	79	710	372	86	470	
30	4.137	0.139	103	-0.08	1.97	1.47	499	478	80	702	367	89	444	
40	5.525	0.139	102	-0.07	2	1.64	528	506	81	696	361	91	453	
50	6.922	0.140	102	-0.07	1.99	2.14	551	535	81	687	355	94	462	
60	8.325	0.140	102	-0.06	1.99	1.96	555	556	81	599	351	96	450	
70	9.729	0.140	101	-0.06	2	1.74	543	544	82	513	348	98	428	
80	11.132	0.140	100	-0.05	1.98	2.02	529	521	82	453	347	99	408	
90	12.540	0.141	100	-0.05	1.97	1.47	517	509	81	408	349	100	394	
100	13.948	0.141	100	-0.05	1.99	2.16	502	487	80	366	351	100	378	
110	15.355	0.141	99	-0.04	1.98	1.43	489	468	80	336	355	101	366	
120	16.767	0.141	99	-0.04	1.99	2.23	481	456	79	320	359	102	359	
130	18.176	0.141	99	-0.04	1.98	1.42	473	446	79	311	363	102	354	
140	19.590	0.141	99	-0.04	1.99	1.6	463	435	78	301	365	102	348	
150	20.999	0.141	99	-0.04	1.98	1.61	454	423	78	293	366	102	342	
160	22.413	0.141	99	-0.04	2	1.89	446	412	78	284	366	102	335	
170	23.825	0.141	99	-0.04	2	1.79	435	403	77	276	364	102	329	
180	25.238	0.141	99	-0.04	1.99	1.64	426	397	77	270	361	102	324	
190	26.651	0.141	99	-0.03	2.01	1.41	418	392	77	264	359	102	320	

[illegible]

Page 3 of 3

Ambient Sample Results:

JOB NUMBER: 034_S_74_1
 TECHNICIAN: BTN GEN
 DATE: 12_14_16
 RUN NUMBER: 3

METER Y FACTOR: **1.003**

	<u>Sample Volume (L)</u>	<u>Meter Temp °F</u>	<u>ΔH</u>	<u>ΔP</u>
Start	0	85	0	0
End	1054.703	102.5	0	0

Total Sample Volume - Vm
 Total Sample Volume - Vm
 Average Sample Rate
 Sample Time
 Average Meter Temperature
 Total Sample Volume (Standard Conditions) - Vmstd

Total Particulates

Particulate Concentration (dry-standard)

Particulate Emission Rate

SAMPLE INFORMATION	
1054.703	Liters
37.246	ft³
0.20	ft³/min
190.00	Minutes
93.75	°F
35.669	dscf
0.0	mg
0.000000000	grams/dscf
0.000000000	grams/hour

JOB NUMBER

034_S_74_1

RUN #

3

DATE:

12_14_16

BURN RATE

1.64

KG/HR DRY

FILTER A
PARTICULATE

6.3

mg

FILTER B
PARTICULATE

6.2

mg

Total Sample Volume - Vm

Average Gas Velocity in Dilution Tunnel - vs

Average Gas Flow Rate in Dilution Tunnel - Qsd

Total Sample Volume (Standard Conditions) - Vmstd

Average Tunnel Temperature

Average Delta p

Average Gas Meter Temperature

Average Delta H

Total Time of Test

Total Particulates

Particulate Concentration (dry-standard)

Ambient Train (dry-standard)

Net (dry-standard)

Particulate Emission Rate

Total PM Emissions

Average Total PM Emissions

AVERAGE PARTICULATE

EMISSIONS RATE

% OF AVERAGE

Emissions Factor

SAMPLE A
INFORMATION

27.04

14.08

9058.70

25.97

feet/second

dscf/hour

dscf

107.8

F

0.042

97

F

2.02

in-h20

190

min

6.3

mg

0.00024

grams/dscf

0.000000000

grams/dscf

0.000242616

grams/dscf

2.20

grams/hour

6.96

grams

6.97

2.20

99.9

1.342

g/Kg -Dry

SAMPLE B
INFORMATION

26.65

14.08

9058.70

25.48

feet/second

dscf/hour

dscf

107.8

F

0.042

97

F

1.99

in-h20

190

min

6.2

mg

0.00024

grams/dscf

0.000000000

grams/dscf

0.00024334

grams/dscf

2.20

grams/hour

6.98

grams

grams

grams/hour

100.1

1.346

g/Kg -Dry

PREBURN

JOB # 034_S_74_1 Model Designation TN 20

TECHNICIAN BTN GEN

DATE: 12_14_16

RUN #: 2

READING INTERVAL: 10

.

Run Time: 60

Tunnel Traverse Information								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.036	0.042	0.042	0.041	0.038	0.041	0.043	0.040
Temperature	105	105	105	105	105	105	105	105

0.040

105.000

			1	2	3	4	5	
			TEMPERATURES					
ET	SCALE READING	FLUE DRAFT	LEFT SIDE	RIGHT SIDE	BACK	TOP	BOTTOM	STOVE AVG T
0	7.2	-0.083	553	576	463	853	469	582.8
10	5.5	-0.068	564	584	221	712	458	507.8
20	4.7	-0.06	548	568	202	603	445	473.2
30	4	-0.047	534	564	199	514	428	447.8
40	3.7	-0.036	518	540	194	428	415	419
50	3.5	-0.032	493	504	184	360	409	390
60	3.3	-0.029	466	468	177	315	406	366.4

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
Dilution Tunnel MW(wet): 28.78 lb/lb-mole
Dilution Tunnel H2O: 2.00 %
Dilution Tunnel Static: -0.400 In H2O
Tunnel Area: 0.196 ft²
Pitot Tube Cp: 0.99

Tunnel Velocity: 13.48719 ft/sec.
Intial Tunnel Flow: 148.3334 scfm
Average Tunnel Flow: 150.1255 scfm

Run # 2
 Date: 12/14/16

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Dilution Tunnel H2O: 2.00 %
 Dilution Tunnel Static: -0.400 In H2O
 Tunnel Area: 0.196 ft²
 Pitot Tube Cp: 0.99

Dilution Tunnel Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.036	0.042	0.042	0.041	0.038	0.041	0.043	0.040
Temperature	105	105	105	105	105	105	105	105

0.040
105.000

Tunnel Velocity: 13.487 ft/sec.
 Intial Tunnel Flow: 148.33 scfm
 Average Tunnel Flow: 150.13 scfm

JOB #	034_S_74_1															
TECHNICIAN	BTN GEN							ROOM TEMP (F)	69.6			BEG	MID	END	AVG	
DATE:	12_14_16							BAROMETRIC				29.96	29.96	29.96	29.96	
RUN #:	2															
READING INTERVAL:	10															
SAMPLE BOX :	B	METER Y FACTOR:	1.007						PROBE MATERIAL:			SS				
FRONT FILTER #:	2998&3003					REAR FILTER #	REAR FILTER #:	2999								
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG			FINAL LEAK RATE (CFM)	<0.01	@	19	IN-HG					
Run Time:	310			AMBIENT FILTER #:	3002	VOLUME	1726.447	LITERS		FUEL MOISTURE DB		19.6	%			
				FINAL LEAK RATE (CFM):	<0.01	@	15	IN-HG								
TEST START TIME:	13:50								1	2	3	4	5	6		
									TEMPERATURES							
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
0	0.000	0.000	0.04	0.01	-0.11		NA	13.8	0	91	244	72	189	4161.32	77	70
10	1.380	0.138	0.04	2	-1.18	13.560	102	12.6	1.2	97	343	76	329	4161.48	78	70
20	2.771	0.139	0.04	2	-1.41	13.596	102	11.3	1.3	100	399	76	325	4161.54	81	70
30	4.174	0.140	0.04	2.02	-0.66	13.596	102	9.8	1.5	100	423	77	151	4161.56	84	70
40	5.578	0.140	0.04	2.02	-1.22	13.608	102	8.2	1.6	101	428	77	148	4161.52	87	69
50	6.988	0.141	0.04	2.03	-1.09	13.608	102	6.8	1.4	101	430	77	153	4161.53	90	70
60	8.404	0.142	0.04	2.02	-1.39	13.584	102	5.5	1.3	99	405	77	159	4161.6	92	70
70	9.823	0.142	0.04	2.04	-0.65	13.548	101	4.7	0.8	96	363	77	166	4161.76	94	70
80	11.247	0.142	0.04	2.02	-1.21	13.499	101	4.1	0.6	92	318	76	169	4161.83	95	70
90	12.674	0.143	0.04	2.03	-1.11	13.487	101	3.6	0.5	91	305	76	168	4161.94	97	70
100	14.100	0.143	0.04	2.03	-1.16	13.487	101	3	0.6	91	319	75	169	4162.03	98	70
110	15.532	0.143	0.04	2.03	-1.37	13.450	101	2.7	0.3	88	282	75	171	4162.1	99	70
120	16.961	0.143	0.04	2.03	-0.75	13.437	100	2.5	0.2	87	254	75	168	4162.35	99	70
130	18.393	0.143	0.04	2.03	-1.17	13.413	100	2.3	0.2	85	238	74	166	4162.53	100	70
140	19.826	0.143	0.04	2.03	-1.39	13.401	100	2.1	0.2	84	228	74	164	4162.61	100	70
150	21.255	0.143	0.04	2.04	-1.52	13.388	100	1.8	0.3	83	220	73	162	4162.61	101	70
160	22.685	0.143	0.04	2.03	-1.24	13.376	100	1.8	0	82	212	73	158	4162.52	101	70
170	24.118	0.143	0.04	2.04	-0.9	13.376	100	1.6	0.2	82	206	73	155	4162.44	101	70
180	25.545	0.143	0.04	2.04	-1.14	13.364	99	1.5	0.1	81	200	73	152	4162.2	101	69
190	26.978	0.143	0.04	2.05	-1.43	13.351	100	1.3	0.2	80	196	72	149	4161.89	101	69
200	28.409	0.143	0.04	2.03	-0.82	13.351	99	1.2	0.1	80	192	72	148	4161.64	101	69
210	29.837	0.143	0.04	2.05	-0.76	13.339	99	1.1	0.1	79	188	72	146	4161.4	101	68
220	31.271	0.143	0.04	2.03	-1.41	13.339	100	0.9	0.2	79	185	71	144	4161.18	100	68
230	32.698	0.143	0.04	2.03	-1.2	13.326	99	0.8	0.1	78	183	71	143	4160.9	100	68
240	34.129	0.143	0.04	2.02	-0.95	13.326	99	0.7	0.1	78	180	71	140	4160.63	100	68
250	35.559	0.143	0.04	2.04	-1.4	13.376	100	0.6	0.1	82	175	72	138	4160.63	100	69
260	36.987	0.143	0.04	2.04	-0.62	13.364	99	0.5	0.1	81	172	72	136	4160.97	100	69
270	38.417	0.143	0.04	2.03	-0.97	13.376	100	0.4	0.1	82	168	73	134	4161.23	100	70

[illegible]

TEST START TIME:		13:50								1	2	3	4	5	6	
										TEMPERATURES						
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
	44.141		0.040	2.03		13.434	100.3			87	253				96	70

JOB #	034_S_74_1							
TECHNICIAN	BTN GEN							
DATE:	12_14_16							
RUN #:	2							
READING INTERVAL:	10							
SAMPLE BOX :	B	METER Y FACTOR:		1.002	PROBE MATERIAL:		SS	
FRONT FILTER #:	3000				REAR FILTER #:	3001		
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG	FINAL LEAK RATE (CFM):	<0.01	@	19 IN-HG

Run Time: 310 Firebox Delta T 124.4

							1	2	3	4	5	6		
							TEMPERATURES							
ET	GAS METER VOLUME	SAMPLE RATE(FT3/MIN)	PROPORTIONAL RATE	FLUE DRAFT	ORIFICE DELTA H	FILTER VAC	LEFT SIDE	RIGHT SIDE	FILTER	FB TOP	FB BOT	METER	STOVE AVG T	
0	0	0	NA	0	0	1	464	465	71	313	406	77	367	
10	1.366	0.137	102	-0.05	1.98	1.35	428	413	75	431	404	78	401	
20	2.737	0.137	102	-0.06	1.99	1.83	403	373	76	525	396	80	404	
30	4.112	0.138	102	-0.07	1.97	1.77	412	383	76	546	381	83	375	
40	5.492	0.138	102	-0.06	2.01	1.44	435	397	76	565	367	86	382	
50	6.883	0.139	102	-0.06	2	1.28	457	423	77	585	354	89	394	
60	8.280	0.140	102	-0.06	2.01	2.06	474	446	77	582	343	91	401	
70	9.679	0.140	101	-0.05	2	1.94	482	454	76	539	333	93	395	
80	11.077	0.140	101	-0.04	1.99	1.8	478	447	76	469	325	95	378	
90	12.481	0.140	101	-0.04	1.98	1.49	462	442	75	421	319	96	362	
100	13.885	0.140	101	-0.05	2.01	1.65	449	452	75	415	315	97	360	
110	15.289	0.140	100	-0.04	1.98	2.06	440	468	75	404	314	98	359	
120	16.697	0.141	100	-0.03	2.01	1.66	429	447	74	351	316	99	342	
130	18.104	0.141	100	-0.03	1.99	1.74	418	432	74	318	319	99	331	
140	19.512	0.141	100	-0.03	1.99	1.7	409	425	73	299	322	100	324	
150	20.922	0.141	100	-0.03	2.01	1.47	401	416	73	285	325	100	318	
160	22.331	0.141	100	-0.03	1.98	1.86	391	406	73	274	327	100	311	
170	23.743	0.141	100	-0.03	1.99	1.31	381	394	72	263	328	101	304	
180	25.152	0.141	99	-0.02	1.99	1.62	372	383	72	254	328	100	298	
190	26.565	0.141	100	-0.02	1.99	1.42	363	374	72	246	328	100	292	
200	27.975	0.141	99	-0.02	2	1.7	355	368	71	239	327	100	287	

[illegible]

Page 3 of 3

Ambient Sample Results:

JOB NUMBER: 034_S_74_1
 TECHNICIAN: BTN GEN
 DATE: 12_14_16
 RUN NUMBER: 2

METER Y FACTOR: **1.003**

	<u>Sample Volume (L)</u>	<u>Meter Temp °F</u>	<u>ΔH</u>	<u>ΔP</u>
Start	0	90	0	0
End	1726.447	98	0	0

Total Sample Volume - Vm
 Total Sample Volume - Vm
 Average Sample Rate
 Sample Time
 Average Meter Temperature
 Total Sample Volume (Standard Conditions) - Vmstd

Total Particulates

Particulate Concentration (dry-standard)
 Particulate Emission Rate

SAMPLE INFORMATION	
1726.447	Liters
60.969	ft ³
0.20	ft ³ /min
310.00	Minutes
94	°F
58.360	dscf
0.3	mg
0.000005141	grams/dscf
0.000058065	grams/hour

JOB NUMBER

034_S_74_1

RUN #

2

DATE:

12_14_16

BURN RATE

1.01

KG/HR DRY

FILTER A
PARTICULATE

7

mg

FILTER B
PARTICULATE

6.3

mg

Total Sample Volume - Vm

Average Gas Velocity in Dilution Tunnel - vs

Average Gas Flow Rate in Dilution Tunnel - Qsd

Total Sample Volume (Standard Conditions) - Vmstd

Average Tunnel Temperature

Average Delta p

Average Gas Meter Temperature

Average Delta H

Total Time of Test

Total Particulates

Particulate Concentration (dry-standard)

Ambient Train (dry-standard)

Net (dry-standard)

Particulate Emission Rate

Total PM Emissions

Average Total PM Emissions

AVERAGE PARTICULATE

EMISSIONS RATE

% OF AVERAGE

Emissions Factor

SAMPLE A
INFORMATION

44.14

13.49

9007.53

42.46

feet/second

dscf/hour

dscf

86.9

F

0.040

96

F

2.03

in-h20

310

min

7

mg

0.00016

grams/dscf

0.000005141

grams/dscf

0.000159723

grams/dscf

1.44

grams/hour

7.43

grams

7.11

grams

1.38

grams/hour

104.5

1.420

g/Kg -Dry

SAMPLE B
INFORMATION

43.50

13.49

9007.53

41.68

feet/second

dscf/hour

dscf

86.9

F

0.040

96

F

1.99

in-h20

310

min

6.3

mg

0.00015

grams/dscf

0.000005141

grams/dscf

0.00014602

grams/dscf

1.32

grams/hour

6.80

grams

PREBURN

JOB # 034_S_74_1 Model Designation TN 20

TECHNICIAN BTN GEN

DATE: 12_13_16

RUN #: 1

READING INTERVAL: 10

.

Run Time: 60

Tunnel Traverse Information								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.038	0.040	0.042	0.041	0.038	0.044	0.042	0.039
Temperature	100	100	100	100	100	100	100	100

0.041

100.000

			1	2	3	4	5	
			TEMPERATURES					
ET	SCALE READING	FLUE DRAFT	LEFT SIDE	RIGHT SIDE	BACK	TOP	BOTTOM	STOVE AVG T
0	7.2	-0.085	521	555	473	842	487	575.6
10	5.5	-0.071	536	567	224	706	476	501.8
20	4.4	-0.052	531	557	208	620	462	475.6
30	3.8	-0.051	511	531	198	498	443	436.2
40	3.5	-0.04	488	506	191	423	426	406.8
50	3.3	-0.031	465	472	182	350	418	377.4
60	3.1	-0.029	446	447	214	313	417	367.4

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
Dilution Tunnel MW(wet): 28.78 lb/lb-mole
Dilution Tunnel H2O: 2.00 %
Dilution Tunnel Static: -0.400 In H2O
Tunnel Area: 0.196 ft²
Pitot Tube Cp: 0.99

Tunnel Velocity: 13.59449 ft/sec.
Intial Tunnel Flow: 149.8319 scfm
Average Tunnel Flow: 152.6641 scfm

Run # 1
 Date: 12/13/16

Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Dilution Tunnel H2O: 2.00 %
 Dilution Tunnel Static: -0.400 In H2O
 Tunnel Area: 0.196 ft²
 Pitot Tube Cp: 0.99

Dilution Tunnel Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
dP	0.038	0.040	0.042	0.041	0.038	0.044	0.042	0.039
Temperature	100	100	100	100	100	100	100	100

0.041
100.000

Tunnel Velocity: 13.594 ft/sec.
 Intial Tunnel Flow: 149.83 scfm
 Average Tunnel Flow: 152.66 scfm

JOB #	034_S_74_1															
TECHNICIAN	BTN GEN							ROOM TEMP (F)	70.1				BEG	MID	END	AVG
DATE:	12_13_16							BAROMETRIC					30.2	30.2	30.2	30.2
RUN #:	1															
READING INTERVAL:	10															
SAMPLE BOX :	A	METER Y FACTOR:	1.007							PROBE MATERIAL:			SS			
FRONT FILTER #:	2992&2997					REAR FILTER #	REAR FILTER #:	2993								
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG			FINAL LEAK RATE (CFM)	<0.01	@	19	IN-HG					
Run Time:	310			AMBIENT FILTER #:	2996	VOLUME	1715.259	LITERS		FUEL MOISTURE DB			19.7	%		
				FINAL LEAK RATE (CFM):	<0.01	@	15	IN-HG								
TEST START TIME:	11:55								1	2	3	4	5	6		
									TEMPERATURES							
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
0	0.000	0.000	0.041	0	-0.01		NA	14	0	92	247	72	236	4161.33	76	70
10	1.372	0.137	0.041	2.01	-0.72	13.686	102	12.8	1.2	98	354	76	339	4161.64	78	70
20	2.761	0.139	0.041	2.04	-1.47	13.710	103	11.4	1.4	100	395	77	335	4161.76	80	70
30	4.156	0.140	0.041	2.01	-1.2	13.710	102	10.1	1.3	100	413	77	152	4161.91	84	70
40	5.553	0.140	0.041	2.03	-1.13	13.710	102	8.6	1.5	100	424	77	147	4161.9	87	71
50	6.955	0.140	0.041	2.01	-1.06	13.686	102	7.5	1.1	98	382	77	150	4161.97	90	71
60	8.367	0.141	0.041	2.03	-1.32	13.673	102	6.4	1.1	97	384	77	153	4162.14	92	71
70	9.778	0.141	0.041	2.04	-0.69	13.661	101	5.4	1	96	370	78	159	4162.22	94	71
80	11.198	0.142	0.041	2.05	-1.15	13.637	101	4.7	0.7	94	336	77	163	4162.24	96	71
90	12.614	0.142	0.041	2.03	-1.45	13.600	101	4.1	0.6	91	311	76	164	4162.25	97	70
100	14.039	0.143	0.041	2.03	-1.31	13.575	101	3.7	0.4	89	295	76	166	4162.23	98	70
110	15.461	0.142	0.041	2.04	-0.74	13.575	101	3.2	0.5	89	299	75	166	4162.19	99	70
120	16.887	0.143	0.041	2.02	-1.35	13.563	101	2.8	0.4	88	282	75	166	4162.17	99	70
130	18.304	0.142	0.041	2.02	-1.16	13.538	100	2.6	0.2	86	245	74	165	4162.15	99	70
140	19.725	0.142	0.041	2.02	-0.77	13.513	100	2.4	0.2	84	226	74	162	4162.1	100	70
150	21.143	0.142	0.041	2.02	-0.75	13.501	100	2.2	0.2	83	215	74	159	4162.18	100	70
160	22.564	0.142	0.041	2.02	-1.42	13.488	100	2.1	0.1	82	207	73	157	4162.29	100	70
170	23.986	0.142	0.041	2.02	-0.91	13.488	100	1.9	0.2	82	202	73	154	4162.37	100	70
180	25.406	0.142	0.041	2.03	-1.41	13.476	100	1.8	0.1	81	200	73	153	4162.45	100	70
190	26.830	0.142	0.041	2.03	-1.24	13.476	100	1.6	0.2	81	198	73	152	4162.57	101	70
200	28.250	0.142	0.041	2.02	-1.2	13.476	99	1.5	0.1	81	194	73	151	4162.5	101	70
210	29.674	0.142	0.041	2.02	-0.65	13.463	100	1.3	0.2	80	191	73	148	4162.61	101	70
220	31.092	0.142	0.041	2.02	-1.05	13.463	99	1.2	0.1	80	189	72	146	4162.72	101	70
230	32.517	0.143	0.041	2.03	-1.14	13.463	100	1	0.2	80	187	72	145	4162.7	101	70
240	33.935	0.142	0.041	2.03	-0.76	13.463	99	0.9	0.1	80	185	72	143	4162.72	101	70
250	35.357	0.142	0.041	2.03	-1.39	13.463	99	0.8	0.1	80	183	72	141	4162.81	101	70
260	36.777	0.142	0.041	2.02	-1.36	13.463	99	0.6	0.2	80	181	72	139	4162.79	101	70
270	38.199	0.142	0.041	2.03	-1.45	13.451	99	0.5	0.1	79	180	72	138	4162.75	101	70

[illegible]

TEST START TIME:		11:55								1	2	3	4	5	6	
										TEMPERATURES						
	GAS METER	SAMPLE	TUNNEL	ORIFICE	FILTER	TUNNEL VEL	Proportional	Scale	Weight	TUNNEL	FLUE	FILTER	FB REAR	FB	METER	AMBIENT
ET	VOLUME	RATE(FT3/MIN)	DELTA P	DELTA H	VAC	FT/SEC	Rate (%)	Weight	Chg	TEMP	TEMP	TEMP	TEMP	INT	TEMP	TEMP
	43.884		0.041	2.02		13.540	100.3			86	256				96	70

JOB #	034_S_74_1							
TECHNICIAN	BTN GEN							
DATE:	12_13_16							
RUN #:	1							
READING INTERVAL:	10							
SAMPLE BOX :	B	METER Y FACTOR:	1.002	PROBE MATERIAL:				SS
FRONT FILTER #:	2994				REAR FILTER #:	2995		
FINAL LEAK RATE (CFM):	<0.01	@	19	IN-HG	FINAL LEAK RATE (CFM):	<0.01	@	19 IN-HG

Run Time: 310 Firebox Delta T 106.4

							1	2	3	4	5	6		
							TEMPERATURES							
ET	GAS METER VOLUME	SAMPLE RATE(FT3/MIN)	PROPORTIONAL RATE	FLUE DRAFT	ORIFICE DELTA H	FILTER VAC	LEFT SIDE	RIGHT SIDE	FILTER	FB TOP	FB BOT	METER	STOVE AVG T	
0	0	0	NA	0	0	1	445	446	72	315	417	76	372	
10	1.340	0.134	101	-0.05	1.97	1.92	425	406	76	438	416	77	405	
20	2.697	0.136	102	-0.06	1.99	1.34	414	381	76	523	407	80	412	
30	4.065	0.137	102	-0.06	1.98	1.57	425	376	77	536	392	83	376	
40	5.437	0.137	102	-0.06	1.98	2.04	449	394	77	563	376	86	386	
50	6.814	0.138	102	-0.05	1.99	1.93	458	405	77	528	361	89	380	
60	8.195	0.138	102	-0.06	1.98	1.6	460	412	77	514	348	91	377	
70	9.580	0.139	101	-0.06	1.99	1.84	466	427	77	525	336	93	383	
80	10.967	0.139	101	-0.05	1.98	1.77	460	436	76	478	325	95	372	
90	12.354	0.139	101	-0.05	1.98	1.94	445	435	76	432	315	96	358	
100	13.743	0.139	100	-0.04	1.98	1.78	434	435	75	399	308	97	348	
110	15.136	0.139	100	-0.04	1.97	1.2	425	439	75	384	303	98	343	
120	16.530	0.139	100	-0.04	1.97	1.76	419	444	75	396	300	98	345	
130	17.923	0.139	100	-0.03	1.98	1.58	413	429	74	342	299	99	330	
140	19.317	0.139	100	-0.03	1.99	1.6	405	418	74	304	300	99	318	
150	20.713	0.140	100	-0.03	1.99	1.32	395	411	73	282	303	99	310	
160	22.110	0.140	100	-0.03	2	1.56	386	404	73	268	306	99	304	
170	23.504	0.139	100	-0.02	1.99	1.93	377	398	73	259	309	100	299	
180	24.900	0.140	100	-0.02	1.99	1.28	371	394	73	253	311	100	296	
190	26.299	0.140	100	-0.02	1.98	1.3	366	393	72	249	312	100	294	
200	27.696	0.140	100	-0.02	1.98	1.52	360	391	72	246	314	100	292	

[illegible]

[illegible]

Ambient Sample Results:

JOB NUMBER: 034_S_74_1
 TECHNICIAN: BTN GEN
 DATE: 12_13_16
 RUN NUMBER: 1

METER Y FACTOR: **1.003**

	<u>Sample Volume (L)</u>	<u>Meter Temp °F</u>	<u>ΔH</u>	<u>ΔP</u>
Start	0	91	0	0
End	1715.259	97	0	0

Total Sample Volume - Vm
 Total Sample Volume - Vm
 Average Sample Rate
 Sample Time
 Average Meter Temperature
 Total Sample Volume (Standard Conditions) - Vmstd

Total Particulates

Particulate Concentration (dry-standard)
 Particulate Emission Rate

SAMPLE INFORMATION	
1715.259	Liters
60.574	ft³
0.20	ft³/min
310.00	Minutes
94	°F
58.446	dscf
0.2	mg
0.000003422	grams/dscf
0.000038710	grams/hour

JOB NUMBER

034_S_74_1

RUN #

1

DATE:

12_13_16

BURN RATE

1.03

KG/HR DRY

FILTER A
PARTICULATE

4.3

mg

FILTER B
PARTICULATE

4.2

mg

Total Sample Volume - Vm

Average Gas Velocity in Dilution Tunnel - vs

Average Gas Flow Rate in Dilution Tunnel - Qsd

Total Sample Volume (Standard Conditions) - Vmstd

Average Tunnel Temperature

Average Delta p

Average Gas Meter Temperature

Average Delta H

Total Time of Test

Total Particulates

Particulate Concentration (dry-standard)

Ambient Train (dry-standard)

Net (dry-standard)

Particulate Emission Rate

Total PM Emissions

Average Total PM Emissions

AVERAGE PARTICULATE

EMISSIONS RATE

% OF AVERAGE

Emissions Factor

SAMPLE A
INFORMATION

43.88

13.59

9159.84

42.55

feet/second

dscf/hour

dscf

86.4

F

0.041

96

F

2.02

in-h20

310

min

4.3

mg

0.00010

grams/dscf

0.000003422

grams/dscf

0.000097646

grams/dscf

0.89

grams/hour

4.62

grams

4.62

grams

0.89

grams/hour

100.1

0.871

g/Kg -Dry

SAMPLE B
INFORMATION

43.08

13.59

9159.84

41.60

feet/second

dscf/hour

dscf

86.4

F

0.041

96

F

1.99

in-h20

310

min

4.2

mg

0.00010

grams/dscf

0.000003422

grams/dscf

0.00009754

grams/dscf

0.89

grams/hour

4.62

grams

grams

grams/hour

99.9

0.870

g/Kg -Dry

Fuel Load Information

Project Number
034-S-74-1

Client
Pacific Energy

Date
12/20/2016

Firebox Volume (ft³) 2

Assessment No

Longest useable measurement parallel or perpendicular to front of unit. 18.25"

Test Fuel Charge Range 13.2 - 14.2
Coal bed range (lbs) 2.80 - 3.50

Vol ≤ 1.5 ft ³	Vol > 1.5 ≤ 3.0 ft ³	Vol > 3.0 ft ³
		
		

Fuel Piece Length 15.25 Inches

Run # 6

Test Run Fuel Moisture (db)

Hydronic Heater

Weight Without
Cleats (Lbs)

Piece	S1	S2	S3	S4	S5	S6	AVG (%)	Fuel
1	19.5	19.2	19.1				19.3	1.50
2	19.6	19.1	19.0				19.2	1.46
3	19.2	19.9	19.2				19.4	1.65
4	19.7	22.4	22.3				21.5	3.62
5	21.2	19.2	19.3				19.9	3.55
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
Spacer Average	19						19.7	Total: 13.6lbs

Signature

Date

Fuel Load Information

Project Number
034-S-74-1

Client
Pacific Energy

Date
12/16/2016

Firebox Volume (ft³) 2

Assessment No

Longest useable measurement parallel or perpendicular to front of unit. 18.25"

Test Fuel Charge Range 13.2 - 14.2
Coal bed range (lbs) 2.80 - 3.50

Vol ≤ 1.5 ft ³	Vol > 1.5 ≤ 3.0 ft ³	Vol > 3.0 ft ³
		
		

Fuel Piece Length 15.25 Inches

Run # 5

Test Run Fuel Moisture (db)					Hydronic Heater		Weight (Lbs)			
Piece	S1	S2	S3	S4	S5	S6	AVG (%)		Fuel	
1	19.0	20.4	20.1					19.8		1.48
2	19.0	19.0	19.6					19.2		1.65
3	19.6	19.0	19.4					19.3		1.61
4	21.6	22.3	21.6					21.8		4.17
5	19.0	19.4	19.3					19.2		3.30
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
Spacer Average	19					Fuel Average		19.7	Total:	13.7 lbs

Signature

Date

Fuel Load Information

Project Number
034-S-74-1

Client
Pacific Energy

Date
12/15/2016

Firebox Volume (ft³) 2

Assessment No

Longest useable measurement parallel or perpendicular to front of unit. 18.25"

Test Fuel Charge Range 13.2 - 14.2
Coal bed range (lbs) 2.80 - 3.50

Vol ≤ 1.5 ft ³	Vol > 1.5 ≤ 3.0 ft ³	Vol > 3.0 ft ³
		
		

Fuel Piece Length 15.25 Inches

Run # 4

Test Run Fuel Moisture (db)					Hydronic Heater		AVG (%)		Weight Without Cleats (Lbs)	
Piece	S1	S2	S3	S4	S5	S6			Fuel	
1	19.5	20.4	20.4				20.1			1.63
2	19.0	20.3	19.6				19.6			1.65
3	19.3	19.0	20.6				19.6			1.76
4	21.3	22.1	19.0				20.8			3.48
5	19.1	19.0	20.3				19.5			3.42
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
Spacer Average	19.5					Fuel Average	19.9		Total:	13.8lbs

Signature

Date

Fuel Load Information

Project Number
034-S-74-1

Client
Pacific Energy

Date
12/14/2016

Firebox Volume (ft³) 2

Assessment No

Longest useable measurement parallel or perpendicular to front of unit. 18.25"

Test Fuel Charge Range 13.2 - 14.2
Coal bed range (lbs) 2.80 - 3.50

Vol ≤ 1.5 ft ³	Vol > 1.5 ≤ 3.0 ft ³	Vol > 3.0 ft ³
		
		

Fuel Piece Length 15.25 Inches

Run # 3

Test Run Fuel Moisture (db)					Hydronic Heater		AVG (%)		Weight Without Cleats (Lbs)	
Piece	S1	S2	S3	S4	S5	S6			Fuel	
1	19.7	19.1	19.0				19.3			1.68
2	19.3	19.5	19.2				19.3			1.52
3	20.4	19.3	20.1				19.9			1.79
4	20.5	19.6	19.5				19.9			3.31
5	21.4	21.6	20.4				21.1			3.84
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
Spacer Average	19.5					Fuel Average	19.8		Total:	13.7lbs

Signature

Date

Fuel Load Information

Project Number
034-S-74-1

Client
Pacific Energy

Date
12/14/2016

Firebox Volume (ft³) 2

Assessment No

Longest useable measurement parallel or perpendicular to front of unit. 18.25"

Test Fuel Charge Range 13.2 - 14.2
Coal bed range (lbs) 2.80 - 3.50

Vol ≤ 1.5 ft ³	Vol > 1.5 ≤ 3.0 ft ³	Vol > 3.0 ft ³
		
		

Fuel Piece Length 15.25 Inches

Run # 2

Test Run Fuel Moisture (db)					Hydronic Heater		AVG (%)		Weight Without Cleats (Lbs)	
Piece	S1	S2	S3	S4	S5	S6			Fuel	
1	19.3	20.0	19.6				19.6			1.68
2	19.4	19.0	19.2				19.2			1.70
3	19.2	19.5	20.6				19.8			1.79
4	19.4	20.3	21.0				20.2			3.24
5	20.4	19.9	19.0				19.8			3.88
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
Spacer Average	19					Fuel Average	19.6		Total:	13.8lbs

Signature

Date

Fuel Load Information

Project Number
034-S-074-1

Client
Pacific Energy

Date
12/13/2016

Firebox Volume (ft³) 2

Assessment No

Longest useable measurement parallel or perpendicular to front of unit. 18.25"

Test Fuel Charge Range 13.2 - 14
Coal bed range (lbs) 2.80 - 3.50

Vol ≤ 1.5 ft ³	Vol > 1.5 ≤ 3.0 ft ³	Vol > 3.0 ft ³
		
		

Fuel Piece Length 15.25 Inches

Run # 1

Test Run Fuel Moisture (db)					Hydronic Heater		AVG (%)		Weight Without Cleats (Lbs)	
Piece	S1	S2	S3	S4	S5	S6			Fuel	
1	20.2	19.4	21.0					20.2		1.72
2	20.5	19.0	19.0					19.5		1.57
3	19.1	19.0	19.0					19.0		1.61
4	20.2	20.8	19.7					20.2		3.24
5	20.3	20.6	19.0					20.0		4.19
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
Spacer Average	19					Fuel Average		19.7	Total:	14.0 lbs

Signature

Date











1.1

1.88

3.24

1.68

1.79

1.70



11.4

12.5

12.1

3.84

3.31

1.68

1.79

1.52





3.48

3.42

1.76

1.65

1.63





3.62

3.55

1.48

5.91

1.50

2.51

1.41



NOT TO BE BROKEN
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
DATE SEALED 12/25/11
MODEL # TN 27

TRUE NORTH

ATTENTION:

THIS SEAL IS NOT TO BE BROKEN WITHOUT PRIOR AUTHORIZATION
BY THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

COMPLIANCE HAS BEEN SEALED IN ACCORDANCE WITH
REQUIREMENTS OF 40 CFR PART 60 SUBPART AAA 560.5

34-S-74-1

DATE SEALED

12/28/

BY Pacific Energy

MODEL #

TN-20